

Edition 2026



Courbes de puissances

UE Multisplit

Hisense

Official Partner

aldes



**2AMW35U4RGC - UE MULTI 2
POSTES 3,5 KW**



**2AMW42U4RGC - UE MULTI 2
POSTES 4,2 KW**



**2AMW52U4RXC - UE MULTI 2
POSTES 5,2 KW**




**3AMW52U4RJC - UE MULTI 3
POSTES 5,2 KW**



**3AMW72U4RJC - UE MULTI 3
POSTES 7,2 KW**



**4AMW81U4RJC - UE MULTI 4
POSTES 8,1 KW**



**5AMW105U4RQC - UE MULTI 5
POSTES 10,5 KW**



**5AMW125U4RTA - UE MULTI 5
POSTES 12,5 KW**

2AMW35U4RGC

-

UE MULTI 2 POSTES 3,5 KW

4. CAPACITIES AND SELECTION DATA

12K

	Cooling Operation PERFORMANCE DATA																																																					
	OUTDOOR DB (°C)																																																					
COMBINATION (%)	IDDB (°C)	ID WB (°C)	-15				-7				0				10				15				21				25				27				30				35				40				45				50			
			Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT								
130%	21	18	2.66	1.53	0.58	220	2.66	1.53	0.58	246	2.66	1.53	0.58	272	2.95	1.70	0.58	289	2.95	1.70	0.58	323	4.49	2.59	0.58	684	4.30	2.47	0.58	719	4.13	2.38	0.58	752	3.97	2.29	0.58	787	3.75	2.16	0.58	838	3.44	1.98	0.58	890	3.18	1.83	0.58	923	2.64	1.52	0.58	959
	21	20	2.79	1.27	0.46	260	2.79	1.27	0.46	286	2.79	1.27	0.46	312	3.10	1.41	0.46	329	3.10	1.41	0.46	363	4.72	2.15	0.46	716	4.52	2.06	0.46	753	4.34	1.98	0.46	788	4.18	1.90	0.46	824	3.94	1.80	0.46	878	3.62	1.65	0.46	932	3.35	1.53	0.46	968	2.78	1.27	0.46	1004
	22	18	2.66	1.64	0.62	220	2.66	1.64	0.62	246	2.66	1.64	0.62	272	2.95	1.82	0.62	289	2.95	1.82	0.62	323	4.49	2.77	0.62	684	4.30	2.65	0.62	719	4.13	2.54	0.62	752	3.97	2.45	0.62	787	3.75	2.31	0.62	838	3.44	2.12	0.62	890	3.18	1.96	0.62	923	2.64	1.63	0.62	959
	22	20	2.79	1.39	0.50	260	2.79	1.39	0.50	286	2.79	1.39	0.50	312	3.10	1.54	0.50	329	3.10	1.54	0.50	363	4.72	2.34	0.50	716	4.52	2.24	0.50	753	4.34	2.15	0.50	788	4.18	2.07	0.50	824	3.94	1.95	0.50	878	3.62	1.79	0.50	932	3.35	1.66	0.50	968	2.78	1.38	0.50	1004
	22	22	2.96	1.11	0.38	299	2.96	1.11	0.38	325	2.96	1.11	0.38	351	3.29	1.24	0.38	368	3.29	1.24	0.38	402	5.00	1.88	0.38	748	4.79	1.80	0.38	787	4.60	1.73	0.38	823	4.43	1.66	0.38	861	4.18	1.57	0.38	917	3.83	1.44	0.38	974	3.55	1.33	0.38	1011	2.94	1.11	0.38	1049
	23	18	2.66	1.74	0.66	220	2.66	1.74	0.66	246	2.66	1.74	0.66	272	2.95	1.94	0.66	289	2.95	1.94	0.66	323	4.49	2.95	0.66	684	4.30	2.82	0.66	719	4.13	2.71	0.66	752	3.97	2.61	0.66	787	3.75	2.46	0.66	838	3.44	2.26	0.66	890	3.18	2.09	0.66	923	2.64	1.73	0.66	959
	23	20	2.79	1.50	0.54	260	2.79	1.50	0.54	286	2.79	1.50	0.54	312	3.10	1.66	0.54	329	3.10	1.66	0.54	363	4.72	2.53	0.54	716	4.52	2.42	0.54	753	4.34	2.33	0.54	788	4.18	2.24	0.54	824	3.94	2.11	0.54	878	3.62	1.94	0.54	932	3.35	1.79	0.54	968	2.78	1.49	0.54	1004
	23	22	2.96	1.23	0.42	299	2.96	1.23	0.42	325	2.96	1.23	0.42	351	3.29	1.37	0.42	368	3.29	1.37	0.42	402	5.00	2.08	0.42	748	4.79	1.99	0.42	787	4.60	1.91	0.42	823	4.43	1.84	0.42	861	4.18	1.74	0.42	917	3.83	1.59	0.42	974	3.55	1.47	0.42	1011	2.94	1.22	0.42	1049
	24	18	2.66	1.85	0.70	220	2.66	1.85	0.70	246	2.66	1.85	0.70	272	2.95	2.05	0.70	289	2.95	2.05	0.70	323	4.49	3.13	0.70	684	4.30	2.99	0.70	719	4.13	2.88	0.70	752	3.97	2.76	0.70	787	3.75	2.61	0.70	838	3.44	2.39	0.70	890	3.18	2.21	0.70	923	2.64	1.84	0.70	959
	24	20	2.79	1.61	0.58	260	2.79	1.61	0.58	286	2.79	1.61	0.58	312	3.10	1.79	0.58	329	3.10	1.79	0.58	363	4.72	2.72	0.58	716	4.52	2.60	0.58	753	4.34	2.50	0.58	788	4.18	2.40	0.58	824	3.94	2.27	0.58	878	3.62	2.08	0.58	932	3.35	1.93	0.58	968	2.78	1.60	0.58	1004
	24	22	2.96	1.35	0.46	299	2.96	1.35	0.46	325	2.96	1.35	0.46	351	3.29	1.50	0.46	368	3.29	1.50	0.46	402	5.00	2.28	0.46	748	4.79	2.18	0.46	787	4.60	2.10	0.46	823	4.43	2.02	0.46	861	4.18	1.90	0.46	917	3.83	1.75	0.46	974	3.55	1.62	0.46	1011	2.94	1.34	0.46	1049
	24	24	3.14	1.05	0.34	339	3.14	1.05	0.34	365	3.14	1.05	0.34	391	3.49	1.17	0.34	408	3.49	1.17	0.34	442	5.30	1.78	0.34	781	5.07	1.70	0.34	821	4.88	1.64	0.34	859	4.69	1.58	0.34	898	4.43	1.49	0.34	957	4.06	1.36	0.34	1016	3.76	1.26	0.34	1055	3.12	1.05	0.34	1095
	25	18	2.66	1.96	0.74	220	2.66	1.96	0.74	246	2.66	1.96	0.74	272	2.95	2.17	0.74	289	2.95	2.17	0.74	323	4.49	3.30	0.74	684	4.30	3.16	0.74	719	4.13	3.04	0.74	752	3.97	2.92	0.74	787	3.75	2.76	0.74	838	3.44	2.53	0.74	890	3.18	2.34	0.74	923	2.64	1.94	0.74	959
	25	20	2.79	1.72	0.62	260	2.79	1.72	0.62	286	2.79	1.72	0.62	312	3.10	1.91	0.62	329	3.10	1.91	0.62	363	4.72	2.91	0.62	716	4.52	2.78	0.62	753	4.34	2.67	0.62	788	4.18	2.57	0.62	824	3.94	2.43	0.62	878	3.62	2.23	0.62	932	3.35	2.06	0.62	968	2.78	1.71	0.62	1004
	25	22	2.96	1.47	0.50	299	2.96	1.47	0.50	325	2.96	1.47	0.50	351	3.29	1.63	0.50	368	3.29	1.63	0.50	402	5.00	2.48	0.50	748	4.79	2.37	0.50	787	4.60	2.28	0.50	823	4.43	2.20	0.50	861	4.18	2.07	0.50	917	3.83	1.90	0.50	974	3.55	1.76	0.50	1011	2.94	1.46	0.50	1049
	25	24	3.14	1.18	0.38	339	3.14	1.18	0.38	365	3.14	1.18	0.38	391	3.49	1.31	0.38	408	3.49	1.31	0.38	442	5.30	1.99	0.38	781	5.07	1.91	0.38	821	4.88	1.83	0.38	859	4.69	1.76	0.38	898	4.43	1.66	0.38	957	4.06	1.53	0.38	1016	3.76	1.41	0.38	1055	3.12	1.17	0.38	1095
	26	18	2.66	2.06	0.78	220	2.66	2.06	0.78	246	2.66	2.06	0.78	272	2.95	2.29	0.78	289	2.95	2.29	0.78	323	4.49	3.48	0.78	684	4.30	3.33	0.78	719	4.13	3.21	0.78	752	3.97	3.08	0.78	787	3.75	2.91	0.78	838	3.44	2.67	0.78	890	3.18	2.47	0.78	923	2.64	2.05	0.78	959
	26	20	2.79	1.83	0.66	260	2.79	1.83	0.66	286	2.79	1.83	0.66	312	3.10	2.03	0.66	329	3.10	2.03	0.66	363	4.72	3.10	0.66	716	4.52	2.96	0.66	753	4.34	2.85	0.66	788	4.18	2.74	0.66	824	3.94	2.58	0.66	878	3.62	2.37	0.66	932	3.35	2.19	0.66	968	2.78	1.82	0.66	1004
	26	22	2.96	1.59	0.54	299	2.96	1.																																														

4. CAPACITIES AND SELECTION DATA

	Cooling Operation PERFORMANCE DATA																																																					
	OUTDOOR DB (°C)																																																					
COMBINATION (%)	IDDB (°C)	ID WB (°C)	-15				-7				0				10				15				21				25				27				30				35				40				45				50			
			Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT								
120%	21	18	2.58	1.55	0.60	209	2.58	1.55	0.60	233	2.58	1.55	0.60	258	2.87	1.72	0.60	274	2.87	1.72	0.60	307	4.36	2.61	0.60	650	4.17	2.50	0.60	684	4.01	2.40	0.60	715	3.86	2.31	0.60	748	3.64	2.18	0.60	797	3.34	2.00	0.60	846	3.09	1.85	0.60	878	2.56	1.54	0.60	912
	21	20	2.71	1.30	0.48	249	2.71	1.30	0.48	273	2.71	1.30	0.48	298	3.01	1.44	0.48	314	3.01	1.44	0.48	347	4.58	2.20	0.48	683	4.38	2.10	0.48	718	4.22	2.02	0.48	751	4.05	1.94	0.48	786	3.82	1.83	0.48	837	3.51	1.68	0.48	889	3.25	1.56	0.48	923	2.70	1.29	0.48	958
	22	18	2.58	1.65	0.64	209	2.58	1.65	0.64	233	2.58	1.65	0.64	258	2.87	1.83	0.64	274	2.87	1.83	0.64	307	4.36	2.79	0.64	650	4.17	2.67	0.64	684	4.01	2.56	0.64	715	3.86	2.47	0.64	748	3.64	2.33	0.64	797	3.34	2.14	0.64	846	3.09	1.98	0.64	878	2.56	1.64	0.64	912
	22	20	2.71	1.41	0.52	249	2.71	1.41	0.52	273	2.71	1.41	0.52	298	3.01	1.56	0.52	314	3.01	1.56	0.52	347	4.58	2.38	0.52	683	4.38	2.28	0.52	718	4.22	2.19	0.52	751	4.05	2.11	0.52	786	3.82	1.99	0.52	837	3.51	1.82	0.52	889	3.25	1.69	0.52	923	2.70	1.40	0.52	958
	22	22	2.87	1.15	0.40	288	2.87	1.15	0.40	312	2.87	1.15	0.40	337	3.19	1.27	0.40	353	3.19	1.27	0.40	386	4.86	1.94	0.40	715	4.65	1.86	0.40	752	4.47	1.78	0.40	786	4.30	1.72	0.40	822	4.05	1.62	0.40	876	3.72	1.49	0.40	930	3.44	1.37	0.40	966	2.86	1.14	0.40	1002
	23	18	2.58	1.75	0.68	209	2.58	1.75	0.68	233	2.58	1.75	0.68	258	2.87	1.95	0.68	274	2.87	1.95	0.68	307	4.36	2.96	0.68	650	4.17	2.83	0.68	684	4.01	2.73	0.68	715	3.86	2.62	0.68	748	3.64	2.47	0.68	797	3.34	2.27	0.68	846	3.09	2.10	0.68	878	2.56	1.74	0.68	912
	23	20	2.71	1.52	0.56	249	2.71	1.52	0.56	273	2.71	1.52	0.56	298	3.01	1.68	0.56	314	3.01	1.68	0.56	347	4.58	2.56	0.56	683	4.38	2.45	0.56	718	4.22	2.36	0.56	751	4.05	2.27	0.56	786	3.82	2.14	0.56	837	3.51	1.96	0.56	889	3.25	1.82	0.56	923	2.70	1.51	0.56	958
	23	22	2.87	1.26	0.44	288	2.87	1.26	0.44	312	2.87	1.26	0.44	337	3.19	1.40	0.44	353	3.19	1.40	0.44	386	4.86	2.13	0.44	715	4.65	2.04	0.44	752	4.47	1.96	0.44	786	4.30	1.89	0.44	822	4.05	1.78	0.44	876	3.72	1.63	0.44	930	3.44	1.51	0.44	966	2.86	1.26	0.44	1002
	24	18	2.58	1.86	0.72	209	2.58	1.86	0.72	233	2.58	1.86	0.72	258	2.87	2.06	0.72	274	2.87	2.06	0.72	307	4.36	3.14	0.72	650	4.17	3.00	0.72	684	4.01	2.89	0.72	715	3.86	2.77	0.72	748	3.64	2.62	0.72	797	3.34	2.40	0.72	846	3.09	2.22	0.72	878	2.56	1.84	0.72	912
	24	20	2.71	1.63	0.60	249	2.71	1.63	0.60	273	2.71	1.63	0.60	298	3.01	1.80	0.60	314	3.01	1.80	0.60	347	4.58	2.75	0.60	683	4.38	2.63	0.60	718	4.22	2.53	0.60	751	4.05	2.43	0.60	786	3.82	2.29	0.60	837	3.51	2.10	0.60	889	3.25	1.95	0.60	923	2.70	1.62	0.60	958
	24	22	2.87	1.38	0.48	288	2.87	1.38	0.48	312	2.87	1.38	0.48	337	3.19	1.53	0.48	353	3.19	1.53	0.48	386	4.86	2.33	0.48	715	4.65	2.23	0.48	752	4.47	2.14	0.48	786	4.30	2.06	0.48	822	4.05	1.94	0.48	876	3.72	1.78	0.48	930	3.44	1.65	0.48	966	2.86	1.37	0.48	1002
	24	24	3.05	1.09	0.36	328	3.05	1.09	0.36	352	3.05	1.09	0.36	377	3.38	1.22	0.36	393	3.38	1.22	0.36	426	5.15	1.85	0.36	747	4.93	1.77	0.36	786	4.74	1.70	0.36	822	4.56	1.64	0.36	860	4.30	1.54	0.36	916	3.94	1.42	0.36	973	3.65	1.31	0.36	1010	3.03	1.09	0.36	1048
	25	18	2.58	1.96	0.76	209	2.58	1.96	0.76	233	2.58	1.96	0.76	258	2.87	2.18	0.76	274	2.87	2.18	0.76	307	4.36	3.31	0.76	650	4.17	3.17	0.76	684	4.01	3.05	0.76	715	3.86	2.93	0.76	748	3.64	2.76	0.76	797	3.34	2.54	0.76	846	3.09	2.35	0.76	878	2.56	1.95	0.76	912
	25	20	2.71	1.73	0.64	249	2.71	1.73	0.64	273	2.71	1.73	0.64	298	3.01	1.93	0.64	314	3.01	1.93	0.64	347	4.58	2.93	0.64	683	4.38	2.80	0.64	718	4.22	2.70	0.64	751	4.05	2.59	0.64	786	3.82	2.45	0.64	837	3.51	2.24	0.64	889	3.25	2.08	0.64	923	2.70	1.72	0.64	958
	25	22	2.87	1.49	0.52	288	2.87	1.49	0.52	312	2.87	1.49	0.52	337	3.19	1.66	0.52	353	3.19	1.66	0.52	386	4.86	2.52	0.52	715	4.65	2.41	0.52	752	4.47	2.32	0.52	786	4.30	2.23	0.52	822	4.05	2.11	0.52	876	3.72	1.93	0.52	930	3.44	1.79	0.52	966	2.86	1.48	0.52	1002
	25	24	3.05	1.22	0.40	328	3.05	1.22	0.40	352	3.05	1.22	0.40	377	3.38	1.35	0.40	393	3.38	1.35	0.40	426	5.15	2.06	0.40	747	4.93	1.97	0.40	786	4.74	1.89	0.40	822	4.56	1.82	0.40	860	4.30	1.72	0.40	916	3.94	1.58	0.40	973	3.65	1.46	0.40	1010	3.03	1.21	0.40	1048
	26	18	2.58	2.06	0.80	209	2.58	2.06	0.80	233	2.58	2.06	0.80	258	2.87	2.29	0.80	274	2.87	2.29	0.80	307	4.36	3.48	0.80	650	4.17	3.33	0.80	684	4.01	3.21	0.80	715	3.86	3.08	0.80	748	3.64	2.91	0.80	797	3.34	2.67	0.80	846	3.09	2.47	0.80	878	2.56	2.05	0.80	912
	26	20	2.71	1.84	0.68	249	2.71	1.84	0.68	273	2.71	1.84	0.68	298	3.01	2.05	0.68	314	3.01	2.05	0.68	347	4.58	3.11	0.68	683	4.38	2.98	0.68	718	4.22	2.86	0.68	751	4.05	2.75	0.68	786	3.82	2.60	0.68	837	3.51	2.38	0.68	889	3.25	2.21	0.68	923	2.70	1.83	0.68	9

4. CAPACITIES AND SELECTION DATA

	Cooling Operation PERFORMANCE DATA																																																					
	OUTDOOR DB (°C)																																																					
COMBINATION (%)	IDDB (°C)	ID WB (°C)	-15				-7				0				10				15				21				25				27				30				35				40				45				50			
			Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT								
110%	21	18	2.50	1.56	0.62	202	2.50	1.56	0.62	226	2.50	1.56	0.62	250	2.78	1.73	0.62	266	2.78	1.73	0.62	297	4.23	2.64	0.62	631	4.05	2.53	0.62	663	3.89	2.43	0.62	694	3.74	2.33	0.62	726	3.53	2.20	0.62	773	3.24	2.02	0.62	821	3.00	1.87	0.62	852	2.49	1.55	0.62	885
	21	20	2.63	1.33	0.50	242	2.63	1.33	0.50	266	2.63	1.33	0.50	290	2.92	1.47	0.50	306	2.92	1.47	0.50	337	4.45	2.24	0.50	664	4.26	2.14	0.50	698	4.09	2.06	0.50	730	3.94	1.98	0.50	764	3.71	1.87	0.50	813	3.41	1.72	0.50	864	3.15	1.59	0.50	896	2.62	1.32	0.50	930
	22	18	2.50	1.66	0.66	202	2.50	1.66	0.66	226	2.50	1.66	0.66	250	2.78	1.85	0.66	266	2.78	1.85	0.66	297	4.23	2.81	0.66	631	4.05	2.69	0.66	663	3.89	2.58	0.66	694	3.74	2.48	0.66	726	3.53	2.34	0.66	773	3.24	2.15	0.66	821	3.00	1.99	0.66	852	2.49	1.65	0.66	885
	22	20	2.63	1.43	0.54	242	2.63	1.43	0.54	266	2.63	1.43	0.54	290	2.92	1.59	0.54	306	2.92	1.59	0.54	337	4.45	2.42	0.54	664	4.26	2.31	0.54	698	4.09	2.22	0.54	730	3.94	2.14	0.54	764	3.71	2.02	0.54	813	3.41	1.85	0.54	864	3.15	1.71	0.54	896	2.62	1.42	0.54	930
	22	22	2.79	1.18	0.42	281	2.79	1.18	0.42	305	2.79	1.18	0.42	329	3.10	1.31	0.42	345	3.10	1.31	0.42	376	4.72	2.00	0.42	695	4.51	1.91	0.42	731	4.34	1.84	0.42	765	4.17	1.77	0.42	800	3.94	1.67	0.42	852	3.61	1.53	0.42	905	3.34	1.42	0.42	939	2.77	1.17	0.42	975
	23	18	2.50	1.76	0.70	202	2.50	1.76	0.70	226	2.50	1.76	0.70	250	2.78	1.96	0.70	266	2.78	1.96	0.70	297	4.23	2.98	0.70	631	4.05	2.85	0.70	663	3.89	2.74	0.70	694	3.74	2.63	0.70	726	3.53	2.49	0.70	773	3.24	2.28	0.70	821	3.00	2.11	0.70	852	2.49	1.75	0.70	885
	23	20	2.63	1.54	0.58	242	2.63	1.54	0.58	266	2.63	1.54	0.58	290	2.92	1.71	0.58	306	2.92	1.71	0.58	337	4.45	2.60	0.58	664	4.26	2.48	0.58	698	4.09	2.39	0.58	730	3.94	2.30	0.58	764	3.71	2.17	0.58	813	3.41	1.99	0.58	864	3.15	1.84	0.58	896	2.62	1.53	0.58	930
	23	22	2.79	1.29	0.46	281	2.79	1.29	0.46	305	2.79	1.29	0.46	329	3.10	1.44	0.46	345	3.10	1.44	0.46	376	4.72	2.19	0.46	695	4.51	2.09	0.46	731	4.34	2.01	0.46	765	4.17	1.93	0.46	800	3.94	1.82	0.46	852	3.61	1.67	0.46	905	3.34	1.55	0.46	939	2.77	1.29	0.46	975
	24	18	2.50	1.86	0.74	202	2.50	1.86	0.74	226	2.50	1.86	0.74	250	2.78	2.07	0.74	266	2.78	2.07	0.74	297	4.23	3.15	0.74	631	4.05	3.01	0.74	663	3.89	2.90	0.74	694	3.74	2.78	0.74	726	3.53	2.63	0.74	773	3.24	2.41	0.74	821	3.00	2.23	0.74	852	2.49	1.85	0.74	885
	24	20	2.63	1.64	0.62	242	2.63	1.64	0.62	266	2.63	1.64	0.62	290	2.92	1.82	0.62	306	2.92	1.82	0.62	337	4.45	2.77	0.62	664	4.26	2.65	0.62	698	4.09	2.55	0.62	730	3.94	2.45	0.62	764	3.71	2.31	0.62	813	3.41	2.12	0.62	864	3.15	1.97	0.62	896	2.62	1.63	0.62	930
	24	22	2.79	1.40	0.50	281	2.79	1.40	0.50	305	2.79	1.40	0.50	329	3.10	1.56	0.50	345	3.10	1.56	0.50	376	4.72	2.37	0.50	695	4.51	2.27	0.50	731	4.34	2.18	0.50	765	4.17	2.10	0.50	800	3.94	1.98	0.50	852	3.61	1.82	0.50	905	3.34	1.68	0.50	939	2.77	1.40	0.50	975
	24	24	2.96	1.13	0.38	321	2.96	1.13	0.38	345	2.96	1.13	0.38	369	3.29	1.26	0.38	385	3.29	1.26	0.38	416	5.00	1.92	0.38	728	4.78	1.83	0.38	766	4.60	1.76	0.38	801	4.42	1.70	0.38	838	4.17	1.60	0.38	892	3.83	1.47	0.38	947	3.54	1.36	0.38	983	2.94	1.13	0.38	1021
	25	18	2.50	1.96	0.78	202	2.50	1.96	0.78	226	2.50	1.96	0.78	250	2.78	2.18	0.78	266	2.78	2.18	0.78	297	4.23	3.32	0.78	631	4.05	3.17	0.78	663	3.89	3.05	0.78	694	3.74	2.93	0.78	726	3.53	2.77	0.78	773	3.24	2.54	0.78	821	3.00	2.35	0.78	852	2.49	1.95	0.78	885
	25	20	2.63	1.75	0.66	242	2.63	1.75	0.66	266	2.63	1.75	0.66	290	2.92	1.94	0.66	306	2.92	1.94	0.66	337	4.45	2.95	0.66	664	4.26	2.82	0.66	698	4.09	2.72	0.66	730	3.94	2.61	0.66	764	3.71	2.46	0.66	813	3.41	2.26	0.66	864	3.15	2.09	0.66	896	2.62	1.74	0.66	930
	25	22	2.79	1.52	0.54	281	2.79	1.52	0.54	305	2.79	1.52	0.54	329	3.10	1.68	0.54	345	3.10	1.68	0.54	376	4.72	2.56	0.54	695	4.51	2.45	0.54	731	4.34	2.36	0.54	765	4.17	2.27	0.54	800	3.94	2.14	0.54	852	3.61	1.96	0.54	905	3.34	1.82	0.54	939	2.77	1.51	0.54	975
	25	24	2.96	1.25	0.42	321	2.96	1.25	0.42	345	2.96	1.25	0.42	369	3.29	1.39	0.42	385	3.29	1.39	0.42	416	5.00	2.12	0.42	728	4.78	2.03	0.42	766	4.60	1.95	0.42	801	4.42	1.87	0.42	838	4.17	1.77	0.42	892	3.83	1.62	0.42	947	3.54	1.50	0.42	983	2.94	1.24	0.42	1021
	26	18	2.50	2.06	0.82	202	2.50	2.06	0.82	226	2.50	2.06	0.82	250	2.78	2.29	0.82	266	2.78	2.29	0.82	297	4.23	3.49	0.82	631	4.05	3.34	0.82	663	3.89	3.21	0.82	694	3.74	3.08	0.82	726	3.53	2.91	0.82	773	3.24	2.67	0.82	821	3.00	2.47	0.82	852	2.49	2.05	0.82	885
	26	20	2.63	1.85	0.70	242	2.63	1.85	0.70	266	2.63	1.85	0.70	290	2.92	2.06	0.70	306	2.92	2.06	0.70	337	4.45	3.13	0.70	664	4.26	2.99	0.70	698	4.09	2.88	0.70	730	3.94	2.77	0.70	764	3.71	2.61	0.70	813	3.41	2.40	0.70	864	3.15	2.22	0.70	896	2.62	1.84	0.70	930
	26	22	2.79	1.																																																		

4. CAPACITIES AND SELECTION DATA

	Cooling Operation PERFORMANCE DATA																																																					
	OUTDOOR DB (°C)																																																					
COMBINATION (%)	IDDB (°C)	ID WB (°C)	-15				-7				0				10				15				21				25				27				30				35				40				45				50			
			Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT								
100%	21	18	2.43	1.46	0.60	196	2.43	1.46	0.60	219	2.43	1.46	0.60	242	2.70	1.62	0.60	257	2.70	1.62	0.60	288	4.11	2.47	0.60	612	3.93	2.36	0.60	644	3.78	2.27	0.60	673	3.64	2.18	0.60	704	3.43	2.06	0.60	750	3.15	1.89	0.60	797	2.91	1.75	0.60	827	2.42	1.45	0.60	858
	21	20	2.56	1.23	0.48	236	2.56	1.23	0.48	259	2.56	1.23	0.48	282	2.84	1.36	0.48	297	2.84	1.36	0.48	328	4.32	2.07	0.48	645	4.13	1.98	0.48	678	3.97	1.91	0.48	709	3.82	1.83	0.48	742	3.61	1.73	0.48	790	3.31	1.59	0.48	839	3.06	1.47	0.48	871	2.54	1.22	0.48	904
	22	18	2.43	1.56	0.64	196	2.43	1.56	0.64	219	2.43	1.56	0.64	242	2.70	1.73	0.64	257	2.70	1.73	0.64	288	4.11	2.63	0.64	612	3.93	2.52	0.64	644	3.78	2.42	0.64	673	3.64	2.33	0.64	704	3.43	2.20	0.64	750	3.15	2.02	0.64	797	2.91	1.86	0.64	827	2.42	1.55	0.64	858
	22	20	2.56	1.33	0.52	236	2.56	1.33	0.52	259	2.56	1.33	0.52	282	2.84	1.48	0.52	297	2.84	1.48	0.52	328	4.32	2.25	0.52	645	4.13	2.15	0.52	678	3.97	2.07	0.52	709	3.82	1.99	0.52	742	3.61	1.87	0.52	790	3.31	1.72	0.52	839	3.06	1.59	0.52	871	2.54	1.32	0.52	904
	22	22	2.71	1.08	0.40	275	2.71	1.08	0.40	298	2.71	1.08	0.40	321	3.01	1.20	0.40	336	3.01	1.20	0.40	367	4.58	1.83	0.40	677	4.38	1.75	0.40	711	4.21	1.69	0.40	744	4.05	1.62	0.40	778	3.82	1.53	0.40	829	3.51	1.40	0.40	880	3.24	1.30	0.40	914	2.69	1.08	0.40	949
	23	18	2.43	1.65	0.68	196	2.43	1.65	0.68	219	2.43	1.65	0.68	242	2.70	1.84	0.68	257	2.70	1.84	0.68	288	4.11	2.79	0.68	612	3.93	2.67	0.68	644	3.78	2.57	0.68	673	3.64	2.47	0.68	704	3.43	2.33	0.68	750	3.15	2.14	0.68	797	2.91	1.98	0.68	827	2.42	1.64	0.68	858
	23	20	2.56	1.43	0.56	236	2.56	1.43	0.56	259	2.56	1.43	0.56	282	2.84	1.59	0.56	297	2.84	1.59	0.56	328	4.32	2.42	0.56	645	4.13	2.31	0.56	678	3.97	2.23	0.56	709	3.82	2.14	0.56	742	3.61	2.02	0.56	790	3.31	1.85	0.56	839	3.06	1.71	0.56	871	2.54	1.42	0.56	904
	23	22	2.71	1.19	0.44	275	2.71	1.19	0.44	298	2.71	1.19	0.44	321	3.01	1.32	0.44	336	3.01	1.32	0.44	367	4.58	2.01	0.44	677	4.38	1.93	0.44	711	4.21	1.85	0.44	744	4.05	1.78	0.44	778	3.82	1.68	0.44	829	3.51	1.54	0.44	880	3.24	1.43	0.44	914	2.69	1.19	0.44	949
	24	18	2.43	1.75	0.72	196	2.43	1.75	0.72	219	2.43	1.75	0.72	242	2.70	1.94	0.72	257	2.70	1.94	0.72	288	4.11	2.96	0.72	612	3.93	2.83	0.72	644	3.78	2.72	0.72	673	3.64	2.62	0.72	704	3.43	2.47	0.72	750	3.15	2.27	0.72	797	2.91	2.10	0.72	827	2.42	1.74	0.72	858
	24	20	2.56	1.53	0.60	236	2.56	1.53	0.60	259	2.56	1.53	0.60	282	2.84	1.70	0.60	297	2.84	1.70	0.60	328	4.32	2.59	0.60	645	4.13	2.48	0.60	678	3.97	2.38	0.60	709	3.82	2.29	0.60	742	3.61	2.16	0.60	790	3.31	1.99	0.60	839	3.06	1.84	0.60	871	2.54	1.52	0.60	904
	24	22	2.71	1.30	0.48	275	2.71	1.30	0.48	298	2.71	1.30	0.48	321	3.01	1.44	0.48	336	3.01	1.44	0.48	367	4.58	2.20	0.48	677	4.38	2.10	0.48	711	4.21	2.02	0.48	744	4.05	1.94	0.48	778	3.82	1.83	0.48	829	3.51	1.68	0.48	880	3.24	1.56	0.48	914	2.69	1.29	0.48	949
	24	24	2.87	1.03	0.36	315	2.87	1.03	0.36	338	2.87	1.03	0.36	361	3.19	1.15	0.36	376	3.19	1.15	0.36	407	4.85	1.75	0.36	709	4.64	1.67	0.36	746	4.47	1.61	0.36	780	4.29	1.55	0.36	816	4.05	1.46	0.36	869	3.72	1.34	0.36	923	3.44	1.24	0.36	958	2.85	1.03	0.36	994
	25	18	2.43	1.85	0.76	196	2.43	1.85	0.76	219	2.43	1.85	0.76	242	2.70	2.05	0.76	257	2.70	2.05	0.76	288	4.11	3.12	0.76	612	3.93	2.99	0.76	644	3.78	2.87	0.76	673	3.64	2.76	0.76	704	3.43	2.61	0.76	750	3.15	2.39	0.76	797	2.91	2.21	0.76	827	2.42	1.84	0.76	858
	25	20	2.56	1.64	0.64	236	2.56	1.64	0.64	259	2.56	1.64	0.64	282	2.84	1.82	0.64	297	2.84	1.82	0.64	328	4.32	2.76	0.64	645	4.13	2.65	0.64	678	3.97	2.54	0.64	709	3.82	2.45	0.64	742	3.61	2.31	0.64	790	3.31	2.12	0.64	839	3.06	1.96	0.64	871	2.54	1.63	0.64	904
	25	22	2.71	1.41	0.52	275	2.71	1.41	0.52	298	2.71	1.41	0.52	321	3.01	1.56	0.52	336	3.01	1.56	0.52	367	4.58	2.38	0.52	677	4.38	2.28	0.52	711	4.21	2.19	0.52	744	4.05	2.11	0.52	778	3.82	1.99	0.52	829	3.51	1.82	0.52	880	3.24	1.69	0.52	914	2.69	1.40	0.52	949
	25	24	2.87	1.15	0.40	315	2.87	1.15	0.40	338	2.87	1.15	0.40	361	3.19	1.28	0.40	376	3.19	1.28	0.40	407	4.85	1.94	0.40	709	4.64	1.86	0.40	746	4.47	1.79	0.40	780	4.29	1.72	0.40	816	4.05	1.62	0.40	869	3.72	1.49	0.40	923	3.44	1.38	0.40	958	2.85	1.14	0.40	994
	26	18	2.43	1.95	0.80	196	2.43	1.95	0.80	219	2.43	1.95	0.80	242	2.70	2.16	0.80	257	2.70	2.16	0.80	288	4.11	3.29	0.80	612	3.93	3.15	0.80	644	3.78	3.02	0.80	673	3.64	2.91	0.80	704	3.43	2.74	0.80	750	3.15	2.52	0.80	797	2.91	2.33	0.80	827	2.42	1.93	0.80	858
	26	20	2.56	1.74	0.68	236	2.56	1.74	0.68	259	2.56	1.74	0.68	282	2.84	1.93	0.68	297	2.84	1.93	0.68	328	4.32	2.94	0.68	645	4.13	2.81	0.68	678	3.97	2.70	0.68	709	3.82	2.60	0.68	742	3.61	2.45	0.68	790	3.31	2.25	0.68	839	3.06	2.08	0.68	871	2.54	1.73	0.68	904
	26	22	2.71	1.																																																		

4. CAPACITIES AND SELECTION DATA

	Cooling Operation PERFORMANCE DATA																																																					
	OUTDOOR DB (°C)																																																					
COMBINATION (%)	IDDB (°C)	ID WB (°C)	-15				-7				0				10				15				21				25				27				30				35				40				45				50			
			Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT								
90%	21	18	2.29	1.28	0.56	183	2.29	1.28	0.56	204	2.29	1.28	0.56	226	2.54	1.42	0.56	241	2.54	1.42	0.56	270	3.86	2.17	0.56	574	3.70	2.07	0.56	604	3.55	1.99	0.56	632	3.42	1.92	0.56	661	3.22	1.81	0.56	704	2.96	1.66	0.56	747	2.74	1.54	0.56	776	2.27	1.27	0.56	805
	21	20	2.40	1.06	0.44	223	2.40	1.06	0.44	244	2.40	1.06	0.44	266	2.67	1.18	0.44	281	2.67	1.18	0.44	310	4.06	1.79	0.44	607	3.89	1.71	0.44	638	3.74	1.65	0.44	668	3.59	1.58	0.44	698	3.39	1.49	0.44	744	3.11	1.37	0.44	790	2.88	1.27	0.44	820	2.39	1.05	0.44	851
	22	18	2.29	1.37	0.60	183	2.29	1.37	0.60	204	2.29	1.37	0.60	226	2.54	1.53	0.60	241	2.54	1.53	0.60	270	3.86	2.32	0.60	574	3.70	2.22	0.60	604	3.55	2.14	0.60	632	3.42	2.05	0.60	661	3.22	1.94	0.60	704	2.96	1.78	0.60	747	2.74	1.65	0.60	776	2.27	1.37	0.60	805
	22	20	2.40	1.16	0.48	223	2.40	1.16	0.48	244	2.40	1.16	0.48	266	2.67	1.28	0.48	281	2.67	1.28	0.48	310	4.06	1.95	0.48	607	3.89	1.87	0.48	638	3.74	1.80	0.48	668	3.59	1.73	0.48	698	3.39	1.63	0.48	744	3.11	1.50	0.48	790	2.88	1.38	0.48	820	2.39	1.15	0.48	851
	22	22	2.55	0.92	0.36	262	2.55	0.92	0.36	283	2.55	0.92	0.36	305	2.83	1.02	0.36	320	2.83	1.02	0.36	349	4.30	1.55	0.36	639	4.12	1.49	0.36	672	3.96	1.43	0.36	703	3.81	1.37	0.36	735	3.59	1.30	0.36	783	3.30	1.19	0.36	831	3.05	1.10	0.36	863	2.53	0.91	0.36	896
	23	18	2.29	1.47	0.64	183	2.29	1.47	0.64	204	2.29	1.47	0.64	226	2.54	1.63	0.64	241	2.54	1.63	0.64	270	3.86	2.48	0.64	574	3.70	2.37	0.64	604	3.55	2.28	0.64	632	3.42	2.19	0.64	661	3.22	2.07	0.64	704	2.96	1.90	0.64	747	2.74	1.75	0.64	776	2.27	1.46	0.64	805
	23	20	2.40	1.25	0.52	223	2.40	1.25	0.52	244	2.40	1.25	0.52	266	2.67	1.39	0.52	281	2.67	1.39	0.52	310	4.06	2.12	0.52	607	3.89	2.02	0.52	638	3.74	1.95	0.52	668	3.59	1.87	0.52	698	3.39	1.77	0.52	744	3.11	1.62	0.52	790	2.88	1.50	0.52	820	2.39	1.24	0.52	851
	23	22	2.55	1.02	0.40	262	2.55	1.02	0.40	283	2.55	1.02	0.40	305	2.83	1.13	0.40	320	2.83	1.13	0.40	349	4.30	1.73	0.40	639	4.12	1.65	0.40	672	3.96	1.59	0.40	703	3.81	1.53	0.40	735	3.59	1.44	0.40	783	3.30	1.32	0.40	831	3.05	1.22	0.40	863	2.53	1.02	0.40	896
	24	18	2.29	1.56	0.68	183	2.29	1.56	0.68	204	2.29	1.56	0.68	226	2.54	1.73	0.68	241	2.54	1.73	0.68	270	3.86	2.63	0.68	574	3.70	2.52	0.68	604	3.55	2.42	0.68	632	3.42	2.33	0.68	661	3.22	2.20	0.68	704	2.96	2.02	0.68	747	2.74	1.86	0.68	776	2.27	1.55	0.68	805
	24	20	2.40	1.35	0.56	223	2.40	1.35	0.56	244	2.40	1.35	0.56	266	2.67	1.50	0.56	281	2.67	1.50	0.56	310	4.06	2.28	0.56	607	3.89	2.18	0.56	638	3.74	2.10	0.56	668	3.59	2.02	0.56	698	3.39	1.90	0.56	744	3.11	1.75	0.56	790	2.88	1.61	0.56	820	2.39	1.34	0.56	851
	24	22	2.55	1.12	0.44	262	2.55	1.12	0.44	283	2.55	1.12	0.44	305	2.83	1.25	0.44	320	2.83	1.25	0.44	349	4.30	1.90	0.44	639	4.12	1.82	0.44	672	3.96	1.75	0.44	703	3.81	1.68	0.44	735	3.59	1.58	0.44	783	3.30	1.45	0.44	831	3.05	1.35	0.44	863	2.53	1.12	0.44	896
	24	24	2.70	0.87	0.32	302	2.70	0.87	0.32	323	2.70	0.87	0.32	345	3.00	0.96	0.32	360	3.00	0.96	0.32	389	4.56	1.46	0.32	672	4.37	1.40	0.32	706	4.20	1.35	0.32	739	4.04	1.30	0.32	773	3.81	1.22	0.32	823	3.50	1.12	0.32	874	3.23	1.04	0.32	907	2.68	0.86	0.32	941
	25	18	2.29	1.65	0.72	183	2.29	1.65	0.72	204	2.29	1.65	0.72	226	2.54	1.83	0.72	241	2.54	1.83	0.72	270	3.86	2.79	0.72	574	3.70	2.67	0.72	604	3.55	2.56	0.72	632	3.42	2.46	0.72	661	3.22	2.32	0.72	704	2.96	2.13	0.72	747	2.74	1.97	0.72	776	2.27	1.64	0.72	805
	25	20	2.40	1.44	0.60	223	2.40	1.44	0.60	244	2.40	1.44	0.60	266	2.67	1.60	0.60	281	2.67	1.60	0.60	310	4.06	2.44	0.60	607	3.89	2.33	0.60	638	3.74	2.25	0.60	668	3.59	2.16	0.60	698	3.39	2.04	0.60	744	3.11	1.87	0.60	790	2.88	1.73	0.60	820	2.39	1.44	0.60	851
	25	22	2.55	1.22	0.48	262	2.55	1.22	0.48	283	2.55	1.22	0.48	305	2.83	1.36	0.48	320	2.83	1.36	0.48	349	4.30	2.07	0.48	639	4.12	1.98	0.48	672	3.96	1.90	0.48	703	3.81	1.83	0.48	735	3.59	1.73	0.48	783	3.30	1.59	0.48	831	3.05	1.47	0.48	863	2.53	1.22	0.48	896
	25	24	2.70	0.97	0.36	302	2.70	0.97	0.36	323	2.70	0.97	0.36	345	3.00	1.08	0.36	360	3.00	1.08	0.36	389	4.56	1.65	0.36	672	4.37	1.58	0.36	706	4.20	1.52	0.36	739	4.04	1.46	0.36	773	3.81	1.37	0.36	823	3.50	1.26	0.36	874	3.23	1.17	0.36	907	2.68	0.97	0.36	941
	26	18	2.29	1.74	0.76	183	2.29	1.74	0.76	204	2.29	1.74	0.76	226	2.54	1.93	0.76	241	2.54	1.93	0.76	270	3.86	2.94	0.76	574	3.70	2.81	0.76	604	3.55	2.70	0.76	632	3.42	2.60	0.76	661	3.22	2.45	0.76	704	2.96	2.25	0.76	747	2.74	2.08	0.76	776	2.27	1.73	0.76	805
	26	20	2.40	1.54	0.64	223	2.40	1.54	0.64	244	2.40	1.54	0.64	266	2.67	1.71	0.64	281	2.67	1.71	0.64	310	4.06	2.60	0.64	607	3.89	2.49	0.64	638	3.74	2.39	0.64	668	3.59	2.30	0.64	698	3.39	2.17	0.64	744	3.11	1.99	0.64	790	2.88	1.84	0.64	820	2.39	1.53	0.64	851
	26	22	2.55																																																			

4. CAPACITIES AND SELECTION DATA

	Cooling Operation PERFORMANCE DATA																																																					
	OUTDOOR DB (°C)																																																					
COMBINATION (%)	IDDB (°C)	ID WB (°C)	-15				-7				0				10				15				21				25				27				30				35				40				45				50			
			Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT								
80%	21	18	2.19	1.18	0.54	162	2.19	1.18	0.54	182	2.19	1.18	0.54	201	2.44	1.31	0.54	215	2.44	1.31	0.54	241	3.71	2.00	0.54	515	3.55	1.91	0.54	542	3.41	1.84	0.54	567	3.28	1.77	0.54	593	3.10	1.67	0.54	631	2.84	1.53	0.54	671	2.63	1.42	0.54	696	2.18	1.18	0.54	722
	21	20	2.31	0.97	0.42	202	2.31	0.97	0.42	222	2.31	0.97	0.42	241	2.56	1.07	0.42	255	2.56	1.07	0.42	281	3.90	1.63	0.42	548	3.73	1.56	0.42	576	3.59	1.50	0.42	603	3.45	1.44	0.42	630	3.25	1.36	0.42	671	2.99	1.25	0.42	713	2.76	1.16	0.42	740	2.29	0.96	0.42	768
	22	18	2.19	1.27	0.58	162	2.19	1.27	0.58	182	2.19	1.27	0.58	201	2.44	1.41	0.58	215	2.44	1.41	0.58	241	3.71	2.15	0.58	515	3.55	2.05	0.58	542	3.41	1.97	0.58	567	3.28	1.90	0.58	593	3.10	1.79	0.58	631	2.84	1.64	0.58	671	2.63	1.52	0.58	696	2.18	1.26	0.58	722
	22	20	2.31	1.06	0.46	202	2.31	1.06	0.46	222	2.31	1.06	0.46	241	2.56	1.18	0.46	255	2.56	1.18	0.46	281	3.90	1.79	0.46	548	3.73	1.71	0.46	576	3.59	1.65	0.46	603	3.45	1.58	0.46	630	3.25	1.49	0.46	671	2.99	1.37	0.46	713	2.76	1.27	0.46	740	2.29	1.05	0.46	768
	22	22	2.44	0.83	0.34	241	2.44	0.83	0.34	261	2.44	0.83	0.34	280	2.72	0.92	0.34	294	2.72	0.92	0.34	320	4.13	1.40	0.34	580	3.95	1.34	0.34	610	3.80	1.29	0.34	638	3.66	1.24	0.34	667	3.45	1.17	0.34	710	3.17	1.07	0.34	754	2.93	0.99	0.34	783	2.43	0.82	0.34	813
	23	18	2.19	1.36	0.62	162	2.19	1.36	0.62	182	2.19	1.36	0.62	201	2.44	1.51	0.62	215	2.44	1.51	0.62	241	3.71	2.29	0.62	515	3.55	2.20	0.62	542	3.41	2.11	0.62	567	3.28	2.03	0.62	593	3.10	1.92	0.62	631	2.84	1.76	0.62	671	2.63	1.63	0.62	696	2.18	1.35	0.62	722
	23	20	2.31	1.15	0.50	202	2.31	1.15	0.50	222	2.31	1.15	0.50	241	2.56	1.28	0.50	255	2.56	1.28	0.50	281	3.90	1.94	0.50	548	3.73	1.86	0.50	576	3.59	1.79	0.50	603	3.45	1.72	0.50	630	3.25	1.62	0.50	671	2.99	1.49	0.50	713	2.76	1.38	0.50	740	2.29	1.14	0.50	768
	23	22	2.44	0.93	0.38	241	2.44	0.93	0.38	261	2.44	0.93	0.38	280	2.72	1.03	0.38	294	2.72	1.03	0.38	320	4.13	1.56	0.38	580	3.95	1.50	0.38	610	3.80	1.44	0.38	638	3.66	1.38	0.38	667	3.45	1.31	0.38	710	3.17	1.20	0.38	754	2.93	1.11	0.38	783	2.43	0.92	0.38	813
	24	18	2.19	1.45	0.66	162	2.19	1.45	0.66	182	2.19	1.45	0.66	201	2.44	1.61	0.66	215	2.44	1.61	0.66	241	3.71	2.44	0.66	515	3.55	2.34	0.66	542	3.41	2.25	0.66	567	3.28	2.16	0.66	593	3.10	2.04	0.66	631	2.84	1.87	0.66	671	2.63	1.73	0.66	696	2.18	1.44	0.66	722
	24	20	2.31	1.24	0.54	202	2.31	1.24	0.54	222	2.31	1.24	0.54	241	2.56	1.38	0.54	255	2.56	1.38	0.54	281	3.90	2.10	0.54	548	3.73	2.01	0.54	576	3.59	1.93	0.54	603	3.45	1.86	0.54	630	3.25	1.75	0.54	671	2.99	1.61	0.54	713	2.76	1.49	0.54	740	2.29	1.24	0.54	768
	24	22	2.44	1.02	0.42	241	2.44	1.02	0.42	261	2.44	1.02	0.42	280	2.72	1.14	0.42	294	2.72	1.14	0.42	320	4.13	1.73	0.42	580	3.95	1.66	0.42	610	3.80	1.59	0.42	638	3.66	1.53	0.42	667	3.45	1.44	0.42	710	3.17	1.33	0.42	754	2.93	1.23	0.42	783	2.43	1.02	0.42	813
	24	24	2.59	0.77	0.30	281	2.59	0.77	0.30	301	2.59	0.77	0.30	320	2.88	0.86	0.30	334	2.88	0.86	0.30	360	4.38	1.31	0.30	612	4.19	1.25	0.30	644	4.03	1.20	0.30	674	3.87	1.16	0.30	705	3.66	1.09	0.30	750	3.36	1.00	0.30	797	3.10	0.93	0.30	827	2.58	0.77	0.30	859
	25	18	2.19	1.53	0.70	162	2.19	1.53	0.70	182	2.19	1.53	0.70	201	2.44	1.70	0.70	215	2.44	1.70	0.70	241	3.71	2.59	0.70	515	3.55	2.48	0.70	542	3.41	2.38	0.70	567	3.28	2.29	0.70	593	3.10	2.16	0.70	631	2.84	1.99	0.70	671	2.63	1.84	0.70	696	2.18	1.52	0.70	722
	25	20	2.31	1.33	0.58	202	2.31	1.33	0.58	222	2.31	1.33	0.58	241	2.56	1.48	0.58	255	2.56	1.48	0.58	281	3.90	2.26	0.58	548	3.73	2.16	0.58	576	3.59	2.08	0.58	603	3.45	2.00	0.58	630	3.25	1.88	0.58	671	2.99	1.73	0.58	713	2.76	1.60	0.58	740	2.29	1.33	0.58	768
	25	22	2.44	1.12	0.46	241	2.44	1.12	0.46	261	2.44	1.12	0.46	280	2.72	1.25	0.46	294	2.72	1.25	0.46	320	4.13	1.90	0.46	580	3.95	1.81	0.46	610	3.80	1.74	0.46	638	3.66	1.68	0.46	667	3.45	1.58	0.46	710	3.17	1.45	0.46	754	2.93	1.34	0.46	783	2.43	1.11	0.46	813
	25	24	2.59	0.88	0.34	281	2.59	0.88	0.34	301	2.59	0.88	0.34	320	2.88	0.98	0.34	334	2.88	0.98	0.34	360	4.38	1.48	0.34	612	4.19	1.42	0.34	644	4.03	1.37	0.34	674	3.87	1.31	0.34	705	3.66	1.24	0.34	750	3.36	1.14	0.34	797	3.10	1.05	0.34	827	2.58	0.87	0.34	859
	26	18	2.19	1.62	0.74	162	2.19	1.62	0.74	182	2.19	1.62	0.74	201	2.44	1.80	0.74	215	2.44	1.80	0.74	241	3.71	2.74	0.74	515	3.55	2.62	0.74	542	3.41	2.52	0.74	567	3.28	2.42	0.74	593	3.10	2.29	0.74	631	2.84	2.10	0.74	671	2.63	1.94	0.74	696	2.18	1.61	0.74	722
	26	20	2.31	1.43	0.62	202	2.31	1.43	0.62	222	2.31	1.43	0.62	241	2.56	1.59	0.62	255	2.56	1.59	0.62	281	3.90	2.41	0.62	548	3.73	2.31	0.62	576	3.59	2.22	0.62	603	3.45	2.13	0.62	630	3.25	2.01	0.62	671	2.99	1.85	0.62	713	2.76	1.71	0.62	740	2.29	1.42	0.62	768
	26	22	2.44	1.22																																																		

4. CAPACITIES AND SELECTION DATA

12K

HEATING PERFORMANCE DATA

COMBINATION (%)	INDOOR DB(°C)	OUTDOOR WB(°C)															
		-15		-10		-5		0		5		10		15		20	
		Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT
130%	15	5.06	1479	5.95	1524	6.61	1540	7.27	1571	7.90	1654	8.53	1737	8.96	1789	9.23	1824
	16	5.00	1491	5.88	1537	6.54	1552	7.18	1584	7.81	1667	8.43	1751	8.85	1803	9.12	1839
	17	4.94	1503	5.81	1549	6.46	1565	7.10	1597	7.71	1681	8.33	1765	8.75	1818	9.01	1854
	18	4.88	1515	5.74	1562	6.38	1577	7.01	1609	7.62	1694	8.23	1779	8.64	1832	8.90	1869
	19	4.82	1527	5.68	1574	6.31	1590	6.93	1622	7.53	1708	8.14	1793	8.54	1847	8.80	1884
	20	4.78	1539	5.62	1587	6.24	1603	6.86	1636	7.46	1722	8.05	1808	8.46	1862	8.71	1899
	21	4.72	1556	5.55	1604	6.17	1620	6.78	1654	7.37	1741	7.96	1828	8.36	1882	8.61	1920
	22	4.66	1573	5.49	1622	6.09	1638	6.70	1672	7.28	1760	7.86	1848	8.26	1903	8.50	1941
	23	4.61	1591	5.42	1640	6.02	1656	6.62	1690	7.19	1779	7.77	1868	8.16	1924	8.40	1963
	24	4.55	1608	5.35	1658	5.95	1675	6.54	1709	7.11	1799	7.67	1889	8.06	1945	8.30	1984
	25	4.50	1626	5.29	1676	5.88	1693	6.46	1727	7.02	1818	7.58	1909	7.96	1967	8.20	2006
	26	4.44	1644	5.23	1694	5.81	1712	6.38	1746	6.94	1838	7.49	1930	7.87	1988	8.10	2028
	27	4.39	1662	5.16	1713	5.74	1730	6.31	1766	6.85	1859	7.40	1952	7.77	2010	8.01	2050
	28	4.34	1680	5.10	1732	5.67	1749	6.23	1785	6.77	1879	7.31	1973	7.68	2032	7.91	2073
	29	4.28	1698	5.04	1751	5.60	1769	6.15	1805	6.69	1900	7.23	1995	7.59	2055	7.81	2096
	30	4.23	1717	4.98	1770	5.53	1788	6.08	1825	6.61	1921	7.14	2017	7.50	2077	7.72	2119
COMBINATION (%)	INDOOR DB(°C)	OUTDOOR WB(°C)															
		-15		-10		-5		0		5		10		15		20	
		Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT
120%	15	4.91	1408	5.78	1452	6.42	1466	7.06	1496	7.67	1575	8.28	1654	8.70	1703	8.96	1738
	16	4.85	1420	5.71	1463	6.35	1478	6.97	1508	7.58	1588	8.19	1667	8.60	1717	8.85	1752
	17	4.80	1431	5.64	1475	6.27	1490	6.89	1521	7.49	1601	8.09	1681	8.49	1731	8.75	1766
	18	4.74	1443	5.58	1487	6.20	1502	6.81	1533	7.40	1614	7.99	1694	8.39	1745	8.64	1780
	19	4.68	1454	5.51	1499	6.12	1514	6.73	1545	7.31	1627	7.90	1708	8.29	1759	8.54	1794
	20	4.64	1466	5.46	1511	6.06	1526	6.66	1558	7.24	1640	7.82	1722	8.21	1773	8.46	1809
	21	4.58	1482	5.39	1528	5.99	1543	6.58	1575	7.15	1658	7.73	1741	8.11	1793	8.36	1829
	22	4.53	1498	5.33	1545	5.92	1560	6.50	1592	7.07	1676	7.63	1760	8.02	1812	8.26	1849
	23	4.47	1515	5.26	1562	5.85	1577	6.42	1610	6.98	1694	7.54	1779	7.92	1832	8.16	1869
	24	4.42	1531	5.20	1579	5.78	1595	6.35	1627	6.90	1713	7.45	1799	7.82	1853	8.06	1890
	25	4.37	1548	5.14	1596	5.71	1612	6.27	1645	6.82	1732	7.36	1818	7.73	1873	7.96	1910
	26	4.31	1565	5.07	1614	5.64	1630	6.20	1663	6.73	1751	7.27	1838	7.64	1894	7.87	1931
	27	4.26	1583	5.01	1632	5.57	1648	6.12	1682	6.65	1770	7.19	1859	7.55	1914	7.77	1953
	28	4.21	1600	4.95	1649	5.50	1666	6.05	1700	6.57	1790	7.10	1879	7.45	1935	7.68	1974
	29	4.16	1618	4.89	1668	5.44	1684	5.98	1719	6.50	1809	7.01	1900	7.37	1957	7.59	1996
	30	4.11	1635	4.84	1686	5.37	1703	5.90	1738	6.42	1829	6.93	1921	7.28	1978	7.50	2018
COMBINATION (%)	INDOOR DB(°C)	OUTDOOR WB(°C)															
		-15		-10		-5		0		5		10		15		20	
		Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT
110%	15	4.77	1381	5.61	1423	6.23	1438	6.85	1467	7.45	1544	8.04	1621	8.44	1670	8.70	1703
	16	4.71	1392	5.54	1435	6.16	1449	6.77	1479	7.36	1557	7.95	1634	8.34	1684	8.60	1717
	17	4.66	1403	5.48	1446	6.09	1461	6.69	1491	7.27	1569	7.85	1648	8.25	1697	8.49	1731
	18	4.60	1414	5.41	1458	6.02	1473	6.61	1503	7.19	1582	7.76	1661	8.15	1711	8.39	1745
	19	4.55	1426	5.35	1470	5.94	1485	6.53	1515	7.10	1595	7.67	1674	8.05	1725	8.29	1759
	20	4.50	1437	5.30	1482	5.89	1497	6.47	1527	7.03	1607	7.59	1688	7.97	1738	8.21	1773
	21	4.45	1453	5.23	1498	5.81	1513	6.39	1544	6.95	1625	7.50	1706	7.88	1758	8.11	1793
	22	4.39	1469	5.17	1514	5.74	1530	6.31	1561	6.86	1643	7.41	1725	7.78	1777	8.02	1812
	23	4.34	1485	5.11	1531	5.68	1546	6.24	1578	6.78	1661	7.32	1744	7.69	1796	7.92	1832
	24	4.29	1501	5.05	1548	5.61	1564	6.16	1595	6.70	1679	7.23	1763	7.60	1816	7.82	1853
	25	4.24	1518	4.99	1565	5.54	1581	6.09	1613	6.62	1698	7.15	1783	7.50	1836	7.73	1873
	26	4.19	1535	4.93	1582	5.47	1598	6.02	1631	6.54	1717	7.06	1802	7.41	1856	7.64	1894
	27	4.14	1552	4.87	1600	5.41	1616	5.94	1649	6.46	1735	6.98	1822	7.33	1877	7.55	1914
	28	4.09	1569	4.81	1617	5.34	1633	5.87	1667	6.38	1755	6.89	1842	7.24	1897	7.45	1935
	29	4.04	1586	4.75	1635	5.28	1651	5.80	1685	6.31	1774	6.81	1862	7.15	1918	7.37	1957
	30	3.99	1603	4.69	1653	5.22	1670	5.73	1704	6.23	1793	6.73	1883	7.07	1939	7.28	1978

4. CAPACITIES AND SELECTION DATA

COMBINATION (%)	INDOOR DB(°C)	OUTDOOR WB(°C)															
		-15		-10		-5		0		5		10		15		20	
		Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT
100%	15	4.63	1340	5.45	1382	6.05	1396	6.65	1424	7.23	1499	7.81	1574	8.20	1621	8.44	1654
	16	4.58	1351	5.38	1393	5.98	1407	6.57	1436	7.14	1511	7.72	1587	8.10	1634	8.34	1667
	17	4.52	1362	5.32	1404	5.91	1418	6.49	1447	7.06	1524	7.62	1600	8.01	1648	8.25	1681
	18	4.47	1373	5.26	1416	5.84	1430	6.42	1459	6.98	1536	7.53	1613	7.91	1661	8.15	1694
	19	4.41	1384	5.19	1427	5.77	1441	6.34	1471	6.89	1548	7.44	1626	7.82	1674	8.05	1708
	20	4.37	1395	5.14	1438	5.71	1453	6.28	1483	6.83	1561	7.37	1639	7.74	1688	7.97	1722
	21	4.32	1411	5.08	1454	5.65	1469	6.20	1499	6.74	1578	7.28	1657	7.65	1706	7.88	1741
	22	4.27	1426	5.02	1470	5.58	1485	6.13	1515	6.66	1595	7.20	1675	7.55	1725	7.78	1760
	23	4.22	1442	4.96	1486	5.51	1501	6.06	1532	6.58	1613	7.11	1693	7.46	1744	7.69	1779
	24	4.17	1458	4.90	1503	5.44	1518	5.98	1549	6.50	1630	7.02	1712	7.37	1763	7.60	1799
	25	4.12	1474	4.84	1519	5.38	1535	5.91	1566	6.43	1648	6.94	1731	7.29	1783	7.50	1818
	26	4.07	1490	4.78	1536	5.31	1552	5.84	1583	6.35	1667	6.86	1750	7.20	1802	7.41	1838
	27	4.02	1506	4.73	1553	5.25	1569	5.77	1601	6.27	1685	6.77	1769	7.11	1822	7.33	1859
	28	3.97	1523	4.67	1570	5.19	1586	5.70	1618	6.20	1703	6.69	1789	7.03	1842	7.24	1879
	29	3.92	1540	4.61	1587	5.13	1603	5.63	1636	6.12	1722	6.61	1808	6.94	1862	7.15	1900
	30	3.87	1557	4.56	1605	5.06	1621	5.56	1654	6.05	1741	6.53	1828	6.86	1883	7.07	1921
COMBINATION (%)	INDOOR DB(°C)	OUTDOOR WB(°C)															
		-15		-10		-5		0		5		10		15		20	
		Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT
90%	15	4.47	1316	5.26	1357	5.84	1371	6.42	1399	6.98	1472	7.54	1546	7.91	1592	8.15	1624
	16	4.42	1327	5.19	1368	5.77	1382	6.34	1410	6.89	1484	7.45	1558	7.82	1605	8.05	1637
	17	4.36	1338	5.13	1379	5.70	1393	6.27	1421	6.81	1496	7.36	1571	7.73	1618	7.96	1650
	18	4.31	1348	5.07	1390	5.64	1404	6.19	1433	6.73	1508	7.27	1584	7.63	1631	7.86	1664
	19	4.26	1359	5.01	1401	5.57	1415	6.12	1444	6.65	1520	7.18	1596	7.54	1644	7.77	1677
	20	4.22	1370	4.96	1413	5.51	1427	6.06	1456	6.59	1533	7.11	1609	7.47	1657	7.69	1691
	21	4.17	1385	4.90	1428	5.45	1443	5.99	1472	6.51	1549	7.03	1627	7.38	1676	7.60	1709
	22	4.12	1400	4.84	1444	5.38	1458	5.91	1488	6.43	1566	6.94	1645	7.29	1694	7.51	1728
	23	4.07	1416	4.79	1460	5.32	1474	5.84	1505	6.35	1584	6.86	1663	7.20	1713	7.42	1747
	24	4.02	1431	4.73	1476	5.25	1491	5.77	1521	6.28	1601	6.78	1681	7.12	1732	7.33	1766
	25	3.97	1447	4.67	1492	5.19	1507	5.70	1538	6.20	1619	6.70	1700	7.03	1751	7.24	1786
	26	3.92	1463	4.62	1508	5.13	1524	5.64	1555	6.13	1637	6.62	1718	6.95	1770	7.16	1805
	27	3.88	1479	4.56	1525	5.07	1540	5.57	1572	6.05	1655	6.54	1737	6.86	1789	7.07	1825
	28	3.83	1495	4.51	1542	5.01	1557	5.50	1589	5.98	1673	6.46	1756	6.78	1809	6.98	1845
	29	3.78	1512	4.45	1559	4.95	1574	5.44	1607	5.91	1691	6.38	1776	6.70	1829	6.90	1866
	30	3.74	1529	4.40	1576	4.89	1592	5.37	1624	5.84	1710	6.30	1795	6.62	1849	6.82	1886
COMBINATION (%)	INDOOR DB(°C)	OUTDOOR WB(°C)															
		-15		-10		-5		0		5		10		15		20	
		Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT
80%	15	4.33	1303	5.10	1343	5.67	1357	6.23	1385	6.77	1458	7.31	1530	7.67	1576	7.90	1608
	16	4.28	1314	5.04	1354	5.60	1368	6.15	1396	6.69	1469	7.22	1543	7.58	1589	7.81	1621
	17	4.23	1324	4.98	1365	5.53	1379	6.08	1407	6.61	1481	7.14	1555	7.49	1602	7.72	1634
	18	4.18	1335	4.92	1376	5.47	1390	6.01	1418	6.53	1493	7.05	1568	7.40	1615	7.63	1647
	19	4.13	1346	4.86	1387	5.40	1401	5.94	1430	6.45	1505	6.97	1580	7.32	1628	7.54	1660
	20	4.09	1356	4.81	1398	5.35	1413	5.88	1441	6.39	1517	6.90	1593	7.24	1641	7.46	1674
	21	4.04	1371	4.76	1414	5.28	1428	5.81	1457	6.31	1534	6.82	1611	7.16	1659	7.37	1692
	22	3.99	1386	4.70	1429	5.22	1444	5.74	1473	6.24	1551	6.74	1628	7.07	1677	7.28	1711
	23	3.95	1402	4.64	1445	5.16	1460	5.67	1489	6.16	1568	6.65	1646	6.99	1696	7.20	1730
	24	3.90	1417	4.59	1461	5.10	1476	5.60	1506	6.09	1585	6.57	1664	6.90	1714	7.11	1749
	25	3.85	1433	4.53	1477	5.04	1492	5.53	1522	6.01	1603	6.50	1683	6.82	1733	7.02	1768
	26	3.81	1449	4.48	1493	4.97	1508	5.47	1539	5.94	1620	6.42	1701	6.74	1752	6.94	1787
	27	3.76	1464	4.42	1510	4.92	1525	5.40	1556	5.87	1638	6.34	1720	6.66	1771	6.86	1807
	28	3.71	1481	4.37	1526	4.86	1542	5.34	1573	5.80	1656	6.26	1739	6.58	1791	6.77	1827
	29	3.67	1497	4.32	1543	4.80	1559	5.27	1591	5.73	1674	6.19	1758	6.50	1811	6.69	1847
	30	3.63	1513	4.27	1560	4.74	1576	5.21	1608	5.66	1693	6.11	1777	6.42	1831	6.61	1867

Remarks:
 Q: Total Cooling Capacity (Gross) **kW**
 INPUT: Power Input (including the compressor, evap. fan motor & cond. **W**
 DB: Dry Bulb Temperature
 WB: Wet Bulb Temperature

2AMW42U4RGC

-

UE MULTI 2 POSTES 4,2 KW

4. CAPACITIES AND SELECTION DATA

14K (Up to 2 indoor units series)

	Cooling Operation PERFORMANCE DATA																																																					
	OUTDOOR DB (°C)																																																					
COMBINATION (%)	IDDB (°C)	ID WB (°C)	-15				-7				0				10				15				21				25				27				30				35				40				45				50			
			Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT								
130%	21	18	3.11	1.79	0.58	267	3.11	1.79	0.58	298	3.11	1.79	0.58	328	3.46	1.99	0.58	349	3.46	1.99	0.58	390	5.26	3.03	0.58	820	5.03	2.90	0.58	862	4.84	2.79	0.58	902	4.65	2.68	0.58	944	4.39	2.53	0.58	1005	4.03	2.32	0.58	1067	3.73	2.15	0.58	1108	3.09	1.78	0.58	1150
	21	20	3.27	1.49	0.46	307	3.27	1.49	0.46	338	3.27	1.49	0.46	368	3.63	1.66	0.46	389	3.63	1.66	0.46	430	5.53	2.52	0.46	853	5.29	2.41	0.46	897	5.09	2.32	0.46	938	4.89	2.23	0.46	981	4.61	2.10	0.46	1045	4.24	1.93	0.46	1110	3.92	1.79	0.46	1152	3.25	1.48	0.46	1196
	22	18	3.11	1.92	0.62	267	3.11	1.92	0.62	298	3.11	1.92	0.62	328	3.46	2.13	0.62	349	3.46	2.13	0.62	390	5.26	3.24	0.62	820	5.03	3.10	0.62	862	4.84	2.98	0.62	902	4.65	2.87	0.62	944	4.39	2.70	0.62	1005	4.03	2.48	0.62	1067	3.73	2.30	0.62	1108	3.09	1.91	0.62	1150
	22	20	3.27	1.62	0.50	307	3.27	1.62	0.50	338	3.27	1.62	0.50	368	3.63	1.80	0.50	389	3.63	1.80	0.50	430	5.53	2.74	0.50	853	5.29	2.62	0.50	897	5.09	2.52	0.50	938	4.89	2.43	0.50	981	4.61	2.29	0.50	1045	4.24	2.10	0.50	1110	3.92	1.94	0.50	1152	3.25	1.61	0.50	1196
	22	22	3.47	1.30	0.38	346	3.47	1.30	0.38	377	3.47	1.30	0.38	407	3.85	1.45	0.38	428	3.85	1.45	0.38	469	5.86	2.20	0.38	885	5.61	2.11	0.38	930	5.39	2.03	0.38	973	5.18	1.95	0.38	1018	4.89	1.84	0.38	1084	4.49	1.69	0.38	1151	4.15	1.56	0.38	1195	3.45	1.30	0.38	1240
	23	18	3.11	2.04	0.66	267	3.11	2.04	0.66	298	3.11	2.04	0.66	328	3.46	2.27	0.66	349	3.46	2.27	0.66	390	5.26	3.45	0.66	820	5.03	3.30	0.66	862	4.84	3.17	0.66	902	4.65	3.05	0.66	944	4.39	2.88	0.66	1005	4.03	2.64	0.66	1067	3.73	2.45	0.66	1108	3.09	2.03	0.66	1150
	23	20	3.27	1.75	0.54	307	3.27	1.75	0.54	338	3.27	1.75	0.54	368	3.63	1.95	0.54	389	3.63	1.95	0.54	430	5.53	2.96	0.54	853	5.29	2.84	0.54	897	5.09	2.73	0.54	938	4.89	2.62	0.54	981	4.61	2.47	0.54	1045	4.24	2.27	0.54	1110	3.92	2.10	0.54	1152	3.25	1.74	0.54	1196
	23	22	3.47	1.44	0.42	346	3.47	1.44	0.42	377	3.47	1.44	0.42	407	3.85	1.60	0.42	428	3.85	1.60	0.42	469	5.86	2.44	0.42	885	5.61	2.33	0.42	930	5.39	2.24	0.42	973	5.18	2.16	0.42	1018	4.89	2.03	0.42	1084	4.49	1.87	0.42	1151	4.15	1.73	0.42	1195	3.45	1.43	0.42	1240
	24	18	3.11	2.17	0.70	267	3.11	2.17	0.70	298	3.11	2.17	0.70	328	3.46	2.41	0.70	349	3.46	2.41	0.70	390	5.26	3.66	0.70	820	5.03	3.50	0.70	862	4.84	3.37	0.70	902	4.65	3.24	0.70	944	4.39	3.06	0.70	1005	4.03	2.80	0.70	1067	3.73	2.59	0.70	1108	3.09	2.15	0.70	1150
	24	20	3.27	1.88	0.58	307	3.27	1.88	0.58	338	3.27	1.88	0.58	368	3.63	2.09	0.58	389	3.63	2.09	0.58	430	5.53	3.18	0.58	853	5.29	3.05	0.58	897	5.09	2.93	0.58	938	4.89	2.82	0.58	981	4.61	2.66	0.58	1045	4.24	2.44	0.58	1110	3.92	2.26	0.58	1152	3.25	1.87	0.58	1196
	24	22	3.47	1.58	0.46	346	3.47	1.58	0.46	377	3.47	1.58	0.46	407	3.85	1.76	0.46	428	3.85	1.76	0.46	469	5.86	2.67	0.46	885	5.61	2.56	0.46	930	5.39	2.46	0.46	973	5.18	2.36	0.46	1018	4.89	2.23	0.46	1084	4.49	2.05	0.46	1151	4.15	1.89	0.46	1195	3.45	1.57	0.46	1240
	24	24	3.68	1.23	0.34	386	3.68	1.23	0.34	417	3.68	1.23	0.34	447	4.08	1.37	0.34	468	4.08	1.37	0.34	509	6.21	2.09	0.34	917	5.94	2.00	0.34	964	5.72	1.92	0.34	1009	5.50	1.85	0.34	1055	5.18	1.74	0.34	1124	4.76	1.60	0.34	1194	4.40	1.48	0.34	1239	3.65	1.23	0.34	1286
	25	18	3.11	2.29	0.74	267	3.11	2.29	0.74	298	3.11	2.29	0.74	328	3.46	2.54	0.74	349	3.46	2.54	0.74	390	5.26	3.87	0.74	820	5.03	3.70	0.74	862	4.84	3.56	0.74	902	4.65	3.42	0.74	944	4.39	3.23	0.74	1005	4.03	2.97	0.74	1067	3.73	2.74	0.74	1108	3.09	2.28	0.74	1150
	25	20	3.27	2.02	0.62	307	3.27	2.02	0.62	338	3.27	2.02	0.62	368	3.63	2.24	0.62	389	3.63	2.24	0.62	430	5.53	3.41	0.62	853	5.29	3.26	0.62	897	5.09	3.13	0.62	938	4.89	3.01	0.62	981	4.61	2.84	0.62	1045	4.24	2.61	0.62	1110	3.92	2.41	0.62	1152	3.25	2.00	0.62	1196
	25	22	3.47	1.72	0.50	346	3.47	1.72	0.50	377	3.47	1.72	0.50	407	3.85	1.91	0.50	428	3.85	1.91	0.50	469	5.86	2.91	0.50	885	5.61	2.78	0.50	930	5.39	2.67	0.50	973	5.18	2.57	0.50	1018	4.89	2.43	0.50	1084	4.49	2.23	0.50	1151	4.15	2.06	0.50	1195	3.45	1.71	0.50	1240
	25	24	3.68	1.38	0.38	386	3.68	1.38	0.38	417	3.68	1.38	0.38	447	4.08	1.53	0.38	468	4.08	1.53	0.38	509	6.21	2.34	0.38	917	5.94	2.23	0.38	964	5.72	2.15	0.38	1009	5.50	2.07	0.38	1055	5.18	1.95	0.38	1124	4.76	1.79	0.38	1194	4.40	1.66	0.38	1239	3.65	1.37	0.38	1286
	26	18	3.11	2.42	0.78	267	3.11	2.42	0.78	298	3.11	2.42	0.78	328	3.46	2.68	0.78	349	3.46	2.68	0.78	390	5.26	4.08	0.78	820	5.03	3.91	0.78	862	4.84	3.76	0.78	902	4.65	3.61	0.78	944	4.39	3.41	0.78	1005	4.03	3.13	0.78	1067	3.73	2.89	0.78	1108	3.09	2.40	0.78	1150
	26	20	3.27	2.15	0.66	307	3.27	2.15	0.66	338	3.27	2.15	0.66	368	3.63	2.38	0.66	389	3.63	2.38	0.66	430	5.53	3.63	0.66	853	5.29	3.47	0.66	897	5.09	3.34	0.66	938	4.89	3.21	0.66	981	4.61	3.03	0.66	1045	4.24	2.78	0.66	1110	3.92	2.57	0.66	1152	3.25	2.13	0.66	111

4. CAPACITIES AND SELECTION DATA

	Cooling Operation PERFORMANCE DATA																																																					
	OUTDOOR DB (°C)																																																					
COMBINATION (%)	IDDB (°C)	ID WB (°C)	-15				-7				0				10				15				21				25				27				30				35				40				45				50			
			Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT												
120%	21	18	3.02	1.81	0.60	253	3.02	1.81	0.60	283	3.02	1.81	0.60	312	3.36	2.01	0.60	331	3.36	2.01	0.60	370	5.11	3.06	0.60	780	4.89	2.93	0.60	820	4.70	2.82	0.60	858	4.52	2.71	0.60	898	4.26	2.55	0.60	956	3.91	2.35	0.60	1015	3.62	2.17	0.60	1054	3.00	1.80	0.60	1094
	21	20	3.18	1.52	0.48	293	3.18	1.52	0.48	323	3.18	1.52	0.48	352	3.53	1.69	0.48	371	3.53	1.69	0.48	410	5.37	2.57	0.48	813	5.14	2.46	0.48	855	4.94	2.37	0.48	894	4.75	2.28	0.48	935	4.48	2.15	0.48	996	4.11	1.97	0.48	1058	3.80	1.82	0.48	1098	3.16	1.51	0.48	1140
	22	18	3.02	1.93	0.64	253	3.02	1.93	0.64	283	3.02	1.93	0.64	312	3.36	2.15	0.64	331	3.36	2.15	0.64	370	5.11	3.26	0.64	780	4.89	3.12	0.64	820	4.70	3.00	0.64	858	4.52	2.89	0.64	898	4.26	2.73	0.64	956	3.91	2.50	0.64	1015	3.62	2.31	0.64	1054	3.00	1.92	0.64	1094
	22	20	3.18	1.65	0.52	293	3.18	1.65	0.52	323	3.18	1.65	0.52	352	3.53	1.83	0.52	371	3.53	1.83	0.52	410	5.37	2.79	0.52	813	5.14	2.67	0.52	855	4.94	2.56	0.52	894	4.75	2.47	0.52	935	4.48	2.33	0.52	996	4.11	2.14	0.52	1058	3.80	1.98	0.52	1098	3.16	1.64	0.52	1140
	22	22	3.37	1.34	0.40	332	3.37	1.34	0.40	362	3.37	1.34	0.40	391	3.74	1.49	0.40	410	3.74	1.49	0.40	449	5.69	2.27	0.40	845	5.44	2.17	0.40	888	5.24	2.09	0.40	929	5.03	2.01	0.40	972	4.75	1.90	0.40	1035	4.36	1.74	0.40	1099	4.03	1.61	0.40	1141	3.35	1.34	0.40	1184
	23	18	3.02	2.05	0.68	253	3.02	2.05	0.68	283	3.02	2.05	0.68	312	3.36	2.28	0.68	331	3.36	2.28	0.68	370	5.11	3.47	0.68	780	4.89	3.32	0.68	820	4.70	3.19	0.68	858	4.52	3.07	0.68	898	4.26	2.90	0.68	956	3.91	2.66	0.68	1015	3.62	2.46	0.68	1054	3.00	2.04	0.68	1094
	23	20	3.18	1.78	0.56	293	3.18	1.78	0.56	323	3.18	1.78	0.56	352	3.53	1.97	0.56	371	3.53	1.97	0.56	410	5.37	3.00	0.56	813	5.14	2.87	0.56	855	4.94	2.76	0.56	894	4.75	2.66	0.56	935	4.48	2.51	0.56	996	4.11	2.30	0.56	1058	3.80	2.13	0.56	1098	3.16	1.77	0.56	1140
	23	22	3.37	1.48	0.44	332	3.37	1.48	0.44	362	3.37	1.48	0.44	391	3.74	1.64	0.44	410	3.74	1.64	0.44	449	5.69	2.50	0.44	845	5.44	2.39	0.44	888	5.24	2.30	0.44	929	5.03	2.21	0.44	972	4.75	2.09	0.44	1035	4.36	1.92	0.44	1099	4.03	1.77	0.44	1141	3.35	1.47	0.44	1184
	24	18	3.02	2.17	0.72	253	3.02	2.17	0.72	283	3.02	2.17	0.72	312	3.36	2.41	0.72	331	3.36	2.41	0.72	370	5.11	3.67	0.72	780	4.89	3.52	0.72	820	4.70	3.38	0.72	858	4.52	3.25	0.72	898	4.26	3.07	0.72	956	3.91	2.81	0.72	1015	3.62	2.60	0.72	1054	3.00	2.16	0.72	1094
	24	20	3.18	1.90	0.60	293	3.18	1.90	0.60	323	3.18	1.90	0.60	352	3.53	2.11	0.60	371	3.53	2.11	0.60	410	5.37	3.22	0.60	813	5.14	3.08	0.60	855	4.94	2.96	0.60	894	4.75	2.85	0.60	935	4.48	2.68	0.60	996	4.11	2.46	0.60	1058	3.80	2.28	0.60	1098	3.16	1.89	0.60	1140
	24	22	3.37	1.61	0.48	332	3.37	1.61	0.48	362	3.37	1.61	0.48	391	3.74	1.79	0.48	410	3.74	1.79	0.48	449	5.69	2.73	0.48	845	5.44	2.61	0.48	888	5.24	2.51	0.48	929	5.03	2.41	0.48	972	4.75	2.28	0.48	1035	4.36	2.09	0.48	1099	4.03	1.93	0.48	1141	3.35	1.60	0.48	1184
	24	24	3.57	1.28	0.36	372	3.57	1.28	0.36	402	3.57	1.28	0.36	431	3.96	1.42	0.36	450	3.96	1.42	0.36	489	6.03	2.17	0.36	877	5.77	2.07	0.36	923	5.55	1.99	0.36	965	5.34	1.92	0.36	1009	5.03	1.81	0.36	1075	4.62	1.66	0.36	1142	4.27	1.54	0.36	1185	3.55	1.27	0.36	1230
	25	18	3.02	2.29	0.76	253	3.02	2.29	0.76	283	3.02	2.29	0.76	312	3.36	2.55	0.76	331	3.36	2.55	0.76	370	5.11	3.88	0.76	780	4.89	3.71	0.76	820	4.70	3.57	0.76	858	4.52	3.43	0.76	898	4.26	3.24	0.76	956	3.91	2.97	0.76	1015	3.62	2.75	0.76	1054	3.00	2.28	0.76	1094
	25	20	3.18	2.03	0.64	293	3.18	2.03	0.64	323	3.18	2.03	0.64	352	3.53	2.26	0.64	371	3.53	2.26	0.64	410	5.37	3.43	0.64	813	5.14	3.28	0.64	855	4.94	3.16	0.64	894	4.75	3.04	0.64	935	4.48	2.86	0.64	996	4.11	2.63	0.64	1058	3.80	2.43	0.64	1098	3.16	2.02	0.64	1140
	25	22	3.37	1.75	0.52	332	3.37	1.75	0.52	362	3.37	1.75	0.52	391	3.74	1.94	0.52	410	3.74	1.94	0.52	449	5.69	2.95	0.52	845	5.44	2.83	0.52	888	5.24	2.72	0.52	929	5.03	2.61	0.52	972	4.75	2.47	0.52	1035	4.36	2.26	0.52	1099	4.03	2.09	0.52	1141	3.35	1.74	0.52	1184
	25	24	3.57	1.43	0.40	372	3.57	1.43	0.40	402	3.57	1.43	0.40	431	3.96	1.58	0.40	450	3.96	1.58	0.40	489	6.03	2.41	0.40	877	5.77	2.30	0.40	923	5.55	2.22	0.40	965	5.34	2.13	0.40	1009	5.03	2.01	0.40	1075	4.62	1.85	0.40	1142	4.27	1.71	0.40	1185	3.55	1.42	0.40	1230
	26	18	3.02	2.42	0.80	253	3.02	2.42	0.80	283	3.02	2.42	0.80	312	3.36	2.68	0.80	331	3.36	2.68	0.80	370	5.11	4.08	0.80	780	4.89	3.91	0.80	820	4.70	3.76	0.80	858	4.52	3.61	0.80	898	4.26	3.41	0.80	956	3.91	3.13	0.80	1015	3.62	2.89	0.80	1054	3.00	2.40	0.80	1094
	26	20	3.18	2.16	0.68	293	3.18	2.16	0.68	323	3.18	2.16	0.68	352	3.53	2.40	0.68	371	3.53	2.40	0.68	410	5.37	3.65	0.68	813	5.14	3.49	0.68	855	4.94	3.36	0.68	894	4.75	3.23	0.68	935	4.48	3.04	0.68	996	4.11											

4. CAPACITIES AND SELECTION DATA

	Cooling Operation PERFORMANCE DATA																																																					
	OUTDOOR DB (°C)																																																					
COMBINATION (%)	IDDB (°C)	ID WB (°C)	-15				-7				0				10				15				21				25				27				30				35				40				45				50			
			Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT												
110%	21	18	2.93	1.83	0.62	245	2.93	1.83	0.62	274	2.93	1.83	0.62	302	3.26	2.03	0.62	321	3.26	2.03	0.62	359	4.96	3.09	0.62	757	4.74	2.96	0.62	796	4.56	2.84	0.62	833	4.39	2.73	0.62	871	4.14	2.58	0.62	928	3.80	2.37	0.62	985	3.51	2.19	0.62	1023	2.92	1.82	0.62	1061
	21	20	3.08	1.55	0.50	285	3.08	1.55	0.50	314	3.08	1.55	0.50	342	3.43	1.72	0.50	361	3.43	1.72	0.50	399	5.21	2.62	0.50	790	4.99	2.51	0.50	830	4.80	2.41	0.50	869	4.61	2.32	0.50	909	4.35	2.19	0.50	968	3.99	2.01	0.50	1028	3.69	1.86	0.50	1067	3.07	1.54	0.50	1107
	22	18	2.93	1.95	0.66	245	2.93	1.95	0.66	274	2.93	1.95	0.66	302	3.26	2.16	0.66	321	3.26	2.16	0.66	359	4.96	3.29	0.66	757	4.74	3.15	0.66	796	4.56	3.03	0.66	833	4.39	2.91	0.66	871	4.14	2.75	0.66	928	3.80	2.52	0.66	985	3.51	2.33	0.66	1023	2.92	1.94	0.66	1061
	22	20	3.08	1.68	0.54	285	3.08	1.68	0.54	314	3.08	1.68	0.54	342	3.43	1.86	0.54	361	3.43	1.86	0.54	399	5.21	2.83	0.54	790	4.99	2.71	0.54	830	4.80	2.61	0.54	869	4.61	2.51	0.54	909	4.35	2.36	0.54	968	3.99	2.17	0.54	1028	3.69	2.01	0.54	1067	3.07	1.67	0.54	1107
	22	22	3.27	1.38	0.42	324	3.27	1.38	0.42	353	3.27	1.38	0.42	381	3.63	1.54	0.42	400	3.63	1.54	0.42	438	5.52	2.34	0.42	822	5.29	2.24	0.42	864	5.08	2.15	0.42	904	4.89	2.07	0.42	945	4.61	1.95	0.42	1007	4.23	1.79	0.42	1069	3.92	1.66	0.42	1110	3.25	1.38	0.42	1152
	23	18	2.93	2.06	0.70	245	2.93	2.06	0.70	274	2.93	2.06	0.70	302	3.26	2.29	0.70	321	3.26	2.29	0.70	359	4.96	3.49	0.70	757	4.74	3.34	0.70	796	4.56	3.21	0.70	833	4.39	3.09	0.70	871	4.14	2.91	0.70	928	3.80	2.67	0.70	985	3.51	2.47	0.70	1023	2.92	2.05	0.70	1061
	23	20	3.08	1.80	0.58	285	3.08	1.80	0.58	314	3.08	1.80	0.58	342	3.43	2.00	0.58	361	3.43	2.00	0.58	399	5.21	3.04	0.58	790	4.99	2.91	0.58	830	4.80	2.80	0.58	869	4.61	2.69	0.58	909	4.35	2.54	0.58	968	3.99	2.33	0.58	1028	3.69	2.15	0.58	1067	3.07	1.79	0.58	1107
	23	22	3.27	1.51	0.46	324	3.27	1.51	0.46	353	3.27	1.51	0.46	381	3.63	1.68	0.46	400	3.63	1.68	0.46	438	5.52	2.56	0.46	822	5.29	2.45	0.46	864	5.08	2.36	0.46	904	4.89	2.26	0.46	945	4.61	2.14	0.46	1007	4.23	1.96	0.46	1069	3.92	1.81	0.46	1110	3.25	1.51	0.46	1152
	24	18	2.93	2.18	0.74	245	2.93	2.18	0.74	274	2.93	2.18	0.74	302	3.26	2.42	0.74	321	3.26	2.42	0.74	359	4.96	3.69	0.74	757	4.74	3.53	0.74	796	4.56	3.39	0.74	833	4.39	3.26	0.74	871	4.14	3.08	0.74	928	3.80	2.82	0.74	985	3.51	2.61	0.74	1023	2.92	2.17	0.74	1061
	24	20	3.08	1.92	0.62	285	3.08	1.92	0.62	314	3.08	1.92	0.62	342	3.43	2.14	0.62	361	3.43	2.14	0.62	399	5.21	3.25	0.62	790	4.99	3.11	0.62	830	4.80	2.99	0.62	869	4.61	2.87	0.62	909	4.35	2.71	0.62	968	3.99	2.49	0.62	1028	3.69	2.30	0.62	1067	3.07	1.91	0.62	1107
	24	22	3.27	1.65	0.50	324	3.27	1.65	0.50	353	3.27	1.65	0.50	381	3.63	1.83	0.50	400	3.63	1.83	0.50	438	5.52	2.78	0.50	822	5.29	2.66	0.50	864	5.08	2.56	0.50	904	4.89	2.46	0.50	945	4.61	2.32	0.50	1007	4.23	2.13	0.50	1069	3.92	1.97	0.50	1110	3.25	1.64	0.50	1152
	24	24	3.47	1.33	0.38	364	3.47	1.33	0.38	393	3.47	1.33	0.38	421	3.85	1.48	0.38	440	3.85	1.48	0.38	478	5.86	2.24	0.38	854	5.60	2.15	0.38	898	5.39	2.07	0.38	940	5.18	1.99	0.38	983	4.89	1.87	0.38	1047	4.49	1.72	0.38	1111	4.15	1.59	0.38	1154	3.44	1.32	0.38	1198
	25	18	2.93	2.30	0.78	245	2.93	2.30	0.78	274	2.93	2.30	0.78	302	3.26	2.55	0.78	321	3.26	2.55	0.78	359	4.96	3.88	0.78	757	4.74	3.72	0.78	796	4.56	3.57	0.78	833	4.39	3.44	0.78	871	4.14	3.24	0.78	928	3.80	2.98	0.78	985	3.51	2.75	0.78	1023	2.92	2.29	0.78	1061
	25	20	3.08	2.05	0.66	285	3.08	2.05	0.66	314	3.08	2.05	0.66	342	3.43	2.27	0.66	361	3.43	2.27	0.66	399	5.21	3.46	0.66	790	4.99	3.31	0.66	830	4.80	3.18	0.66	869	4.61	3.06	0.66	909	4.35	2.89	0.66	968	3.99	2.65	0.66	1028	3.69	2.45	0.66	1067	3.07	2.03	0.66	1107
	25	22	3.27	1.78	0.54	324	3.27	1.78	0.54	353	3.27	1.78	0.54	381	3.63	1.97	0.54	400	3.63	1.97	0.54	438	5.52	3.00	0.54	822	5.29	2.87	0.54	864	5.08	2.76	0.54	904	4.89	2.66	0.54	945	4.61	2.51	0.54	1007	4.23	2.30	0.54	1069	3.92	2.13	0.54	1110	3.25	1.77	0.54	1152
	25	24	3.47	1.47	0.42	364	3.47	1.47	0.42	393	3.47	1.47	0.42	421	3.85	1.63	0.42	440	3.85	1.63	0.42	478	5.86	2.48	0.42	854	5.60	2.37	0.42	898	5.39	2.28	0.42	940	5.18	2.19	0.42	983	4.89	2.07	0.42	1047	4.49	1.90	0.42	1111	4.15	1.76	0.42	1154	3.44	1.46	0.42	1198
	26	18	2.93	2.42	0.82	245	2.93	2.42	0.82	274	2.93	2.42	0.82	302	3.26	2.68	0.82	321	3.26	2.68	0.82	359	4.96	4.08	0.82	757	4.74	3.91	0.82	796	4.56	3.76	0.82	833	4.39	3.61	0.82	871	4.14	3.41	0.82	928	3.80	3.13	0.82	985	3.51	2.89	0.82	1023	2.92	2.40	0.82	1061
	26	20	3.08	2.17	0.70	285	3.08	2.17	0.70	314	3.08	2.17	0.70	342	3.43	2.41	0.70	361	3.43	2.41	0.70	399	5.21	3.67	0.70	790	4.99	3.51	0.70	830																								

4. CAPACITIES AND SELECTION DATA

		Cooling Operation PERFORMANCE DATA																																																				
		OUTDOOR DB (°C)																																																				
COMBINATION (%)	IDDB (°C)	ID WB (°C)	-15				-7				0				10				15				21				25				27				30				35				40				45				50			
			Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT												
100%	21	18	2.85	1.71	0.60	238	2.85	1.71	0.60	265	2.85	1.71	0.60	293	3.16	1.90	0.60	311	3.16	1.90	0.60	348	4.81	2.89	0.60	735	4.61	2.76	0.60	772	4.43	2.66	0.60	808	4.26	2.56	0.60	845	4.02	2.41	0.60	900	3.69	2.21	0.60	956	3.41	2.05	0.60	992	2.83	1.70	0.60	1030
	21	20	2.99	1.44	0.48	278	2.99	1.44	0.48	305	2.99	1.44	0.48	333	3.33	1.60	0.48	351	3.33	1.60	0.48	388	5.06	2.43	0.48	767	4.84	2.32	0.48	807	4.66	2.23	0.48	844	4.48	2.15	0.48	883	4.22	2.03	0.48	940	3.88	1.86	0.48	998	3.59	1.72	0.48	1036	2.98	1.43	0.48	1076
	22	18	2.85	1.82	0.64	238	2.85	1.82	0.64	265	2.85	1.82	0.64	293	3.16	2.03	0.64	311	3.16	2.03	0.64	348	4.81	3.08	0.64	735	4.61	2.95	0.64	772	4.43	2.83	0.64	808	4.26	2.73	0.64	845	4.02	2.57	0.64	900	3.69	2.36	0.64	956	3.41	2.18	0.64	992	2.83	1.81	0.64	1030
	22	20	2.99	1.56	0.52	278	2.99	1.56	0.52	305	2.99	1.56	0.52	333	3.33	1.73	0.52	351	3.33	1.73	0.52	388	5.06	2.63	0.52	767	4.84	2.52	0.52	807	4.66	2.42	0.52	844	4.48	2.33	0.52	883	4.22	2.20	0.52	940	3.88	2.02	0.52	998	3.59	1.86	0.52	1036	2.98	1.55	0.52	1076
	22	22	3.17	1.27	0.40	317	3.17	1.27	0.40	344	3.17	1.27	0.40	372	3.53	1.41	0.40	390	3.53	1.41	0.40	427	5.36	2.15	0.40	799	5.13	2.05	0.40	840	4.93	1.97	0.40	879	4.74	1.90	0.40	919	4.48	1.79	0.40	979	4.11	1.64	0.40	1040	3.80	1.52	0.40	1079	3.15	1.26	0.40	1120
	23	18	2.85	1.94	0.68	238	2.85	1.94	0.68	265	2.85	1.94	0.68	293	3.16	2.15	0.68	311	3.16	2.15	0.68	348	4.81	3.27	0.68	735	4.61	3.13	0.68	772	4.43	3.01	0.68	808	4.26	2.90	0.68	845	4.02	2.73	0.68	900	3.69	2.51	0.68	956	3.41	2.32	0.68	992	2.83	1.93	0.68	1030
	23	20	2.99	1.68	0.56	278	2.99	1.68	0.56	305	2.99	1.68	0.56	333	3.33	1.86	0.56	351	3.33	1.86	0.56	388	5.06	2.83	0.56	767	4.84	2.71	0.56	807	4.66	2.61	0.56	844	4.48	2.51	0.56	883	4.22	2.36	0.56	940	3.88	2.17	0.56	998	3.59	2.01	0.56	1036	2.98	1.67	0.56	1076
	23	22	3.17	1.40	0.44	317	3.17	1.40	0.44	344	3.17	1.40	0.44	372	3.53	1.55	0.44	390	3.53	1.55	0.44	427	5.36	2.36	0.44	799	5.13	2.26	0.44	840	4.93	2.17	0.44	879	4.74	2.09	0.44	919	4.48	1.97	0.44	979	4.11	1.81	0.44	1040	3.80	1.67	0.44	1079	3.15	1.39	0.44	1120
	24	18	2.85	2.05	0.72	238	2.85	2.05	0.72	265	2.85	2.05	0.72	293	3.16	2.28	0.72	311	3.16	2.28	0.72	348	4.81	3.47	0.72	735	4.61	3.32	0.72	772	4.43	3.19	0.72	808	4.26	3.07	0.72	845	4.02	2.89	0.72	900	3.69	2.66	0.72	956	3.41	2.46	0.72	992	2.83	2.04	0.72	1030
	24	20	2.99	1.80	0.60	278	2.99	1.80	0.60	305	2.99	1.80	0.60	333	3.33	2.00	0.60	351	3.33	2.00	0.60	388	5.06	3.04	0.60	767	4.84	2.90	0.60	807	4.66	2.79	0.60	844	4.48	2.69	0.60	883	4.22	2.53	0.60	940	3.88	2.33	0.60	998	3.59	2.15	0.60	1036	2.98	1.79	0.60	1076
	24	22	3.17	1.52	0.48	317	3.17	1.52	0.48	344	3.17	1.52	0.48	372	3.53	1.69	0.48	390	3.53	1.69	0.48	427	5.36	2.57	0.48	799	5.13	2.46	0.48	840	4.93	2.37	0.48	879	4.74	2.28	0.48	919	4.48	2.15	0.48	979	4.11	1.97	0.48	1040	3.80	1.82	0.48	1079	3.15	1.51	0.48	1120
	24	24	3.36	1.21	0.36	357	3.36	1.21	0.36	384	3.36	1.21	0.36	412	3.74	1.35	0.36	430	3.74	1.35	0.36	467	5.68	2.05	0.36	832	5.44	1.96	0.36	874	5.23	1.88	0.36	915	5.03	1.81	0.36	957	4.74	1.71	0.36	1019	4.36	1.57	0.36	1082	4.03	1.45	0.36	1123	3.34	1.20	0.36	1166
	25	18	2.85	2.17	0.76	238	2.85	2.17	0.76	265	2.85	2.17	0.76	293	3.16	2.40	0.76	311	3.16	2.40	0.76	348	4.81	3.66	0.76	735	4.61	3.50	0.76	772	4.43	3.37	0.76	808	4.26	3.24	0.76	845	4.02	3.05	0.76	900	3.69	2.80	0.76	956	3.41	2.59	0.76	992	2.83	2.15	0.76	1030
	25	20	2.99	1.92	0.64	278	2.99	1.92	0.64	305	2.99	1.92	0.64	333	3.33	2.13	0.64	351	3.33	2.13	0.64	388	5.06	3.24	0.64	767	4.84	3.10	0.64	807	4.66	2.98	0.64	844	4.48	2.86	0.64	883	4.22	2.70	0.64	940	3.88	2.48	0.64	998	3.59	2.30	0.64	1036	2.98	1.90	0.64	1076
	25	22	3.17	1.65	0.52	317	3.17	1.65	0.52	344	3.17	1.65	0.52	372	3.53	1.83	0.52	390	3.53	1.83	0.52	427	5.36	2.79	0.52	799	5.13	2.67	0.52	840	4.93	2.57	0.52	879	4.74	2.47	0.52	919	4.48	2.33	0.52	979	4.11	2.14	0.52	1040	3.80	1.98	0.52	1079	3.15	1.64	0.52	1120
	25	24	3.36	1.35	0.40	357	3.36	1.35	0.40	384	3.36	1.35	0.40	412	3.74	1.49	0.40	430	3.74	1.49	0.40	467	5.68	2.27	0.40	832	5.44	2.18	0.40	874	5.23	2.09	0.40	915	5.03	2.01	0.40	957	4.74	1.90	0.40	1019	4.36	1.74	0.40	1082	4.03	1.61	0.40	1123	3.34	1.34	0.40	1166
	26	18	2.85	2.28	0.80	238	2.85	2.28	0.80	265	2.85	2.28	0.80	293	3.16	2.53	0.80	311	3.16	2.53	0.80	348	4.81	3.85	0.80	735	4.61	3.69	0.80	772	4.43	3.54	0.80	808	4.26	3.41	0.80	845	4.02	3.21	0.80	900	3.69	2.95	0.80	956	3.41	2.73	0.80	992	2.83	2.27	0.80	1030
	26	20	2.99	2.04	0.68	278	2.99	2.04	0.68	305	2.99	2.04	0.68	333	3.33	2.26	0.68	351	3.33	2.26	0.68	388	5.06	3.44	0.68	767	4.84	3.29	0.68	807	4.66	3.17	0.68	844	4.48	3.04	0.68	883	4.22	2.87	0.68	940	3.88	2.64	0.68	99								

4. CAPACITIES AND SELECTION DATA

	Cooling Operation PERFORMANCE DATA																																																					
	OUTDOOR DB (°C)																																																					
COMBINATION (%)	IDDB (°C)	ID WB (°C)	-15				-7				0				10				15				21				25				27				30				35				40				45				50			
			Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT								
90%	21	18	2.68	1.50	0.56	222	2.68	1.50	0.56	248	2.68	1.50	0.56	274	2.97	1.67	0.56	291	2.97	1.67	0.56	326	4.53	2.54	0.56	689	4.33	2.43	0.56	725	4.16	2.34	0.56	758	4.00	2.25	0.56	793	3.78	2.12	0.56	845	3.47	1.95	0.56	897	3.21	1.80	0.56	931	2.66	1.49	0.56	967
	21	20	2.81	1.24	0.44	262	2.81	1.24	0.44	288	2.81	1.24	0.44	314	3.13	1.38	0.44	331	3.13	1.38	0.44	366	4.76	2.10	0.44	722	4.55	2.01	0.44	759	4.38	1.93	0.44	794	4.21	1.86	0.44	831	3.97	1.75	0.44	885	3.64	1.61	0.44	940	3.37	1.49	0.44	975	2.80	1.23	0.44	1012
	22	18	2.68	1.61	0.60	222	2.68	1.61	0.60	248	2.68	1.61	0.60	274	2.97	1.79	0.60	291	2.97	1.79	0.60	326	4.53	2.72	0.60	689	4.33	2.60	0.60	725	4.16	2.50	0.60	758	4.00	2.41	0.60	793	3.78	2.27	0.60	845	3.47	2.08	0.60	897	3.21	1.93	0.60	931	2.66	1.60	0.60	967
	22	20	2.81	1.35	0.48	262	2.81	1.35	0.48	288	2.81	1.35	0.48	314	3.13	1.50	0.48	331	3.13	1.50	0.48	366	4.76	2.29	0.48	722	4.55	2.19	0.48	759	4.38	2.10	0.48	794	4.21	2.02	0.48	831	3.97	1.91	0.48	885	3.64	1.75	0.48	940	3.37	1.62	0.48	975	2.80	1.35	0.48	1012
	22	22	2.98	1.08	0.36	301	2.98	1.08	0.36	327	2.98	1.08	0.36	353	3.31	1.20	0.36	370	3.31	1.20	0.36	405	5.04	1.82	0.36	754	4.82	1.74	0.36	793	4.64	1.67	0.36	829	4.46	1.61	0.36	867	4.21	1.52	0.36	924	3.86	1.39	0.36	981	3.57	1.29	0.36	1018	2.97	1.07	0.36	1057
	23	18	2.68	1.72	0.64	222	2.68	1.72	0.64	248	2.68	1.72	0.64	274	2.97	1.91	0.64	291	2.97	1.91	0.64	326	4.53	2.90	0.64	689	4.33	2.78	0.64	725	4.16	2.67	0.64	758	4.00	2.57	0.64	793	3.78	2.42	0.64	845	3.47	2.22	0.64	897	3.21	2.06	0.64	931	2.66	1.71	0.64	967
	23	20	2.81	1.47	0.52	262	2.81	1.47	0.52	288	2.81	1.47	0.52	314	3.13	1.63	0.52	331	3.13	1.63	0.52	366	4.76	2.48	0.52	722	4.55	2.37	0.52	759	4.38	2.28	0.52	794	4.21	2.19	0.52	831	3.97	2.07	0.52	885	3.64	1.90	0.52	940	3.37	1.76	0.52	975	2.80	1.46	0.52	1012
	23	22	2.98	1.20	0.40	301	2.98	1.20	0.40	327	2.98	1.20	0.40	353	3.31	1.33	0.40	370	3.31	1.33	0.40	405	5.04	2.02	0.40	754	4.82	1.93	0.40	793	4.64	1.86	0.40	829	4.46	1.79	0.40	867	4.21	1.69	0.40	924	3.86	1.55	0.40	981	3.57	1.43	0.40	1018	2.97	1.19	0.40	1057
	24	18	2.68	1.82	0.68	222	2.68	1.82	0.68	248	2.68	1.82	0.68	274	2.97	2.03	0.68	291	2.97	2.03	0.68	326	4.53	3.08	0.68	689	4.33	2.95	0.68	725	4.16	2.84	0.68	758	4.00	2.73	0.68	793	3.78	2.57	0.68	845	3.47	2.36	0.68	897	3.21	2.18	0.68	931	2.66	1.81	0.68	967
	24	20	2.81	1.58	0.56	262	2.81	1.58	0.56	288	2.81	1.58	0.56	314	3.13	1.75	0.56	331	3.13	1.75	0.56	366	4.76	2.67	0.56	722	4.55	2.55	0.56	759	4.38	2.45	0.56	794	4.21	2.36	0.56	831	3.97	2.23	0.56	885	3.64	2.04	0.56	940	3.37	1.89	0.56	975	2.80	1.57	0.56	1012
	24	22	2.98	1.32	0.44	301	2.98	1.32	0.44	327	2.98	1.32	0.44	353	3.31	1.46	0.44	370	3.31	1.46	0.44	405	5.04	2.22	0.44	754	4.82	2.13	0.44	793	4.64	2.05	0.44	829	4.46	1.97	0.44	867	4.21	1.86	0.44	924	3.86	1.70	0.44	981	3.57	1.58	0.44	1018	2.97	1.31	0.44	1057
	24	24	3.16	1.02	0.32	341	3.16	1.02	0.32	367	3.16	1.02	0.32	393	3.51	1.13	0.32	410	3.51	1.13	0.32	445	5.34	1.72	0.32	787	5.11	1.64	0.32	827	4.92	1.58	0.32	865	4.73	1.52	0.32	905	4.46	1.43	0.32	964	4.09	1.31	0.32	1024	3.79	1.22	0.32	1062	3.14	1.01	0.32	1103
	25	18	2.68	1.93	0.72	222	2.68	1.93	0.72	248	2.68	1.93	0.72	274	2.97	2.14	0.72	291	2.97	2.14	0.72	326	4.53	3.26	0.72	689	4.33	3.12	0.72	725	4.16	3.00	0.72	758	4.00	2.89	0.72	793	3.78	2.72	0.72	845	3.47	2.50	0.72	897	3.21	2.31	0.72	931	2.66	1.92	0.72	967
	25	20	2.81	1.69	0.60	262	2.81	1.69	0.60	288	2.81	1.69	0.60	314	3.13	1.88	0.60	331	3.13	1.88	0.60	366	4.76	2.86	0.60	722	4.55	2.74	0.60	759	4.38	2.63	0.60	794	4.21	2.53	0.60	831	3.97	2.39	0.60	885	3.64	2.19	0.60	940	3.37	2.03	0.60	975	2.80	1.68	0.60	1012
	25	22	2.98	1.43	0.48	301	2.98	1.43	0.48	327	2.98	1.43	0.48	353	3.31	1.59	0.48	370	3.31	1.59	0.48	405	5.04	2.42	0.48	754	4.82	2.32	0.48	793	4.64	2.23	0.48	829	4.46	2.15	0.48	867	4.21	2.02	0.48	924	3.86	1.86	0.48	981	3.57	1.72	0.48	1018	2.97	1.43	0.48	1057
	25	24	3.16	1.14	0.36	341	3.16	1.14	0.36	367	3.16	1.14	0.36	393	3.51	1.27	0.36	410	3.51	1.27	0.36	445	5.34	1.93	0.36	787	5.11	1.85	0.36	827	4.92	1.78	0.36	865	4.73	1.71	0.36	905	4.46	1.61	0.36	964	4.09	1.48	0.36	1024	3.79	1.37	0.36	1062	3.14	1.13	0.36	1103
	26	18	2.68	2.04	0.76	222	2.68	2.04	0.76	248	2.68	2.04	0.76	274	2.97	2.26	0.76	291	2.97	2.26	0.76	326	4.53	3.44	0.76	689	4.33	3.30	0.76	725	4.16	3.17	0.76	758	4.00	3.05	0.76	793	3.78	2.87	0.76	845	3.47	2.64	0.76	897	3.21	2.44	0.76	931	2.66	2.03	0.76	967
	26	20	2.81	1.80	0.64	262	2.81	1.80	0.64	288	2.81	1.80	0.64	314	3.13	2.00	0.64	331	3.13	2.00	0.64	366	4.76	3.05	0.64	722	4.55	2.92	0.64	759	4.38	2.81	0.64	794	4.21	2.70	0.64	831	3.97	2.54	0.64	885	3.64	2.34	0.64	940	3.37	2.16	0.64	975	2.80			

4. CAPACITIES AND SELECTION DATA

				Cooling Operation PERFORMANCE DATA																																																		
				OUTDOOR DB (°C)																																																		
COMBINATION (%)	IDDB (°C)	ID WB (°C)	-15				-7				0				10				15				21				25				27				30				35				40				45				50			
			Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT								
80%	21	18	2.57	1.39	0.54	198	2.57	1.39	0.54	221	2.57	1.39	0.54	245	2.86	1.54	0.54	260	2.86	1.54	0.54	291	4.34	2.34	0.54	619	4.16	2.24	0.54	651	4.00	2.15	0.54	681	3.84	2.07	0.54	712	3.63	1.95	0.54	758	3.33	1.79	0.54	805	3.08	1.66	0.54	836	2.56	1.38	0.54	913
	21	20	2.70	1.13	0.42	238	2.70	1.13	0.42	261	2.70	1.13	0.42	285	3.00	1.26	0.42	300	3.00	1.26	0.42	331	4.57	1.91	0.42	652	4.37	1.83	0.42	685	4.20	1.76	0.42	717	4.04	1.69	0.42	750	3.81	1.60	0.42	798	3.50	1.47	0.42	848	3.24	1.36	0.42	880	2.69	1.12	0.42	868
	22	18	2.57	1.49	0.58	198	2.57	1.49	0.58	221	2.57	1.49	0.58	245	2.86	1.65	0.58	260	2.86	1.65	0.58	291	4.34	2.51	0.58	619	4.16	2.41	0.58	651	4.00	2.31	0.58	681	3.84	2.22	0.58	712	3.63	2.10	0.58	758	3.33	1.93	0.58	805	3.08	1.78	0.58	836	2.56	1.48	0.58	913
	22	20	2.70	1.24	0.46	238	2.70	1.24	0.46	261	2.70	1.24	0.46	285	3.00	1.38	0.46	300	3.00	1.38	0.46	331	4.57	2.09	0.46	652	4.37	2.00	0.46	685	4.20	1.93	0.46	717	4.04	1.85	0.46	750	3.81	1.75	0.46	798	3.50	1.60	0.46	848	3.24	1.48	0.46	880	2.69	1.23	0.46	958
	22	22	2.86	0.97	0.34	277	2.86	0.97	0.34	300	2.86	0.97	0.34	324	3.18	1.08	0.34	339	3.18	1.08	0.34	370	4.84	1.64	0.34	683	4.63	1.57	0.34	719	4.45	1.51	0.34	752	4.28	1.45	0.34	786	4.04	1.37	0.34	837	3.71	1.26	0.34	889	3.43	1.16	0.34	923	2.85	0.96	0.34	868
	23	18	2.57	1.59	0.62	198	2.57	1.59	0.62	221	2.57	1.59	0.62	245	2.86	1.77	0.62	260	2.86	1.77	0.62	291	4.34	2.69	0.62	619	4.16	2.57	0.62	651	4.00	2.47	0.62	681	3.84	2.38	0.62	712	3.63	2.24	0.62	758	3.33	2.06	0.62	805	3.08	1.91	0.62	836	2.56	1.58	0.62	913
	23	20	2.70	1.35	0.50	238	2.70	1.35	0.50	261	2.70	1.35	0.50	285	3.00	1.50	0.50	300	3.00	1.50	0.50	331	4.57	2.28	0.50	652	4.37	2.18	0.50	685	4.20	2.10	0.50	717	4.04	2.01	0.50	750	3.81	1.90	0.50	798	3.50	1.74	0.50	848	3.24	1.61	0.50	880	2.69	1.34	0.50	958
	23	22	2.86	1.08	0.38	277	2.86	1.08	0.38	300	2.86	1.08	0.38	324	3.18	1.20	0.38	339	3.18	1.20	0.38	370	4.84	1.83	0.38	683	4.63	1.75	0.38	719	4.45	1.69	0.38	752	4.28	1.62	0.38	786	4.04	1.53	0.38	837	3.71	1.40	0.38	889	3.43	1.30	0.38	923	2.85	1.08	0.38	868
	24	18	2.57	1.69	0.66	198	2.57	1.69	0.66	221	2.57	1.69	0.66	245	2.86	1.88	0.66	260	2.86	1.88	0.66	291	4.34	2.86	0.66	619	4.16	2.74	0.66	651	4.00	2.63	0.66	681	3.84	2.53	0.66	712	3.63	2.39	0.66	758	3.33	2.19	0.66	805	3.08	2.03	0.66	836	2.56	1.68	0.66	913
	24	20	2.70	1.46	0.54	238	2.70	1.46	0.54	261	2.70	1.46	0.54	285	3.00	1.62	0.54	300	3.00	1.62	0.54	331	4.57	2.46	0.54	652	4.37	2.35	0.54	685	4.20	2.26	0.54	717	4.04	2.18	0.54	750	3.81	2.05	0.54	798	3.50	1.88	0.54	848	3.24	1.74	0.54	880	2.69	1.45	0.54	958
	24	22	2.86	1.20	0.42	277	2.86	1.20	0.42	300	2.86	1.20	0.42	324	3.18	1.33	0.42	339	3.18	1.33	0.42	370	4.84	2.03	0.42	683	4.63	1.94	0.42	719	4.45	1.86	0.42	752	4.28	1.79	0.42	786	4.04	1.69	0.42	837	3.71	1.55	0.42	889	3.43	1.44	0.42	923	2.85	1.19	0.42	1004
	24	24	3.04	0.91	0.30	317	3.04	0.91	0.30	340	3.04	0.91	0.30	364	3.37	1.01	0.30	379	3.37	1.01	0.30	410	5.13	1.53	0.30	716	4.91	1.47	0.30	753	4.72	1.41	0.30	788	4.54	1.36	0.30	824	4.28	1.28	0.30	877	3.93	1.17	0.30	932	3.64	1.09	0.30	967	3.02	0.90	0.30	868
	25	18	2.57	1.80	0.70	198	2.57	1.80	0.70	221	2.57	1.80	0.70	245	2.86	2.00	0.70	260	2.86	2.00	0.70	291	4.34	3.04	0.70	619	4.16	2.90	0.70	651	4.00	2.79	0.70	681	3.84	2.69	0.70	712	3.63	2.53	0.70	758	3.33	2.33	0.70	805	3.08	2.15	0.70	836	2.56	1.79	0.70	913
	25	20	2.70	1.56	0.58	238	2.70	1.56	0.58	261	2.70	1.56	0.58	285	3.00	1.74	0.58	300	3.00	1.74	0.58	331	4.57	2.64	0.58	652	4.37	2.53	0.58	685	4.20	2.43	0.58	717	4.04	2.34	0.58	750	3.81	2.21	0.58	798	3.50	2.02	0.58	848	3.24	1.87	0.58	880	2.69	1.55	0.58	958
	25	22	2.86	1.31	0.46	277	2.86	1.31	0.46	300	2.86	1.31	0.46	324	3.18	1.46	0.46	339	3.18	1.46	0.46	370	4.84	2.22	0.46	683	4.63	2.12	0.46	719	4.45	2.04	0.46	752	4.28	1.96	0.46	786	4.04	1.85	0.46	837	3.71	1.70	0.46	889	3.43	1.57	0.46	923	2.85	1.31	0.46	1004
	25	24	3.04	1.03	0.34	317	3.04	1.03	0.34	340	3.04	1.03	0.34	364	3.37	1.14	0.34	379	3.37	1.14	0.34	410	5.13	1.74	0.34	716	4.91	1.66	0.34	753	4.72	1.60	0.34	788	4.54	1.54	0.34	824	4.28	1.45	0.34	877	3.93	1.33	0.34	932	3.64	1.23	0.34	967	3.02	1.02	0.34	868
	26	18	2.57	1.90	0.74	198	2.57	1.90	0.74	221	2.57	1.90	0.74	245	2.86	2.11	0.74	260	2.86	2.11	0.74	291	4.34	3.21	0.74	619	4.16	3.07	0.74	651	4.00	2.95	0.74	681	3.84	2.84	0.74	712	3.63	2.68	0.74	758	3.33	2.46	0.74	805	3.08	2.27	0.74	836	2.56	1.89	0.74	913
	26	20	2.70	1.67	0.62	238	2.70	1.67	0.62	261	2.70	1.67	0.62	285	3.00	1.86	0.62	300	3.00	1.86	0.62	331	4.57	2.83	0.62	652	4.37	2.70	0.62	685	4.20	2.60	0.62	717	4.04	2.50	0.62	750	3.81	2.36	0.62	798	3.50	2.16	0.62	848	3.24	2.00	0.62	880	2.69	1.66	0.62	958
	26	22	2.86	1.																																																		

4. CAPACITIES AND SELECTION DATA

14K (Up to 2 indoor units series)

HEATING PERFORMANCE DATA

COMBINATION (%)	INDOOR DB(°C)	OUTDOOR WB(°C)															
		-15		-10		-5		0		5		10		15		20	
		Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT
130%	15	3.25	889	3.83	917	4.25	926	4.67	945	5.08	994	5.49	1044	5.76	1075	5.93	1097
	16	3.21	896	3.78	924	4.20	933	4.62	952	5.02	1002	5.42	1053	5.69	1084	5.86	1106
	17	3.18	903	3.74	931	4.15	941	4.56	960	4.96	1011	5.36	1061	5.62	1093	5.79	1115
	18	3.14	911	3.69	939	4.10	948	4.51	968	4.90	1019	5.29	1070	5.56	1102	5.72	1124
	19	3.10	918	3.65	946	4.05	956	4.45	976	4.84	1027	5.23	1078	5.49	1111	5.66	1133
	20	3.07	925	3.61	954	4.01	964	4.41	983	4.79	1035	5.18	1087	5.44	1120	5.60	1142
	21	3.03	936	3.57	965	3.97	974	4.36	994	4.74	1047	5.12	1099	5.37	1132	5.53	1154
	22	3.00	946	3.53	975	3.92	985	4.31	1005	4.68	1058	5.05	1111	5.31	1144	5.47	1167
	23	2.96	956	3.48	986	3.87	996	4.25	1016	4.62	1070	4.99	1123	5.24	1157	5.40	1180
	24	2.93	967	3.44	997	3.82	1007	4.20	1027	4.57	1081	4.93	1136	5.18	1170	5.34	1193
	25	2.89	977	3.40	1008	3.78	1018	4.15	1039	4.51	1093	4.87	1148	5.12	1182	5.27	1206
	26	2.86	988	3.36	1019	3.73	1029	4.10	1050	4.46	1105	4.82	1161	5.06	1195	5.21	1219
	27	2.82	999	3.32	1030	3.69	1040	4.05	1062	4.41	1118	4.76	1173	5.00	1209	5.15	1233
	28	2.79	1010	3.28	1041	3.64	1052	4.00	1073	4.35	1130	4.70	1186	4.94	1222	5.08	1246
	29	2.75	1021	3.24	1053	3.60	1063	3.96	1085	4.30	1142	4.64	1199	4.88	1235	5.02	1260
	30	2.72	1032	3.20	1064	3.56	1075	3.91	1097	4.25	1155	4.59	1213	4.82	1249	4.96	1274
120%	15	3.16	847	3.72	873	4.13	882	4.54	900	4.93	947	5.33	994	5.59	1024	5.76	1045
	16	3.12	854	3.67	880	4.08	889	4.48	907	4.87	955	5.26	1002	5.53	1032	5.69	1053
	17	3.08	860	3.63	887	4.03	896	4.43	914	4.81	962	5.20	1011	5.46	1041	5.62	1062
	18	3.05	867	3.58	894	3.98	903	4.38	922	4.76	970	5.14	1019	5.40	1049	5.56	1070
	19	3.01	874	3.54	901	3.94	910	4.33	929	4.70	978	5.08	1027	5.33	1058	5.49	1079
	20	2.98	881	3.51	909	3.90	918	4.28	937	4.65	986	5.03	1035	5.28	1066	5.44	1088
	21	2.95	891	3.47	919	3.85	928	4.23	947	4.60	997	4.97	1047	5.22	1078	5.37	1099
	22	2.91	901	3.42	929	3.80	938	4.18	957	4.54	1008	4.91	1058	5.15	1090	5.31	1112
	23	2.88	911	3.38	939	3.76	948	4.13	968	4.49	1019	4.85	1070	5.09	1102	5.24	1124
	24	2.84	921	3.34	949	3.71	959	4.08	978	4.44	1030	4.79	1081	5.03	1114	5.18	1136
	25	2.81	931	3.30	960	3.67	969	4.03	989	4.38	1041	4.73	1093	4.97	1126	5.12	1149
	26	2.77	941	3.26	970	3.62	980	3.98	1000	4.33	1053	4.68	1105	4.91	1139	5.06	1161
	27	2.74	952	3.22	981	3.58	991	3.94	1011	4.28	1064	4.62	1118	4.85	1151	5.00	1174
	28	2.71	962	3.18	992	3.54	1002	3.89	1022	4.23	1076	4.56	1130	4.79	1164	4.94	1187
	29	2.67	973	3.15	1003	3.50	1013	3.84	1033	4.18	1088	4.51	1142	4.73	1177	4.88	1200
	30	2.64	983	3.11	1014	3.45	1024	3.80	1045	4.13	1100	4.46	1155	4.68	1189	4.82	1213
110%	15	3.07	830	3.61	856	4.01	864	4.40	882	4.79	928	5.17	975	5.43	1004	5.59	1024
	16	3.03	837	3.56	863	3.96	871	4.35	889	4.73	936	5.11	983	5.36	1012	5.53	1032
	17	2.99	844	3.52	870	3.91	878	4.30	896	4.67	944	5.05	991	5.30	1020	5.46	1041
	18	2.96	850	3.48	877	3.87	885	4.25	904	4.62	951	4.99	999	5.24	1029	5.40	1049
	19	2.92	857	3.44	884	3.82	893	4.20	911	4.56	959	4.93	1007	5.18	1037	5.33	1058
	20	2.89	864	3.41	891	3.78	900	4.16	918	4.52	967	4.88	1015	5.12	1045	5.28	1066
	21	2.86	874	3.36	901	3.74	910	4.11	928	4.46	977	4.82	1026	5.06	1057	5.22	1078
	22	2.83	883	3.32	911	3.69	920	4.06	939	4.41	988	4.76	1037	5.00	1068	5.15	1090
	23	2.79	893	3.28	921	3.65	930	4.01	949	4.36	999	4.71	1049	4.94	1080	5.09	1102
	24	2.76	903	3.24	931	3.61	940	3.96	959	4.31	1010	4.65	1060	4.88	1092	5.03	1114
	25	2.72	913	3.21	941	3.56	950	3.91	970	4.25	1021	4.59	1072	4.82	1104	4.97	1126
	26	2.69	923	3.17	951	3.52	961	3.87	980	4.20	1032	4.54	1084	4.77	1116	4.91	1139
	27	2.66	933	3.13	962	3.48	971	3.82	991	4.15	1043	4.49	1096	4.71	1128	4.85	1151
	28	2.63	943	3.09	972	3.44	982	3.77	1002	4.10	1055	4.43	1108	4.65	1141	4.79	1164
	29	2.60	954	3.05	983	3.39	993	3.73	1013	4.05	1067	4.38	1120	4.60	1153	4.73	1177
	30	2.57	964	3.02	994	3.35	1004	3.68	1024	4.01	1078	4.33	1132	4.54	1166	4.68	1189

4. CAPACITIES AND SELECTION DATA

COMBINATION (%)	INDOOR DB(°C)	OUTDOOR WB(°C)															
		-15		-10		-5		0		5		10		15		20	
		Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT
100%	15	2.98	806	3.50	831	3.89	839	4.28	856	4.65	901	5.02	947	5.27	975	5.43	994
	16	2.94	812	3.46	838	3.85	846	4.23	863	4.59	909	4.96	954	5.21	983	5.36	1002
	17	2.91	819	3.42	844	3.80	853	4.18	870	4.54	916	4.90	962	5.15	991	5.30	1011
	18	2.87	826	3.38	851	3.75	860	4.13	877	4.48	923	4.84	970	5.09	999	5.24	1019
	19	2.84	832	3.34	858	3.71	867	4.08	884	4.43	931	4.79	977	5.03	1007	5.18	1027
	20	2.81	839	3.31	865	3.67	874	4.04	891	4.39	938	4.74	985	4.98	1015	5.12	1035
	21	2.78	848	3.27	874	3.63	883	3.99	901	4.33	949	4.68	996	4.92	1026	5.06	1047
	22	2.74	857	3.23	884	3.59	893	3.94	911	4.28	959	4.63	1007	4.86	1037	5.00	1058
	23	2.71	867	3.19	894	3.54	903	3.89	921	4.23	970	4.57	1018	4.80	1049	4.94	1070
	24	2.68	876	3.15	904	3.50	913	3.85	931	4.18	980	4.52	1029	4.74	1060	4.88	1081
	25	2.65	886	3.11	914	3.46	923	3.80	942	4.13	991	4.46	1041	4.68	1072	4.82	1093
	26	2.61	896	3.07	924	3.42	933	3.75	952	4.08	1002	4.41	1052	4.63	1084	4.77	1105
	27	2.58	906	3.04	934	3.38	943	3.71	962	4.03	1013	4.35	1064	4.57	1096	4.71	1118
	28	2.55	916	3.00	944	3.34	954	3.66	973	3.98	1024	4.30	1075	4.52	1108	4.65	1130
	29	2.52	926	2.97	954	3.30	964	3.62	984	3.94	1035	4.25	1087	4.46	1120	4.60	1142
	30	2.49	936	2.93	965	3.26	975	3.58	995	3.89	1047	4.20	1099	4.41	1132	4.54	1155
COMBINATION (%)	INDOOR DB(°C)	OUTDOOR WB(°C)															
		-15		-10		-5		0		5		10		15		20	
		Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT
90%	15	2.87	791	3.38	816	3.76	824	4.13	841	4.49	885	4.84	929	5.09	957	5.24	976
	16	2.84	798	3.34	822	3.71	831	4.08	848	4.43	892	4.79	937	5.03	965	5.18	984
	17	2.80	804	3.30	829	3.67	837	4.03	855	4.38	900	4.73	945	4.97	973	5.12	992
	18	2.77	811	3.26	836	3.62	844	3.98	861	4.33	907	4.67	952	4.91	981	5.05	1000
	19	2.74	817	3.22	843	3.58	851	3.93	868	4.28	914	4.62	960	4.85	989	4.99	1008
	20	2.71	824	3.19	849	3.54	858	3.90	875	4.23	921	4.57	968	4.80	997	4.95	1017
	21	2.68	833	3.15	859	3.50	867	3.85	885	4.18	932	4.52	978	4.74	1008	4.89	1028
	22	2.65	842	3.11	868	3.46	877	3.80	895	4.13	942	4.46	989	4.69	1019	4.83	1039
	23	2.62	851	3.08	878	3.42	887	3.76	905	4.08	952	4.41	1000	4.63	1030	4.77	1050
	24	2.58	861	3.04	887	3.38	896	3.71	915	4.03	963	4.36	1011	4.57	1041	4.71	1062
	25	2.55	870	3.00	897	3.34	906	3.67	925	3.99	973	4.30	1022	4.52	1053	4.66	1074
	26	2.52	880	2.97	907	3.30	916	3.62	935	3.94	984	4.25	1033	4.47	1064	4.60	1085
	27	2.49	889	2.93	917	3.26	926	3.58	945	3.89	995	4.20	1045	4.41	1076	4.54	1097
	28	2.46	899	2.90	927	3.22	936	3.54	955	3.84	1006	4.15	1056	4.36	1088	4.49	1109
	29	2.43	909	2.86	937	3.18	947	3.49	966	3.80	1017	4.10	1068	4.31	1100	4.44	1122
	30	2.40	919	2.83	948	3.14	957	3.45	977	3.75	1028	4.05	1079	4.26	1112	4.38	1134
COMBINATION (%)	INDOOR DB(°C)	OUTDOOR WB(°C)															
		-15		-10		-5		0		5		10		15		20	
		Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT
80%	15	2.79	783	3.28	808	3.64	816	4.00	833	4.35	876	4.70	920	4.93	948	5.08	967
	16	2.75	790	3.24	814	3.60	822	3.96	839	4.30	883	4.64	928	4.88	955	5.02	975
	17	2.72	796	3.20	821	3.56	829	3.91	846	4.25	891	4.59	935	4.82	963	4.96	982
	18	2.69	803	3.16	827	3.51	836	3.86	853	4.20	898	4.53	943	4.76	971	4.90	990
	19	2.66	809	3.13	834	3.47	843	3.82	860	4.15	905	4.48	950	4.70	979	4.84	998
	20	2.63	816	3.09	841	3.44	849	3.78	867	4.11	912	4.44	958	4.66	987	4.80	1006
	21	2.60	825	3.06	850	3.40	859	3.73	876	4.06	922	4.38	968	4.60	997	4.74	1017
	22	2.57	834	3.02	859	3.36	868	3.69	886	4.01	932	4.33	979	4.55	1008	4.68	1029
	23	2.54	843	2.98	869	3.32	878	3.64	896	3.96	943	4.28	990	4.49	1020	4.63	1040
	24	2.51	852	2.95	878	3.28	887	3.60	905	3.91	953	4.23	1001	4.44	1031	4.57	1051
	25	2.48	861	2.91	888	3.24	897	3.56	915	3.87	964	4.18	1012	4.38	1042	4.52	1063
	26	2.45	871	2.88	898	3.20	907	3.51	925	3.82	974	4.13	1023	4.33	1054	4.46	1075
	27	2.42	881	2.84	908	3.16	917	3.47	936	3.77	985	4.08	1034	4.28	1065	4.41	1086
	28	2.39	890	2.81	918	3.12	927	3.43	946	3.73	996	4.03	1045	4.23	1077	4.36	1098
	29	2.36	900	2.78	928	3.08	937	3.39	956	3.68	1007	3.98	1057	4.18	1089	4.30	1110
	30	2.33	910	2.74	938	3.05	948	3.35	967	3.64	1018	3.93	1069	4.13	1101	4.25	1123

Remarks:
 Q: Total Cooling Capacity (Gross) **kW**
 INPUT: Power Input (including the compressor, evap. fan motor & cond. **W**
 DB: Dry Bulb Temperature
 WB: Wet Bulb Temperature

2AMW52U4RXC

-

UE MULTI 2 POSTES 5,2 KW

4. CAPACITIES AND SELECTION DATA

18K(Up to 2 indoor units series)

	Cooling Operation PERFORMANCE DATA																																																					
	OUTDOOR DB (°C)																																																					
COMBINATION (%)	IDDB (°C)	ID WB (°C)	-15				-7				0				10				15				21				25				27				30				35				40				45				50			
			Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT								
130%	21	18	3.80	2.19	0.58	385	3.80	2.19	0.58	429	3.80	2.19	0.58	472	4.22	2.43	0.58	501	4.22	2.43	0.58	559	6.41	3.69	0.58	1166	6.14	3.54	0.58	1226	5.90	3.40	0.58	1282	5.68	3.27	0.58	1341	5.35	3.08	0.58	1428	4.92	2.83	0.58	1517	4.55	2.62	0.58	1574	3.77	2.17	0.58	1634
	21	20	3.99	1.82	0.46	425	3.99	1.82	0.46	469	3.99	1.82	0.46	512	4.43	2.02	0.46	541	4.43	2.02	0.46	599	6.74	3.07	0.46	1198	6.45	2.94	0.46	1260	6.20	2.83	0.46	1318	5.97	2.72	0.46	1379	5.63	2.57	0.46	1468	5.17	2.36	0.46	1559	4.78	2.18	0.46	1618	3.97	1.81	0.46	1680
	22	18	3.80	2.34	0.62	385	3.80	2.34	0.62	429	3.80	2.34	0.62	472	4.22	2.60	0.62	501	4.22	2.60	0.62	559	6.41	3.95	0.62	1166	6.14	3.78	0.62	1226	5.90	3.64	0.62	1282	5.68	3.50	0.62	1341	5.35	3.30	0.62	1428	4.92	3.03	0.62	1517	4.55	2.80	0.62	1574	3.77	2.32	0.62	1634
	22	20	3.99	1.98	0.50	425	3.99	1.98	0.50	469	3.99	1.98	0.50	512	4.43	2.20	0.50	541	4.43	2.20	0.50	599	6.74	3.34	0.50	1198	6.45	3.20	0.50	1260	6.20	3.08	0.50	1318	5.97	2.96	0.50	1379	5.63	2.79	0.50	1468	5.17	2.56	0.50	1559	4.78	2.37	0.50	1618	3.97	1.97	0.50	1680
	22	22	4.23	1.59	0.38	464	4.23	1.59	0.38	508	4.23	1.59	0.38	551	4.70	1.77	0.38	580	4.70	1.77	0.38	638	7.15	2.69	0.38	1230	6.84	2.57	0.38	1293	6.58	2.47	0.38	1353	6.32	2.38	0.38	1415	5.97	2.24	0.38	1507	5.48	2.06	0.38	1601	5.07	1.90	0.38	1661	4.20	1.58	0.38	1725
	23	18	3.80	2.49	0.66	385	3.80	2.49	0.66	429	3.80	2.49	0.66	472	4.22	2.77	0.66	501	4.22	2.77	0.66	559	6.41	4.21	0.66	1166	6.14	4.03	0.66	1226	5.90	3.87	0.66	1282	5.68	3.72	0.66	1341	5.35	3.51	0.66	1428	4.92	3.22	0.66	1517	4.55	2.98	0.66	1574	3.77	2.48	0.66	1634
	23	20	3.99	2.14	0.54	425	3.99	2.14	0.54	469	3.99	2.14	0.54	512	4.43	2.38	0.54	541	4.43	2.38	0.54	599	6.74	3.61	0.54	1198	6.45	3.46	0.54	1260	6.20	3.32	0.54	1318	5.97	3.20	0.54	1379	5.63	3.02	0.54	1468	5.17	2.77	0.54	1559	4.78	2.56	0.54	1618	3.97	2.13	0.54	1680
	23	22	4.23	1.76	0.42	464	4.23	1.76	0.42	508	4.23	1.76	0.42	551	4.70	1.95	0.42	580	4.70	1.95	0.42	638	7.15	2.97	0.42	1230	6.84	2.84	0.42	1293	6.58	2.74	0.42	1353	6.32	2.63	0.42	1415	5.97	2.48	0.42	1507	5.48	2.28	0.42	1601	5.07	2.11	0.42	1661	4.20	1.75	0.42	1725
	24	18	3.80	2.64	0.70	385	3.80	2.64	0.70	429	3.80	2.64	0.70	472	4.22	2.93	0.70	501	4.22	2.93	0.70	559	6.41	4.46	0.70	1166	6.14	4.27	0.70	1226	5.90	4.11	0.70	1282	5.68	3.95	0.70	1341	5.35	3.73	0.70	1428	4.92	3.42	0.70	1517	4.55	3.16	0.70	1574	3.77	2.63	0.70	1634
	24	20	3.99	2.30	0.58	425	3.99	2.30	0.58	469	3.99	2.30	0.58	512	4.43	2.55	0.58	541	4.43	2.55	0.58	599	6.74	3.88	0.58	1198	6.45	3.72	0.58	1260	6.20	3.57	0.58	1318	5.97	3.44	0.58	1379	5.63	3.24	0.58	1468	5.17	2.98	0.58	1559	4.78	2.75	0.58	1618	3.97	2.28	0.58	1680
	24	22	4.23	1.93	0.46	464	4.23	1.93	0.46	508	4.23	1.93	0.46	551	4.70	2.14	0.46	580	4.70	2.14	0.46	638	7.15	3.26	0.46	1230	6.84	3.12	0.46	1293	6.58	3.00	0.46	1353	6.32	2.88	0.46	1415	5.97	2.72	0.46	1507	5.48	2.50	0.46	1601	5.07	2.31	0.46	1661	4.20	1.92	0.46	1725
	24	24	4.48	1.51	0.34	504	4.48	1.51	0.34	548	4.48	1.51	0.34	591	4.98	1.67	0.34	620	4.98	1.67	0.34	678	7.58	2.54	0.34	1263	7.25	2.44	0.34	1328	6.97	2.34	0.34	1389	6.70	2.25	0.34	1453	6.32	2.12	0.34	1547	5.80	1.95	0.34	1643	5.37	1.80	0.34	1705	4.46	1.50	0.34	1770
	25	18	3.80	2.79	0.74	385	3.80	2.79	0.74	429	3.80	2.79	0.74	472	4.22	3.10	0.74	501	4.22	3.10	0.74	559	6.41	4.72	0.74	1166	6.14	4.52	0.74	1226	5.90	4.34	0.74	1282	5.68	4.18	0.74	1341	5.35	3.94	0.74	1428	4.92	3.62	0.74	1517	4.55	3.35	0.74	1574	3.77	2.78	0.74	1634
	25	20	3.99	2.46	0.62	425	3.99	2.46	0.62	469	3.99	2.46	0.62	512	4.43	2.73	0.62	541	4.43	2.73	0.62	599	6.74	4.15	0.62	1198	6.45	3.97	0.62	1260	6.20	3.82	0.62	1318	5.97	3.67	0.62	1379	5.63	3.47	0.62	1468	5.17	3.18	0.62	1559	4.78	2.94	0.62	1618	3.97	2.44	0.62	1680
	25	22	4.23	2.10	0.50	464	4.23	2.10	0.50	508	4.23	2.10	0.50	551	4.70	2.33	0.50	580	4.70	2.33	0.50	638	7.15	3.54	0.50	1230	6.84	3.39	0.50	1293	6.58	3.26	0.50	1353	6.32	3.14	0.50	1415	5.97	2.96	0.50	1507	5.48	2.72	0.50	1601	5.07	2.51	0.50	1661	4.20	2.08	0.50	1725
	25	24	4.48	1.69	0.38	504	4.48	1.69	0.38	548	4.48	1.69	0.38	591	4.98	1.87	0.38	620	4.98	1.87	0.38	678	7.58	2.85	0.38	1263	7.25	2.73	0.38	1328	6.97	2.62	0.38	1389	6.70	2.52	0.38	1453	6.32	2.38	0.38	1547	5.80	2.18	0.38	1643	5.37	2.02	0.38	1705	4.46	1.68	0.38	1770
	26	18	3.80	2.95	0.78	385	3.80	2.95	0.78	429	3.80	2.95	0.78	472	4.22	3.27	0.78	501	4.22	3.27	0.78	559	6.41	4.98	0.78	1166	6.14	4.76	0.78	1226	5.90	4.58	0.78	1282	5.68	4.40	0.78	1341	5.35	4.15	0.78	1428	4.92	3.81	0.78	1517	4.55	3.53	0.78	1574	3.77	2.93	0.78	1634
	26	20	3.99	2.62	0.66	425	3.99	2.62	0.66	469	3.99	2.62	0.66	512	4.43	2.91	0.66	541	4.43	2.91	0.66	599	6.74	4.42	0.66	1198	6.45	4.23	0.66	1260	6.20	4.07	0.66	1318	5.97	3.91	0.66	1379	5.63	3.69	0.66	1468	5.17	3.39	0.66	1559	4.78	3.13	0.6					

4. CAPACITIES AND SELECTION DATA

				Cooling Operation PERFORMANCE DATA																																																		
				OUTDOOR DB (°C)																																																		
COMBINATION (%)	IDDB (°C)	ID WB (°C)	-15				-7				0				10				15				21				25				27				30				35				40				45				50			
			Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT								
120%	21	18	3.69	2.21	0.60	366	3.69	2.21	0.60	408	3.69	2.21	0.60	449	4.09	2.45	0.60	477	4.09	2.45	0.60	532	6.23	3.73	0.60	1109	5.96	3.57	0.60	1166	5.73	3.43	0.60	1220	5.51	3.30	0.60	1276	5.20	3.12	0.60	1359	4.77	2.86	0.60	1443	4.41	2.65	0.60	1498	3.66	2.20	0.60	1555
	21	20	3.87	1.86	0.48	406	3.87	1.86	0.48	448	3.87	1.86	0.48	489	4.30	2.06	0.48	517	4.30	2.06	0.48	572	6.55	3.14	0.48	1142	6.26	3.00	0.48	1201	6.02	2.89	0.48	1256	5.79	2.78	0.48	1314	5.46	2.62	0.48	1399	5.02	2.40	0.48	1486	4.64	2.22	0.48	1542	3.85	1.85	0.48	1601
	22	18	3.69	2.36	0.64	366	3.69	2.36	0.64	408	3.69	2.36	0.64	449	4.09	2.62	0.64	477	4.09	2.62	0.64	532	6.23	3.98	0.64	1109	5.96	3.81	0.64	1166	5.73	3.66	0.64	1220	5.51	3.52	0.64	1276	5.20	3.32	0.64	1359	4.77	3.05	0.64	1443	4.41	2.82	0.64	1498	3.66	2.34	0.64	1555
	22	20	3.87	2.01	0.52	406	3.87	2.01	0.52	448	3.87	2.01	0.52	489	4.30	2.23	0.52	517	4.30	2.23	0.52	572	6.55	3.40	0.52	1142	6.26	3.25	0.52	1201	6.02	3.13	0.52	1256	5.79	3.01	0.52	1314	5.46	2.84	0.52	1399	5.02	2.60	0.52	1486	4.64	2.41	0.52	1542	3.85	2.00	0.52	1601
	22	22	4.11	1.64	0.40	445	4.11	1.64	0.40	487	4.11	1.64	0.40	528	4.56	1.82	0.40	556	4.56	1.82	0.40	611	6.94	2.77	0.40	1174	6.64	2.65	0.40	1234	6.38	2.55	0.40	1291	6.14	2.45	0.40	1350	5.79	2.31	0.40	1438	5.32	2.12	0.40	1527	4.92	1.96	0.40	1585	4.08	1.63	0.40	1646
	23	18	3.69	2.50	0.68	366	3.69	2.50	0.68	408	3.69	2.50	0.68	449	4.09	2.78	0.68	477	4.09	2.78	0.68	532	6.23	4.23	0.68	1109	5.96	4.05	0.68	1166	5.73	3.89	0.68	1220	5.51	3.74	0.68	1276	5.20	3.53	0.68	1359	4.77	3.24	0.68	1443	4.41	3.00	0.68	1498	3.66	2.49	0.68	1555
	23	20	3.87	2.17	0.56	406	3.87	2.17	0.56	448	3.87	2.17	0.56	489	4.30	2.41	0.56	517	4.30	2.41	0.56	572	6.55	3.66	0.56	1142	6.26	3.50	0.56	1201	6.02	3.37	0.56	1256	5.79	3.24	0.56	1314	5.46	3.06	0.56	1399	5.02	2.81	0.56	1486	4.64	2.59	0.56	1542	3.85	2.15	0.56	1601
	23	22	4.11	1.80	0.44	445	4.11	1.80	0.44	487	4.11	1.80	0.44	528	4.56	2.00	0.44	556	4.56	2.00	0.44	611	6.94	3.05	0.44	1174	6.64	2.92	0.44	1234	6.38	2.80	0.44	1291	6.14	2.70	0.44	1350	5.79	2.54	0.44	1438	5.32	2.34	0.44	1527	4.92	2.16	0.44	1585	4.08	1.79	0.44	1646
	24	18	3.69	2.65	0.72	366	3.69	2.65	0.72	408	3.69	2.65	0.72	449	4.09	2.94	0.72	477	4.09	2.94	0.72	532	6.23	4.48	0.72	1109	5.96	4.29	0.72	1166	5.73	4.12	0.72	1220	5.51	3.96	0.72	1276	5.20	3.74	0.72	1359	4.77	3.43	0.72	1443	4.41	3.18	0.72	1498	3.66	2.64	0.72	1555
	24	20	3.87	2.32	0.60	406	3.87	2.32	0.60	448	3.87	2.32	0.60	489	4.30	2.58	0.60	517	4.30	2.58	0.60	572	6.55	3.92	0.60	1142	6.26	3.75	0.60	1201	6.02	3.61	0.60	1256	5.79	3.47	0.60	1314	5.46	3.27	0.60	1399	5.02	3.01	0.60	1486	4.64	2.78	0.60	1542	3.85	2.31	0.60	1601
	24	22	4.11	1.97	0.48	445	4.11	1.97	0.48	487	4.11	1.97	0.48	528	4.56	2.19	0.48	556	4.56	2.19	0.48	611	6.94	3.33	0.48	1174	6.64	3.18	0.48	1234	6.38	3.06	0.48	1291	6.14	2.94	0.48	1350	5.79	2.78	0.48	1438	5.32	2.55	0.48	1527	4.92	2.36	0.48	1585	4.08	1.96	0.48	1646
	24	24	4.35	1.56	0.36	485	4.35	1.56	0.36	527	4.35	1.56	0.36	568	4.83	1.74	0.36	596	4.83	1.74	0.36	651	7.35	2.64	0.36	1206	7.04	2.53	0.36	1269	6.77	2.43	0.36	1327	6.51	2.34	0.36	1388	6.14	2.21	0.36	1478	5.64	2.02	0.36	1570	5.21	1.87	0.36	1629	4.33	1.55	0.36	1691
	25	18	3.69	2.80	0.76	366	3.69	2.80	0.76	408	3.69	2.80	0.76	449	4.09	3.11	0.76	477	4.09	3.11	0.76	532	6.23	4.73	0.76	1109	5.96	4.53	0.76	1166	5.73	4.35	0.76	1220	5.51	4.18	0.76	1276	5.20	3.95	0.76	1359	4.77	3.62	0.76	1443	4.41	3.35	0.76	1498	3.66	2.78	0.76	1555
	25	20	3.87	2.48	0.64	406	3.87	2.48	0.64	448	3.87	2.48	0.64	489	4.30	2.75	0.64	517	4.30	2.75	0.64	572	6.55	4.18	0.64	1142	6.26	4.00	0.64	1201	6.02	3.85	0.64	1256	5.79	3.70	0.64	1314	5.46	3.49	0.64	1399	5.02	3.21	0.64	1486	4.64	2.97	0.64	1542	3.85	2.46	0.64	1601
	25	22	4.11	2.13	0.52	445	4.11	2.13	0.52	487	4.11	2.13	0.52	528	4.56	2.37	0.52	556	4.56	2.37	0.52	611	6.94	3.60	0.52	1174	6.64	3.45	0.52	1234	6.38	3.32	0.52	1291	6.14	3.19	0.52	1350	5.79	3.01	0.52	1438	5.32	2.76	0.52	1527	4.92	2.55	0.52	1585	4.08	2.12	0.52	1646
	25	24	4.35	1.74	0.40	485	4.35	1.74	0.40	527	4.35	1.74	0.40	568	4.83	1.93	0.40	596	4.83	1.93	0.40	651	7.35	2.94	0.40	1206	7.04	2.81	0.40	1269	6.77	2.70	0.40	1327	6.51	2.60	0.40	1388	6.14	2.45	0.40	1478	5.64	2.25	0.40	1570	5.21	2.08	0.40	1629	4.33	1.73	0.40	1691
	26	18	3.69	2.95	0.80	366	3.69	2.95	0.80	408	3.69	2.95	0.80	449	4.09	3.27	0.80	477	4.09	3.27	0.80	532	6.23	4.98	0.80	1109	5.96	4.76	0.80	1166	5.73	4.58	0.80	1220	5.51	4.40	0.80	1276	5.20	4.16	0.80	1359	4.77	3.81	0.80	1443	4.41	3.53	0.80	1498	3.66	2.93	0.80	1555
	26	20	3.87	2.63	0.68	406	3.87	2.63	0.68	448	3.87	2.63	0.68	489	4.30	2.92	0.68	517	4.30	2.92	0.68	572	6.55	4.45	0.68	1142	6.26	4.26	0.68	1201	6.02	4.09	0.68	1256	5.79	3.93	0.68	1314	5.46	3.71	0.68	139												

4. CAPACITIES AND SELECTION DATA

	Cooling Operation PERFORMANCE DATA																																																					
	OUTDOOR DB (°C)																																																					
COMBINATION (%)	IDDB (°C)	ID WB (°C)	-15				-7				0				10				15				21				25				27				30				35				40				45				50			
			Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT												
110%	21	18	3.58	2.23	0.62	355	3.58	2.23	0.62	395	3.58	2.23	0.62	435	3.97	2.48	0.62	462	3.97	2.48	0.62	516	6.05	3.77	0.62	1076	5.79	3.61	0.62	1132	5.56	3.47	0.62	1184	5.35	3.34	0.62	1239	5.05	3.15	0.62	1319	4.63	2.89	0.62	1401	4.29	2.67	0.62	1454	3.56	2.22	0.62	1509
	21	20	3.76	1.89	0.50	395	3.76	1.89	0.50	435	3.76	1.89	0.50	475	4.18	2.10	0.50	502	4.18	2.10	0.50	556	6.36	3.20	0.50	1109	6.08	3.06	0.50	1166	5.85	2.94	0.50	1220	5.62	2.83	0.50	1276	5.30	2.67	0.50	1359	4.87	2.45	0.50	1443	4.50	2.27	0.50	1498	3.74	1.88	0.50	1555
	22	18	3.58	2.37	0.66	355	3.58	2.37	0.66	395	3.58	2.37	0.66	435	3.97	2.64	0.66	462	3.97	2.64	0.66	516	6.05	4.01	0.66	1076	5.79	3.84	0.66	1132	5.56	3.69	0.66	1184	5.35	3.55	0.66	1239	5.05	3.35	0.66	1319	4.63	3.07	0.66	1401	4.29	2.84	0.66	1454	3.56	2.36	0.66	1509
	22	20	3.76	2.04	0.54	395	3.76	2.04	0.54	435	3.76	2.04	0.54	475	4.18	2.27	0.54	502	4.18	2.27	0.54	556	6.36	3.45	0.54	1109	6.08	3.30	0.54	1166	5.85	3.18	0.54	1220	5.62	3.06	0.54	1276	5.30	2.88	0.54	1359	4.87	2.65	0.54	1443	4.50	2.45	0.54	1498	3.74	2.03	0.54	1555
	22	22	3.99	1.69	0.42	434	3.99	1.69	0.42	474	3.99	1.69	0.42	514	4.43	1.87	0.42	541	4.43	1.87	0.42	595	6.74	2.85	0.42	1141	6.45	2.73	0.42	1200	6.20	2.62	0.42	1255	5.96	2.52	0.42	1313	5.62	2.38	0.42	1398	5.16	2.19	0.42	1485	4.77	2.02	0.42	1541	3.96	1.68	0.42	1600
	23	18	3.58	2.52	0.70	355	3.58	2.52	0.70	395	3.58	2.52	0.70	435	3.97	2.80	0.70	462	3.97	2.80	0.70	516	6.05	4.25	0.70	1076	5.79	4.07	0.70	1132	5.56	3.91	0.70	1184	5.35	3.76	0.70	1239	5.05	3.55	0.70	1319	4.63	3.26	0.70	1401	4.29	3.01	0.70	1454	3.56	2.50	0.70	1509
	23	20	3.76	2.19	0.58	395	3.76	2.19	0.58	435	3.76	2.19	0.58	475	4.18	2.44	0.58	502	4.18	2.44	0.58	556	6.36	3.71	0.58	1109	6.08	3.55	0.58	1166	5.85	3.41	0.58	1220	5.62	3.28	0.58	1276	5.30	3.09	0.58	1359	4.87	2.84	0.58	1443	4.50	2.63	0.58	1498	3.74	2.18	0.58	1555
	23	22	3.99	1.85	0.46	434	3.99	1.85	0.46	474	3.99	1.85	0.46	514	4.43	2.05	0.46	541	4.43	2.05	0.46	595	6.74	3.12	0.46	1141	6.45	2.99	0.46	1200	6.20	2.87	0.46	1255	5.96	2.76	0.46	1313	5.62	2.61	0.46	1398	5.16	2.39	0.46	1485	4.77	2.21	0.46	1541	3.96	1.84	0.46	1600
	24	18	3.58	2.66	0.74	355	3.58	2.66	0.74	395	3.58	2.66	0.74	435	3.97	2.95	0.74	462	3.97	2.95	0.74	516	6.05	4.50	0.74	1076	5.79	4.30	0.74	1132	5.56	4.14	0.74	1184	5.35	3.98	0.74	1239	5.05	3.75	0.74	1319	4.63	3.44	0.74	1401	4.29	3.19	0.74	1454	3.56	2.64	0.74	1509
	24	20	3.76	2.34	0.62	395	3.76	2.34	0.62	435	3.76	2.34	0.62	475	4.18	2.60	0.62	502	4.18	2.60	0.62	556	6.36	3.96	0.62	1109	6.08	3.79	0.62	1166	5.85	3.65	0.62	1220	5.62	3.51	0.62	1276	5.30	3.31	0.62	1359	4.87	3.04	0.62	1443	4.50	2.81	0.62	1498	3.74	2.33	0.62	1555
	24	22	3.99	2.01	0.50	434	3.99	2.01	0.50	474	3.99	2.01	0.50	514	4.43	2.23	0.50	541	4.43	2.23	0.50	595	6.74	3.39	0.50	1141	6.45	3.25	0.50	1200	6.20	3.12	0.50	1255	5.96	3.00	0.50	1313	5.62	2.83	0.50	1398	5.16	2.60	0.50	1485	4.77	2.40	0.50	1541	3.96	1.99	0.50	1600
	24	24	4.23	1.62	0.38	474	4.23	1.62	0.38	514	4.23	1.62	0.38	554	4.69	1.80	0.38	581	4.69	1.80	0.38	635	7.14	2.74	0.38	1174	6.83	2.62	0.38	1234	6.57	2.52	0.38	1291	6.32	2.42	0.38	1350	5.96	2.29	0.38	1438	5.47	2.10	0.38	1527	5.06	1.94	0.38	1585	4.20	1.61	0.38	1645
	25	18	3.58	2.80	0.78	355	3.58	2.80	0.78	395	3.58	2.80	0.78	435	3.97	3.11	0.78	462	3.97	3.11	0.78	516	6.05	4.74	0.78	1076	5.79	4.53	0.78	1132	5.56	4.36	0.78	1184	5.35	4.19	0.78	1239	5.05	3.95	0.78	1319	4.63	3.63	0.78	1401	4.29	3.36	0.78	1454	3.56	2.79	0.78	1509
	25	20	3.76	2.49	0.66	395	3.76	2.49	0.66	435	3.76	2.49	0.66	475	4.18	2.77	0.66	502	4.18	2.77	0.66	556	6.36	4.22	0.66	1109	6.08	4.03	0.66	1166	5.85	3.88	0.66	1220	5.62	3.73	0.66	1276	5.30	3.52	0.66	1359	4.87	3.23	0.66	1443	4.50	2.99	0.66	1498	3.74	2.48	0.66	1555
	25	22	3.99	2.17	0.54	434	3.99	2.17	0.54	474	3.99	2.17	0.54	514	4.43	2.41	0.54	541	4.43	2.41	0.54	595	6.74	3.66	0.54	1141	6.45	3.50	0.54	1200	6.20	3.37	0.54	1255	5.96	3.24	0.54	1313	5.62	3.06	0.54	1398	5.16	2.80	0.54	1485	4.77	2.59	0.54	1541	3.96	2.15	0.54	1600
	25	24	4.23	1.79	0.42	474	4.23	1.79	0.42	514	4.23	1.79	0.42	554	4.69	1.99	0.42	581	4.69	1.99	0.42	635	7.14	3.02	0.42	1174	6.83	2.89	0.42	1234	6.57	2.78	0.42	1291	6.32	2.67	0.42	1350	5.96	2.52	0.42	1438	5.47	2.32	0.42	1527	5.06	2.14	0.42	1585	4.20	1.78	0.42	1645
	26	18	3.58	2.95	0.82	355	3.58	2.95	0.82	395	3.58	2.95	0.82	435	3.97	3.27	0.82	462	3.97	3.27	0.82	516	6.05	4.98	0.82	1076	5.79	4.76	0.82	1132	5.56	4.58	0.82	1184	5.35	4.41	0.82	1239	5.05	4.16	0.82	1319	4.63	3.81	0.82	1401	4.29	3.53	0.82	1454	3.56	2.93	0.82	1509
	26	20	3.76	2.65	0.70	395	3.76	2.65	0.70	435	3.76	2.65	0.70	475	4.18	2.94	0.70	502	4.18	2.94	0.70	556	6.36	4.47	0.70	1109	6.08	4.28	0.70	1166	5.85	4.11	0.70	1220</																				

4. CAPACITIES AND SELECTION DATA

	Cooling Operation PERFORMANCE DATA																																																					
	OUTDOOR DB (°C)																																																					
COMBINATION (%)	IDDB (°C)	ID WB (°C)	-15				-7				0				10				15				21				25				27				30				35				40				45				50			
			Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT												
100%	21	18	3.47	2.08	0.60	344	3.47	2.08	0.60	383	3.47	2.08	0.60	422	3.86	2.32	0.60	448	3.86	2.32	0.60	500	5.87	3.52	0.60	1045	5.62	3.37	0.60	1098	5.40	3.24	0.60	1149	5.19	3.12	0.60	1202	4.90	2.94	0.60	1280	4.50	2.70	0.60	1359	4.16	2.50	0.60	1411	3.45	2.07	0.60	1465
	21	20	3.65	1.75	0.48	384	3.65	1.75	0.48	423	3.65	1.75	0.48	462	4.06	1.95	0.48	488	4.06	1.95	0.48	540	6.17	2.96	0.48	1077	5.90	2.83	0.48	1133	5.68	2.73	0.48	1185	5.46	2.62	0.48	1239	5.15	2.47	0.48	1320	4.73	2.27	0.48	1402	4.37	2.10	0.48	1455	3.63	1.74	0.48	1510
	22	18	3.47	2.22	0.64	344	3.47	2.22	0.64	383	3.47	2.22	0.64	422	3.86	2.47	0.64	448	3.86	2.47	0.64	500	5.87	3.76	0.64	1045	5.62	3.60	0.64	1098	5.40	3.46	0.64	1149	5.19	3.32	0.64	1202	4.90	3.14	0.64	1280	4.50	2.88	0.64	1359	4.16	2.66	0.64	1411	3.45	2.21	0.64	1465
	22	20	3.65	1.90	0.52	384	3.65	1.90	0.52	423	3.65	1.90	0.52	462	4.06	2.11	0.52	488	4.06	2.11	0.52	540	6.17	3.21	0.52	1077	5.90	3.07	0.52	1133	5.68	2.95	0.52	1185	5.46	2.84	0.52	1239	5.15	2.68	0.52	1320	4.73	2.46	0.52	1402	4.37	2.27	0.52	1455	3.63	1.89	0.52	1510
	22	22	3.87	1.55	0.40	423	3.87	1.55	0.40	462	3.87	1.55	0.40	501	4.30	1.72	0.40	527	4.30	1.72	0.40	579	6.54	2.62	0.40	1109	6.26	2.50	0.40	1166	6.02	2.41	0.40	1220	5.79	2.31	0.40	1276	5.46	2.18	0.40	1359	5.01	2.00	0.40	1443	4.64	1.85	0.40	1498	3.85	1.54	0.40	1555
	23	18	3.47	2.36	0.68	344	3.47	2.36	0.68	383	3.47	2.36	0.68	422	3.86	2.62	0.68	448	3.86	2.62	0.68	500	5.87	3.99	0.68	1045	5.62	3.82	0.68	1098	5.40	3.67	0.68	1149	5.19	3.53	0.68	1202	4.90	3.33	0.68	1280	4.50	3.06	0.68	1359	4.16	2.83	0.68	1411	3.45	2.35	0.68	1465
	23	20	3.65	2.04	0.56	384	3.65	2.04	0.56	423	3.65	2.04	0.56	462	4.06	2.27	0.56	488	4.06	2.27	0.56	540	6.17	3.46	0.56	1077	5.90	3.31	0.56	1133	5.68	3.18	0.56	1185	5.46	3.06	0.56	1239	5.15	2.88	0.56	1320	4.73	2.65	0.56	1402	4.37	2.45	0.56	1455	3.63	2.03	0.56	1510
	23	22	3.87	1.70	0.44	423	3.87	1.70	0.44	462	3.87	1.70	0.44	501	4.30	1.89	0.44	527	4.30	1.89	0.44	579	6.54	2.88	0.44	1109	6.26	2.75	0.44	1166	6.02	2.65	0.44	1220	5.79	2.55	0.44	1276	5.46	2.40	0.44	1359	5.01	2.20	0.44	1443	4.64	2.04	0.44	1498	3.85	1.69	0.44	1555
	24	18	3.47	2.50	0.72	344	3.47	2.50	0.72	383	3.47	2.50	0.72	422	3.86	2.78	0.72	448	3.86	2.78	0.72	500	5.87	4.23	0.72	1045	5.62	4.04	0.72	1098	5.40	3.89	0.72	1149	5.19	3.74	0.72	1202	4.90	3.53	0.72	1280	4.50	3.24	0.72	1359	4.16	3.00	0.72	1411	3.45	2.49	0.72	1465
	24	20	3.65	2.19	0.60	384	3.65	2.19	0.60	423	3.65	2.19	0.60	462	4.06	2.43	0.60	488	4.06	2.43	0.60	540	6.17	3.70	0.60	1077	5.90	3.54	0.60	1133	5.68	3.41	0.60	1185	5.46	3.28	0.60	1239	5.15	3.09	0.60	1320	4.73	2.84	0.60	1402	4.37	2.62	0.60	1455	3.63	2.18	0.60	1510
	24	22	3.87	1.86	0.48	423	3.87	1.86	0.48	462	3.87	1.86	0.48	501	4.30	2.06	0.48	527	4.30	2.06	0.48	579	6.54	3.14	0.48	1109	6.26	3.00	0.48	1166	6.02	2.89	0.48	1220	5.79	2.78	0.48	1276	5.46	2.62	0.48	1359	5.01	2.41	0.48	1443	4.64	2.23	0.48	1498	3.85	1.85	0.48	1555
	24	24	4.10	1.48	0.36	463	4.10	1.48	0.36	502	4.10	1.48	0.36	541	4.56	1.64	0.36	567	4.56	1.64	0.36	619	6.93	2.50	0.36	1142	6.63	2.39	0.36	1201	6.38	2.30	0.36	1256	6.13	2.21	0.36	1314	5.79	2.08	0.36	1399	5.31	1.91	0.36	1486	4.91	1.77	0.36	1542	4.08	1.47	0.36	1601
	25	18	3.47	2.64	0.76	344	3.47	2.64	0.76	383	3.47	2.64	0.76	422	3.86	2.93	0.76	448	3.86	2.93	0.76	500	5.87	4.46	0.76	1045	5.62	4.27	0.76	1098	5.40	4.11	0.76	1149	5.19	3.95	0.76	1202	4.90	3.72	0.76	1280	4.50	3.42	0.76	1359	4.16	3.16	0.76	1411	3.45	2.62	0.76	1465
	25	20	3.65	2.34	0.64	384	3.65	2.34	0.64	423	3.65	2.34	0.64	462	4.06	2.60	0.64	488	4.06	2.60	0.64	540	6.17	3.95	0.64	1077	5.90	3.78	0.64	1133	5.68	3.63	0.64	1185	5.46	3.49	0.64	1239	5.15	3.30	0.64	1320	4.73	3.03	0.64	1402	4.37	2.80	0.64	1455	3.63	2.32	0.64	1510
	25	22	3.87	2.01	0.52	423	3.87	2.01	0.52	462	3.87	2.01	0.52	501	4.30	2.24	0.52	527	4.30	2.24	0.52	579	6.54	3.40	0.52	1109	6.26	3.25	0.52	1166	6.02	3.13	0.52	1220	5.79	3.01	0.52	1276	5.46	2.84	0.52	1359	5.01	2.61	0.52	1443	4.64	2.41	0.52	1498	3.85	2.00	0.52	1555
	25	24	4.10	1.64	0.40	463	4.10	1.64	0.40	502	4.10	1.64	0.40	541	4.56	1.82	0.40	567	4.56	1.82	0.40	619	6.93	2.77	0.40	1142	6.63	2.65	0.40	1201	6.38	2.55	0.40	1256	6.13	2.45	0.40	1314	5.79	2.31	0.40	1399	5.31	2.12	0.40	1486	4.91	1.97	0.40	1542	4.08	1.63	0.40	1601
	26	18	3.47	2.78	0.80	344	3.47	2.78	0.80	383	3.47	2.78	0.80	422	3.86	3.09	0.80	448	3.86	3.09	0.80	500	5.87	4.70	0.80	1045	5.62	4.49	0.80	1098	5.40	4.32	0.80	1149	5.19	4.16	0.80	1202	4.90	3.92	0.80	1280	4.50	3.60	0.80	1359	4.16	3.33	0.80	1411	3.45	2.76	0.80	1465
	26	20	3.65	2.48	0.68	384	3.65	2.48	0.68	423																																												

4. CAPACITIES AND SELECTION DATA

				Cooling Operation PERFORMANCE DATA																																																		
				OUTDOOR DB (°C)																																																		
COMBINATION (%)	IDDB (°C)	ID WB (°C)	-15				-7				0				10				15				21				25				27				30				35				40				45				50			
			Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT								
90%	21	18	3.27	1.83	0.56	322	3.27	1.83	0.56	359	3.27	1.83	0.56	395	3.63	2.03	0.56	420	3.63	2.03	0.56	469	5.52	3.10	0.56	981	5.28	2.96	0.56	1032	5.08	2.85	0.56	1079	4.88	2.74	0.56	1129	4.61	2.58	0.56	1202	4.23	2.37	0.56	1277	3.91	2.19	0.56	1325	3.25	1.82	0.56	1375
	21	20	3.43	1.51	0.44	362	3.43	1.51	0.44	399	3.43	1.51	0.44	435	3.81	1.68	0.44	460	3.81	1.68	0.44	509	5.80	2.56	0.44	1014	5.55	2.45	0.44	1066	5.34	2.35	0.44	1115	5.13	2.26	0.44	1166	4.84	2.13	0.44	1242	4.44	1.96	0.44	1319	4.11	1.81	0.44	1369	3.41	1.50	0.44	1421
	22	18	3.27	1.96	0.60	322	3.27	1.96	0.60	359	3.27	1.96	0.60	395	3.63	2.18	0.60	420	3.63	2.18	0.60	469	5.52	3.32	0.60	981	5.28	3.17	0.60	1032	5.08	3.05	0.60	1079	4.88	2.93	0.60	1129	4.61	2.77	0.60	1202	4.23	2.54	0.60	1277	3.91	2.35	0.60	1325	3.25	1.95	0.60	1375
	22	20	3.43	1.65	0.48	362	3.43	1.65	0.48	399	3.43	1.65	0.48	435	3.81	1.83	0.48	460	3.81	1.83	0.48	509	5.80	2.79	0.48	1014	5.55	2.67	0.48	1066	5.34	2.57	0.48	1115	5.13	2.47	0.48	1166	4.84	2.33	0.48	1242	4.44	2.14	0.48	1319	4.11	1.98	0.48	1369	3.41	1.64	0.48	1421
	22	22	3.64	1.31	0.36	401	3.64	1.31	0.36	438	3.64	1.31	0.36	474	4.04	1.46	0.36	499	4.04	1.46	0.36	548	6.15	2.22	0.36	1045	5.88	2.12	0.36	1099	5.66	2.04	0.36	1150	5.44	1.96	0.36	1203	5.13	1.85	0.36	1281	4.71	1.70	0.36	1360	4.36	1.57	0.36	1412	3.62	1.31	0.36	1466
	23	18	3.27	2.09	0.64	322	3.27	2.09	0.64	359	3.27	2.09	0.64	395	3.63	2.33	0.64	420	3.63	2.33	0.64	469	5.52	3.54	0.64	981	5.28	3.38	0.64	1032	5.08	3.25	0.64	1079	4.88	3.13	0.64	1129	4.61	2.95	0.64	1202	4.23	2.71	0.64	1277	3.91	2.51	0.64	1325	3.25	2.08	0.64	1375
	23	20	3.43	1.79	0.52	362	3.43	1.79	0.52	399	3.43	1.79	0.52	435	3.81	1.99	0.52	460	3.81	1.99	0.52	509	5.80	3.02	0.52	1014	5.55	2.89	0.52	1066	5.34	2.78	0.52	1115	5.13	2.67	0.52	1166	4.84	2.52	0.52	1242	4.44	2.32	0.52	1319	4.11	2.14	0.52	1369	3.41	1.78	0.52	1421
	23	22	3.64	1.46	0.40	401	3.64	1.46	0.40	438	3.64	1.46	0.40	474	4.04	1.62	0.40	499	4.04	1.62	0.40	548	6.15	2.47	0.40	1045	5.88	2.36	0.40	1099	5.66	2.27	0.40	1150	5.44	2.18	0.40	1203	5.13	2.06	0.40	1281	4.71	1.89	0.40	1360	4.36	1.75	0.40	1412	3.62	1.45	0.40	1466
	24	18	3.27	2.22	0.68	322	3.27	2.22	0.68	359	3.27	2.22	0.68	395	3.63	2.47	0.68	420	3.63	2.47	0.68	469	5.52	3.76	0.68	981	5.28	3.60	0.68	1032	5.08	3.46	0.68	1079	4.88	3.32	0.68	1129	4.61	3.14	0.68	1202	4.23	2.88	0.68	1277	3.91	2.66	0.68	1325	3.25	2.21	0.68	1375
	24	20	3.43	1.93	0.56	362	3.43	1.93	0.56	399	3.43	1.93	0.56	435	3.81	2.14	0.56	460	3.81	2.14	0.56	509	5.80	3.25	0.56	1014	5.55	3.11	0.56	1066	5.34	2.99	0.56	1115	5.13	2.88	0.56	1166	4.84	2.72	0.56	1242	4.44	2.49	0.56	1319	4.11	2.31	0.56	1369	3.41	1.91	0.56	1421
	24	22	3.64	1.60	0.44	401	3.64	1.60	0.44	438	3.64	1.60	0.44	474	4.04	1.78	0.44	499	4.04	1.78	0.44	548	6.15	2.71	0.44	1045	5.88	2.59	0.44	1099	5.66	2.49	0.44	1150	5.44	2.40	0.44	1203	5.13	2.26	0.44	1281	4.71	2.08	0.44	1360	4.36	1.92	0.44	1412	3.62	1.59	0.44	1466
	24	24	3.86	1.24	0.32	441	3.86	1.24	0.32	478	3.86	1.24	0.32	514	4.28	1.37	0.32	539	4.28	1.37	0.32	588	6.52	2.09	0.32	1078	6.24	2.00	0.32	1134	6.00	1.92	0.32	1186	5.77	1.85	0.32	1240	5.44	1.75	0.32	1321	4.99	1.60	0.32	1403	4.62	1.48	0.32	1456	3.83	1.23	0.32	1512
	25	18	3.27	2.35	0.72	322	3.27	2.35	0.72	359	3.27	2.35	0.72	395	3.63	2.62	0.72	420	3.63	2.62	0.72	469	5.52	3.98	0.72	981	5.28	3.81	0.72	1032	5.08	3.66	0.72	1079	4.88	3.52	0.72	1129	4.61	3.32	0.72	1202	4.23	3.05	0.72	1277	3.91	2.82	0.72	1325	3.25	2.34	0.72	1375
	25	20	3.43	2.06	0.60	362	3.43	2.06	0.60	399	3.43	2.06	0.60	435	3.81	2.29	0.60	460	3.81	2.29	0.60	509	5.80	3.49	0.60	1014	5.55	3.34	0.60	1066	5.34	3.21	0.60	1115	5.13	3.08	0.60	1166	4.84	2.91	0.60	1242	4.44	2.67	0.60	1319	4.11	2.47	0.60	1369	3.41	2.05	0.60	1421
	25	22	3.64	1.75	0.48	401	3.64	1.75	0.48	438	3.64	1.75	0.48	474	4.04	1.94	0.48	499	4.04	1.94	0.48	548	6.15	2.96	0.48	1045	5.88	2.83	0.48	1099	5.66	2.72	0.48	1150	5.44	2.62	0.48	1203	5.13	2.47	0.48	1281	4.71	2.27	0.48	1360	4.36	2.10	0.48	1412	3.62	1.74	0.48	1466
	25	24	3.86	1.39	0.36	441	3.86	1.39	0.36	478	3.86	1.39	0.36	514	4.28	1.55	0.36	539	4.28	1.55	0.36	588	6.52	2.35	0.36	1078	6.24	2.25	0.36	1134	6.00	2.16	0.36	1186	5.77	2.08	0.36	1240	5.44	1.96	0.36	1321	4.99	1.80	0.36	1403	4.62	1.67	0.36	1456	3.83	1.38	0.36	1512
	26	18	3.27	2.49	0.76	322	3.27	2.49	0.76	359	3.27	2.49	0.76	395	3.63	2.76	0.76	420	3.63	2.76	0.76	469	5.52	4.20	0.76	981	5.28	4.02	0.76	1032	5.08	3.86	0.76	1079	4.88	3.72	0.76	1129	4.61	3.51	0.76	1202	4.23	3.22	0.76	1277	3.91	2.98	0.76	1325	3.25	2.47	0.76	1375
	26	20	3.43	2.20	0.64	362	3.43	2.20	0.64	399	3.43	2.20	0.64	435	3.81	2.44	0.64	460	3.81	2.44	0.64	509	5.80	3.72	0.64	1014	5.55	3.56	0.64	1066	5.34	3.42</																						

4. CAPACITIES AND SELECTION DATA

			Cooling Operation PERFORMANCE DATA																																																			
			OUTDOOR DB (°C)																																																			
COMBINATION (%)	IDDB (°C)	ID WB (°C)	-15				-7				0				10				15				21				25				27				30				35				40				45				50			
			Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT								
80%	21	18	3.14	1.69	0.54	288	3.14	1.69	0.54	321	3.14	1.69	0.54	354	3.48	1.88	0.54	376	3.48	1.88	0.54	420	5.30	2.85	0.54	881	5.07	2.73	0.54	927	4.87	2.63	0.54	969	4.69	2.53	0.54	1014	4.42	2.38	0.54	1080	4.06	2.19	0.54	1147	3.75	2.02	0.54	1190	3.12	1.68	0.54	1236
	21	20	3.29	1.38	0.42	328	3.29	1.38	0.42	361	3.29	1.38	0.42	394	3.66	1.53	0.42	416	3.66	1.53	0.42	460	5.57	2.33	0.42	914	5.33	2.23	0.42	961	5.12	2.15	0.42	1005	4.93	2.06	0.42	1051	4.65	1.95	0.42	1120	4.27	1.79	0.42	1189	3.95	1.65	0.42	1234	3.28	1.37	0.42	1281
	22	18	3.14	1.81	0.58	288	3.14	1.81	0.58	321	3.14	1.81	0.58	354	3.48	2.02	0.58	376	3.48	2.02	0.58	420	5.30	3.07	0.58	881	5.07	2.93	0.58	927	4.87	2.82	0.58	969	4.69	2.71	0.58	1014	4.42	2.56	0.58	1080	4.06	2.35	0.58	1147	3.75	2.17	0.58	1190	3.12	1.80	0.58	1236
	22	20	3.29	1.51	0.46	328	3.29	1.51	0.46	361	3.29	1.51	0.46	394	3.66	1.68	0.46	416	3.66	1.68	0.46	460	5.57	2.55	0.46	914	5.33	2.44	0.46	961	5.12	2.35	0.46	1005	4.93	2.26	0.46	1051	4.65	2.13	0.46	1120	4.27	1.96	0.46	1189	3.95	1.81	0.46	1234	3.28	1.50	0.46	1281
	22	22	3.49	1.18	0.34	367	3.49	1.18	0.34	400	3.49	1.18	0.34	433	3.88	1.31	0.34	455	3.88	1.31	0.34	499	5.90	2.00	0.34	946	5.65	1.91	0.34	994	5.43	1.84	0.34	1040	5.22	1.77	0.34	1088	4.93	1.67	0.34	1159	4.52	1.53	0.34	1231	4.18	1.42	0.34	1277	3.47	1.18	0.34	1326
	23	18	3.14	1.94	0.62	288	3.14	1.94	0.62	321	3.14	1.94	0.62	354	3.48	2.15	0.62	376	3.48	2.15	0.62	420	5.30	3.28	0.62	881	5.07	3.14	0.62	927	4.87	3.02	0.62	969	4.69	2.90	0.62	1014	4.42	2.74	0.62	1080	4.06	2.51	0.62	1147	3.75	2.32	0.62	1190	3.12	1.93	0.62	1236
	23	20	3.29	1.64	0.50	328	3.29	1.64	0.50	361	3.29	1.64	0.50	394	3.66	1.83	0.50	416	3.66	1.83	0.50	460	5.57	2.78	0.50	914	5.33	2.66	0.50	961	5.12	2.56	0.50	1005	4.93	2.46	0.50	1051	4.65	2.32	0.50	1120	4.27	2.13	0.50	1189	3.95	1.97	0.50	1234	3.28	1.63	0.50	1281
	23	22	3.49	1.32	0.38	367	3.49	1.32	0.38	400	3.49	1.32	0.38	433	3.88	1.47	0.38	455	3.88	1.47	0.38	499	5.90	2.24	0.38	946	5.65	2.14	0.38	994	5.43	2.06	0.38	1040	5.22	1.98	0.38	1088	4.93	1.87	0.38	1159	4.52	1.71	0.38	1231	4.18	1.58	0.38	1277	3.47	1.32	0.38	1326
	24	18	3.14	2.07	0.66	288	3.14	2.07	0.66	321	3.14	2.07	0.66	354	3.48	2.29	0.66	376	3.48	2.29	0.66	420	5.30	3.49	0.66	881	5.07	3.34	0.66	927	4.87	3.21	0.66	969	4.69	3.09	0.66	1014	4.42	2.91	0.66	1080	4.06	2.67	0.66	1147	3.75	2.47	0.66	1190	3.12	2.05	0.66	1236
	24	20	3.29	1.78	0.54	328	3.29	1.78	0.54	361	3.29	1.78	0.54	394	3.66	1.97	0.54	416	3.66	1.97	0.54	460	5.57	3.00	0.54	914	5.33	2.87	0.54	961	5.12	2.76	0.54	1005	4.93	2.65	0.54	1051	4.65	2.50	0.54	1120	4.27	2.30	0.54	1189	3.95	2.13	0.54	1234	3.28	1.76	0.54	1281
	24	22	3.49	1.46	0.42	367	3.49	1.46	0.42	400	3.49	1.46	0.42	433	3.88	1.62	0.42	455	3.88	1.62	0.42	499	5.90	2.47	0.42	946	5.65	2.37	0.42	994	5.43	2.27	0.42	1040	5.22	2.19	0.42	1088	4.93	2.06	0.42	1159	4.52	1.89	0.42	1231	4.18	1.75	0.42	1277	3.47	1.45	0.42	1326
	24	24	3.70	1.11	0.30	407	3.70	1.11	0.30	440	3.70	1.11	0.30	473	4.11	1.23	0.30	495	4.11	1.23	0.30	539	6.26	1.87	0.30	978	5.99	1.79	0.30	1029	5.76	1.72	0.30	1076	5.54	1.65	0.30	1126	5.22	1.56	0.30	1199	4.79	1.43	0.30	1273	4.43	1.32	0.30	1322	3.68	1.10	0.30	1372
	25	18	3.14	2.19	0.70	288	3.14	2.19	0.70	321	3.14	2.19	0.70	354	3.48	2.43	0.70	376	3.48	2.43	0.70	420	5.30	3.70	0.70	881	5.07	3.54	0.70	927	4.87	3.41	0.70	969	4.69	3.28	0.70	1014	4.42	3.09	0.70	1080	4.06	2.84	0.70	1147	3.75	2.62	0.70	1190	3.12	2.18	0.70	1236
	25	20	3.29	1.91	0.58	328	3.29	1.91	0.58	361	3.29	1.91	0.58	394	3.66	2.12	0.58	416	3.66	2.12	0.58	460	5.57	3.22	0.58	914	5.33	3.08	0.58	961	5.12	2.97	0.58	1005	4.93	2.85	0.58	1051	4.65	2.69	0.58	1120	4.27	2.47	0.58	1189	3.95	2.28	0.58	1234	3.28	1.90	0.58	1281
	25	22	3.49	1.60	0.46	367	3.49	1.60	0.46	400	3.49	1.60	0.46	433	3.88	1.78	0.46	455	3.88	1.78	0.46	499	5.90	2.71	0.46	946	5.65	2.59	0.46	994	5.43	2.49	0.46	1040	5.22	2.40	0.46	1088	4.93	2.26	0.46	1159	4.52	2.07	0.46	1231	4.18	1.92	0.46	1277	3.47	1.59	0.46	1326
	25	24	3.70	1.25	0.34	407	3.70	1.25	0.34	440	3.70	1.25	0.34	473	4.11	1.39	0.34	495	4.11	1.39	0.34	539	6.26	2.12	0.34	978	5.99	2.03	0.34	1029	5.76	1.95	0.34	1076	5.54	1.88	0.34	1126	5.22	1.77	0.34	1199	4.79	1.62	0.34	1273	4.43	1.50	0.34	1322	3.68	1.25	0.34	1372
	26	18	3.14	2.32	0.74	288	3.14	2.32	0.74	321	3.14	2.32	0.74	354	3.48	2.57	0.74	376	3.48	2.57	0.74	420	5.30	3.91	0.74	881	5.07	3.75	0.74	927	4.87	3.60	0.74	969	4.69	3.46	0.74	1014	4.42	3.27	0.74	1080	4.06	3.00	0.74	1147	3.75	2.77	0.74	1190	3.12	2.30	0.74	1236
	26	20	3.29	2.04	0.62	328	3.29	2.04	0.62	361	3.29	2.04	0.62	394	3.66	2.26	0.62	416	3.66	2.26	0.62	460	5.57	3.45	0.62																													

5. CAPACITIES AND SELECTION DATA

18K(Up to 2 indoor units series)

HEATING PERFORMANCE DATA

COMBINATION (%)	INDOOR DB(°C)	OUTDOOR WB(°C)															
		-15		-10		-5		0		5		10		15		20	
		Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT
130%	15	3.76	1240	4.42	1278	4.91	1291	5.40	1318	5.87	1387	6.34	1456	6.66	1500	6.86	1530
	16	3.71	1250	4.37	1289	4.86	1302	5.34	1328	5.80	1398	6.26	1468	6.58	1512	6.77	1542
	17	3.67	1260	4.32	1299	4.80	1312	5.27	1339	5.73	1409	6.19	1480	6.50	1524	6.69	1555
	18	3.63	1270	4.27	1309	4.74	1323	5.21	1350	5.66	1421	6.12	1492	6.42	1537	6.61	1567
	19	3.58	1280	4.22	1320	4.68	1333	5.15	1361	5.60	1432	6.04	1504	6.35	1549	6.54	1580
	20	3.55	1291	4.17	1331	4.64	1344	5.10	1372	5.54	1444	5.98	1516	6.28	1561	6.47	1593
	21	3.51	1305	4.12	1345	4.58	1359	5.04	1387	5.47	1460	5.91	1533	6.21	1579	6.39	1610
	22	3.46	1319	4.07	1360	4.53	1374	4.98	1402	5.41	1476	5.84	1549	6.13	1596	6.32	1628
	23	3.42	1334	4.03	1375	4.47	1389	4.92	1417	5.34	1492	5.77	1567	6.06	1614	6.24	1646
	24	3.38	1349	3.98	1390	4.42	1404	4.86	1433	5.28	1508	5.70	1584	5.99	1631	6.17	1664
	25	3.34	1363	3.93	1406	4.37	1420	4.80	1449	5.22	1525	5.63	1601	5.91	1649	6.09	1682
	26	3.30	1378	3.88	1421	4.31	1435	4.74	1465	5.15	1542	5.57	1619	5.84	1667	6.02	1701
	27	3.26	1394	3.84	1437	4.26	1451	4.68	1481	5.09	1559	5.50	1637	5.77	1686	5.95	1719
	28	3.22	1409	3.79	1452	4.21	1467	4.63	1497	5.03	1576	5.43	1655	5.70	1704	5.88	1738
	29	3.18	1424	3.74	1468	4.16	1483	4.57	1513	4.97	1593	5.37	1673	5.64	1723	5.80	1757
	30	3.14	1440	3.70	1485	4.11	1500	4.52	1530	4.91	1611	5.30	1691	5.57	1742	5.74	1777
120%	15	3.65	1181	4.29	1217	4.77	1230	5.24	1255	5.70	1321	6.15	1387	6.46	1429	6.66	1457
	16	3.61	1190	4.24	1227	4.71	1240	5.18	1265	5.63	1332	6.08	1398	6.38	1440	6.58	1469
	17	3.56	1200	4.19	1237	4.66	1250	5.12	1275	5.56	1342	6.01	1409	6.31	1452	6.50	1481
	18	3.52	1210	4.14	1247	4.60	1260	5.06	1285	5.50	1353	5.94	1421	6.23	1463	6.42	1493
	19	3.48	1219	4.09	1257	4.55	1270	5.00	1296	5.43	1364	5.87	1432	6.16	1475	6.35	1505
	20	3.44	1229	4.05	1267	4.50	1280	4.95	1306	5.38	1375	5.81	1444	6.10	1487	6.28	1517
	21	3.40	1243	4.00	1281	4.45	1294	4.89	1321	5.31	1390	5.74	1460	6.03	1503	6.21	1533
	22	3.36	1257	3.96	1295	4.40	1308	4.83	1335	5.25	1405	5.67	1476	5.95	1520	6.13	1550
	23	3.32	1270	3.91	1310	4.34	1323	4.77	1350	5.19	1421	5.60	1492	5.88	1537	6.06	1567
	24	3.28	1284	3.86	1324	4.29	1337	4.72	1365	5.13	1437	5.54	1508	5.81	1554	5.99	1585
	25	3.24	1298	3.82	1339	4.24	1352	4.66	1380	5.06	1452	5.47	1525	5.74	1571	5.91	1602
	26	3.20	1313	3.77	1353	4.19	1367	4.60	1395	5.00	1468	5.40	1542	5.67	1588	5.84	1620
	27	3.17	1327	3.72	1368	4.14	1382	4.55	1410	4.94	1484	5.34	1559	5.61	1605	5.77	1638
	28	3.13	1342	3.68	1383	4.09	1397	4.49	1426	4.88	1501	5.27	1576	5.54	1623	5.70	1656
	29	3.09	1357	3.64	1398	4.04	1413	4.44	1441	4.82	1517	5.21	1593	5.47	1641	5.64	1674
	30	3.05	1371	3.59	1414	3.99	1428	4.39	1457	4.77	1534	5.15	1611	5.41	1659	5.57	1692
110%	15	3.54	1158	4.17	1194	4.63	1206	5.09	1230	5.53	1295	5.97	1360	6.27	1401	6.46	1429
	16	3.50	1167	4.12	1203	4.58	1215	5.03	1240	5.47	1305	5.90	1371	6.20	1412	6.38	1440
	17	3.46	1177	4.07	1213	4.52	1225	4.97	1250	5.40	1316	5.83	1382	6.13	1423	6.31	1452
	18	3.42	1186	4.02	1223	4.47	1235	4.91	1260	5.34	1327	5.76	1393	6.05	1435	6.23	1463
	19	3.38	1196	3.97	1233	4.42	1245	4.85	1270	5.27	1337	5.70	1404	5.98	1446	6.16	1475
	20	3.34	1205	3.93	1242	4.37	1255	4.80	1281	5.22	1348	5.64	1415	5.92	1458	6.10	1487
	21	3.30	1218	3.89	1256	4.32	1269	4.75	1295	5.16	1363	5.57	1431	5.85	1474	6.03	1503
	22	3.26	1232	3.84	1270	4.27	1283	4.69	1309	5.10	1378	5.51	1447	5.78	1490	5.95	1520
	23	3.23	1245	3.79	1284	4.22	1297	4.63	1323	5.04	1393	5.44	1463	5.71	1507	5.88	1537
	24	3.19	1259	3.75	1298	4.17	1311	4.58	1338	4.98	1408	5.37	1479	5.64	1523	5.81	1554
	25	3.15	1273	3.70	1312	4.12	1326	4.52	1353	4.92	1424	5.31	1495	5.57	1540	5.74	1571
	26	3.11	1287	3.66	1327	4.07	1340	4.47	1368	4.86	1439	5.25	1511	5.51	1557	5.67	1588
	27	3.07	1301	3.62	1341	4.02	1355	4.42	1383	4.80	1455	5.18	1528	5.44	1574	5.61	1605
	28	3.04	1315	3.57	1356	3.97	1370	4.36	1398	4.74	1471	5.12	1545	5.38	1591	5.54	1623
	29	3.00	1330	3.53	1371	3.92	1385	4.31	1413	4.68	1488	5.06	1562	5.31	1609	5.47	1641
	30	2.96	1345	3.49	1386	3.87	1400	4.26	1429	4.63	1504	5.00	1579	5.25	1626	5.41	1659

4. CAPACITIES AND SELECTION DATA

COMBINATION (%)	INDOOR DB(°C)	OUTDOOR WB(°C)															
		-15		-10		-5		0		5		10		15		20	
		Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT
100%	15	3.44	1124	4.05	1159	4.50	1171	4.94	1194	5.37	1257	5.80	1320	6.09	1360	6.27	1387
	16	3.40	1133	4.00	1168	4.44	1180	4.88	1204	5.31	1267	5.73	1331	6.02	1371	6.20	1398
	17	3.36	1142	3.95	1178	4.39	1189	4.82	1214	5.24	1278	5.66	1342	5.95	1382	6.13	1409
	18	3.32	1151	3.90	1187	4.34	1199	4.77	1224	5.18	1288	5.60	1352	5.88	1393	6.05	1421
	19	3.28	1161	3.86	1197	4.29	1209	4.71	1233	5.12	1298	5.53	1363	5.81	1404	5.98	1432
	20	3.25	1170	3.82	1206	4.24	1218	4.66	1243	5.07	1309	5.48	1374	5.75	1415	5.92	1444
	21	3.21	1183	3.77	1220	4.19	1232	4.61	1257	5.01	1323	5.41	1389	5.68	1431	5.85	1460
	22	3.17	1196	3.73	1233	4.14	1245	4.55	1271	4.95	1338	5.34	1405	5.61	1447	5.78	1476
	23	3.13	1209	3.68	1247	4.09	1259	4.50	1285	4.89	1352	5.28	1420	5.54	1463	5.71	1492
	24	3.09	1222	3.64	1260	4.04	1273	4.44	1299	4.83	1367	5.22	1436	5.48	1479	5.64	1508
	25	3.06	1236	3.60	1274	4.00	1287	4.39	1313	4.77	1382	5.15	1451	5.41	1495	5.57	1525
	26	3.02	1249	3.55	1288	3.95	1301	4.34	1328	4.72	1398	5.09	1467	5.35	1511	5.51	1542
	27	2.98	1263	3.51	1302	3.90	1315	4.29	1342	4.66	1413	5.03	1484	5.28	1528	5.44	1559
	28	2.95	1277	3.47	1317	3.85	1330	4.23	1357	4.60	1428	4.97	1500	5.22	1545	5.38	1576
	29	2.91	1291	3.43	1331	3.81	1345	4.18	1372	4.55	1444	4.91	1516	5.16	1562	5.31	1593
	30	2.88	1305	3.39	1346	3.76	1359	4.13	1387	4.49	1460	4.85	1533	5.10	1579	5.25	1611
COMBINATION (%)	INDOOR DB(°C)	OUTDOOR WB(°C)															
		-15		-10		-5		0		5		10		15		20	
		Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT
90%	15	3.32	1104	3.91	1138	4.34	1149	4.77	1173	5.18	1235	5.60	1296	5.88	1335	6.05	1362
	16	3.28	1113	3.86	1147	4.29	1159	4.71	1182	5.12	1245	5.53	1307	5.81	1346	5.98	1373
	17	3.24	1122	3.81	1156	4.24	1168	4.66	1192	5.06	1255	5.47	1317	5.74	1357	5.91	1384
	18	3.20	1131	3.77	1166	4.19	1177	4.60	1202	5.00	1265	5.40	1328	5.67	1368	5.84	1395
	19	3.16	1140	3.72	1175	4.14	1187	4.55	1211	4.94	1275	5.34	1339	5.60	1379	5.77	1406
	20	3.13	1149	3.69	1185	4.10	1197	4.50	1221	4.89	1285	5.28	1349	5.55	1390	5.71	1418
	21	3.10	1162	3.64	1198	4.05	1210	4.45	1234	4.83	1299	5.22	1364	5.48	1405	5.65	1433
	22	3.06	1174	3.60	1211	4.00	1223	4.39	1248	4.78	1314	5.16	1379	5.42	1421	5.58	1449
	23	3.02	1187	3.56	1224	3.95	1236	4.34	1262	4.72	1328	5.10	1395	5.35	1436	5.51	1465
	24	2.99	1200	3.51	1238	3.90	1250	4.29	1276	4.66	1343	5.03	1410	5.29	1452	5.45	1481
	25	2.95	1214	3.47	1251	3.86	1264	4.24	1290	4.61	1357	4.97	1425	5.22	1468	5.38	1497
	26	2.91	1227	3.43	1265	3.81	1278	4.19	1304	4.55	1372	4.91	1441	5.16	1484	5.32	1514
	27	2.88	1240	3.39	1279	3.76	1292	4.14	1318	4.50	1388	4.86	1457	5.10	1501	5.25	1531
	28	2.84	1254	3.35	1293	3.72	1306	4.09	1333	4.44	1403	4.80	1473	5.04	1517	5.19	1547
	29	2.81	1268	3.31	1307	3.67	1320	4.04	1347	4.39	1418	4.74	1489	4.98	1534	5.13	1564
	30	2.78	1282	3.27	1322	3.63	1335	3.99	1362	4.34	1434	4.68	1505	4.92	1551	5.06	1582
COMBINATION (%)	INDOOR DB(°C)	OUTDOOR WB(°C)															
		-15	-10	-5	0	5	10	15	20	-15	-10	-5	0	5	10	15	20
		Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT
80%	15	3.22	1093	3.79	1127	4.21	1138	4.63	1161	5.03	1222	5.43	1283	5.70	1322	5.87	1348
	16	3.18	1102	3.74	1136	4.16	1147	4.57	1171	4.97	1232	5.37	1294	5.63	1333	5.80	1359
	17	3.14	1110	3.70	1145	4.11	1156	4.52	1180	4.91	1242	5.30	1304	5.57	1343	5.73	1370
	18	3.11	1119	3.65	1154	4.06	1166	4.46	1189	4.85	1252	5.24	1315	5.50	1354	5.67	1381
	19	3.07	1128	3.61	1163	4.01	1175	4.41	1199	4.79	1262	5.18	1325	5.44	1365	5.60	1392
	20	3.04	1138	3.58	1173	3.97	1185	4.37	1209	4.75	1272	5.13	1336	5.38	1376	5.54	1404
	21	3.00	1150	3.53	1186	3.93	1198	4.31	1222	4.69	1286	5.06	1351	5.32	1391	5.48	1419
	22	2.97	1163	3.49	1199	3.88	1211	4.26	1235	4.63	1301	5.00	1366	5.25	1407	5.41	1435
	23	2.93	1176	3.45	1212	3.83	1224	4.21	1249	4.58	1315	4.94	1381	5.19	1422	5.35	1450
	24	2.90	1188	3.41	1225	3.79	1238	4.16	1263	4.52	1329	4.88	1396	5.13	1438	5.28	1466
	25	2.86	1202	3.37	1239	3.74	1251	4.11	1277	4.47	1344	4.83	1411	5.07	1453	5.22	1483
	26	2.83	1215	3.33	1252	3.70	1265	4.06	1291	4.41	1359	4.77	1427	5.01	1469	5.16	1499
	27	2.79	1228	3.29	1266	3.65	1279	4.01	1305	4.36	1374	4.71	1442	4.95	1486	5.09	1515
	28	2.76	1242	3.25	1280	3.61	1293	3.96	1319	4.31	1389	4.65	1458	4.89	1502	5.03	1532
	29	2.73	1255	3.21	1294	3.56	1307	3.92	1334	4.26	1404	4.60	1474	4.83	1518	4.97	1549
	30	2.69	1269	3.17	1308	3.52	1322	3.87	1348	4.21	1419	4.54	1490	4.77	1535	4.91	1566

Remarks:
Q: Total Cooling Capacity (Gross) **kW**
INPUT: Power Input (including the compressor, evap. fan motor & cond. **W**
DB: Dry Bulb Temperature
WB: Wet Bulb Temperature

3AMW52U4RJC

-

UE MULTI 3 POSTES 5,2 KW

4. CAPACITIES AND SELECTION DATA

18K (Up to 3 indoor units series)

				Cooling Operation PERFORMANCE DATA																																																		
				OUTDOOR DB (°C)																																																		
COMBINATION (%)	IDDB (°C)	ID WB (°C)	-15				-7				0				10				15				21				25				27				30				35				40				45				50			
			Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT								
130%	21	18	5.34	3.79	0.71	914	5.28	3.75	0.71	922	5.23	3.71	0.71	931	5.16	3.66	0.71	938	5.11	3.63	0.71	943	5.05	3.59	0.71	975	4.98	3.54	0.71	1018	4.89	3.47	0.71	1087	4.78	3.39	0.71	1137	4.64	3.29	0.71	1180	4.26	3.02	0.71	1254	3.51	2.50	0.71	1302	2.90	2.06	0.71	1352
	21	20	5.56	3.28	0.59	937	5.50	3.25	0.59	946	5.44	3.21	0.59	954	5.37	3.17	0.59	962	5.32	3.14	0.59	967	5.26	3.10	0.59	998	5.19	3.06	0.59	1041	5.10	3.01	0.59	1110	4.98	2.94	0.59	1161	4.83	2.85	0.59	1204	4.44	2.62	0.59	1277	3.66	2.16	0.59	1325	3.02	1.78	0.59	1375
	22	18	5.50	4.13	0.75	923	5.45	4.08	0.75	932	5.39	4.04	0.75	940	5.32	3.99	0.75	948	5.27	3.95	0.75	953	5.21	3.91	0.75	984	5.14	3.85	0.75	1028	5.05	3.78	0.75	1098	4.93	3.70	0.75	1149	4.78	3.59	0.75	1192	4.39	3.29	0.75	1266	3.62	2.72	0.75	1315	2.99	2.24	0.75	1365
	22	20	5.67	3.57	0.63	947	5.61	3.54	0.63	955	5.55	3.50	0.63	964	5.48	3.45	0.63	972	5.43	3.42	0.63	976	5.37	3.38	0.63	1008	5.29	3.33	0.63	1052	5.20	3.28	0.63	1122	5.08	3.20	0.63	1172	4.93	3.11	0.63	1216	4.53	2.85	0.63	1290	3.73	2.35	0.63	1339	3.08	1.94	0.63	1389
	22	22	5.77	2.94	0.51	963	5.71	2.91	0.51	972	5.65	2.88	0.51	980	5.57	2.84	0.51	988	5.52	2.81	0.51	993	5.46	2.78	0.51	1024	5.38	2.75	0.51	1068	5.29	2.70	0.51	1138	5.16	2.63	0.51	1189	5.01	2.56	0.51	1232	4.60	2.35	0.51	1306	3.80	1.94	0.51	1355	3.13	1.60	0.51	1405
	23	18	5.61	4.43	0.79	932	5.56	4.39	0.79	941	5.50	4.34	0.79	950	5.43	4.29	0.79	957	5.37	4.24	0.79	962	5.31	4.20	0.79	994	5.24	4.14	0.79	1038	5.15	4.07	0.79	1109	5.03	3.97	0.79	1160	4.88	3.86	0.79	1204	4.48	3.54	0.79	1279	3.70	2.92	0.79	1328	3.05	2.41	0.79	1379
	23	20	5.79	3.88	0.67	956	5.73	3.84	0.67	965	5.67	3.80	0.67	974	5.59	3.75	0.67	981	5.54	3.71	0.67	986	5.48	3.67	0.67	1018	5.40	3.62	0.67	1062	5.31	3.55	0.67	1133	5.18	3.47	0.67	1184	5.03	3.37	0.67	1228	4.62	3.09	0.67	1303	3.81	2.55	0.67	1352	3.14	2.11	0.67	1403
	23	22	5.88	3.24	0.55	973	5.83	3.20	0.55	981	5.76	3.17	0.55	990	5.69	3.13	0.55	998	5.63	3.10	0.55	1003	5.57	3.06	0.55	1035	5.49	3.02	0.55	1079	5.40	2.97	0.55	1149	5.27	2.90	0.55	1201	5.12	2.81	0.55	1244	4.70	2.58	0.55	1320	3.87	2.13	0.55	1369	3.20	1.76	0.55	1419
	24	18	5.73	4.75	0.83	942	5.67	4.71	0.83	951	5.61	4.66	0.83	959	5.54	4.60	0.83	967	5.48	4.55	0.83	972	5.42	4.50	0.83	1004	5.35	4.44	0.83	1049	5.25	4.36	0.83	1120	5.13	4.26	0.83	1172	4.98	4.13	0.83	1216	4.57	3.80	0.83	1292	3.77	3.13	0.83	1342	3.11	2.58	0.83	1393
	24	20	5.90	4.19	0.71	966	5.84	4.15	0.71	975	5.78	4.10	0.71	983	5.71	4.05	0.71	991	5.65	4.01	0.71	996	5.59	3.97	0.71	1029	5.51	3.91	0.71	1073	5.41	3.84	0.71	1144	5.29	3.75	0.71	1196	5.13	3.64	0.71	1240	4.71	3.35	0.71	1316	3.89	2.76	0.71	1366	3.21	2.28	0.71	1417
	24	22	6.00	3.54	0.59	983	5.94	3.51	0.59	991	5.88	3.47	0.59	1000	5.80	3.42	0.59	1008	5.75	3.39	0.59	1013	5.68	3.35	0.59	1045	5.61	3.31	0.59	1090	5.51	3.25	0.59	1161	5.38	3.17	0.59	1213	5.22	3.08	0.59	1257	4.79	2.83	0.59	1333	3.95	2.33	0.59	1382	3.26	1.92	0.59	1434
	24	24	6.09	2.86	0.47	1002	6.03	2.83	0.47	1011	5.96	2.80	0.47	1019	5.89	2.77	0.47	1027	5.83	2.74	0.47	1032	5.76	2.71	0.47	1065	5.68	2.67	0.47	1109	5.58	2.62	0.47	1180	5.45	2.56	0.47	1232	5.29	2.49	0.47	1276	4.86	2.28	0.47	1352	4.01	1.88	0.47	1402	3.31	1.55	0.47	1453
	25	18	5.90	5.14	0.87	951	5.85	5.09	0.87	960	5.78	5.03	0.87	969	5.71	4.97	0.87	977	5.65	4.92	0.87	982	5.59	4.86	0.87	1015	5.51	4.80	0.87	1059	5.42	4.71	0.87	1131	5.29	4.60	0.87	1184	5.13	4.47	0.87	1228	4.71	4.10	0.87	1305	3.89	3.38	0.87	1355	3.21	2.79	0.87	1407
	25	20	6.09	4.56	0.75	976	6.03	4.52	0.75	985	5.96	4.47	0.75	993	5.88	4.41	0.75	1001	5.83	4.37	0.75	1006	5.76	4.32	0.75	1039	5.68	4.26	0.75	1084	5.58	4.19	0.75	1156	5.45	4.09	0.75	1208	5.29	3.97	0.75	1253	4.86	3.64	0.75	1330	4.01	3.01	0.75	1380	3.31	2.48	0.75	1432
	25	22	6.19	3.90	0.63	993	6.13	3.86	0.63	1001	6.06	3.82	0.63	1010	5.98	3.77	0.63	1018	5.92	3.73	0.63	1023	5.86	3.69	0.63	1056	5.78	3.64	0.63	1101	5.68	3.58	0.63	1173	5.54	3.49	0.63	1225	5.38	3.39	0.63	1270	4.94	3.11	0.63	1346	4.08	2.57	0.63	1396	3.36	2.12	0.63	1448
	25	24	6.28	3.20	0.51	1012	6.21	3.17	0.51	1021	6.15	3.13	0.51	1030	6.07	3.09	0.51	1038	6.01	3.06	0.51	1043	5.94	3.03	0.51	1075	5.86	2.99	0.51	1120	5.76	2.94	0.51	1192	5.62	2.87	0.51	1245	5.46	2.78	0.51	1289	5.01	2.56	0.51	1366	4.13	2.11	0.51	1416	3.41	1.74	0.51	1468
	26	18	6.09	5.54	0.91	961	6.03	5.48	0.91	970	5.96	5.43	0.91	979	5.89	5.36	0.91	987	5.83	5.30	0.91	992	5.76	5.24	0.91	1025	5.68	5.17	0.91	1070	5.58	5.08	0.91	1143	5.45	4.96	0.91	1196	5.29	4.82	0.91	1241	4.86	4.42	0.91	1318	4.01	3.65	0.91	1369	3.31	3.01	0.91	1421
	26	20	6.27	4.96	0.79	986	6.21	4.91	0.79	995	6.14	4.85	0.79	1003	6.07	4.79	0.79	1011	6.01	4.74	0.79	1016	5.94	4.69	0.79	1050	5.86	4.63	0.79	1095	5.75	4.55	0.79	1168																				

4. CAPACITIES AND SELECTION DATA

	Cooling Operation PERFORMANCE DATA																																																					
	OUTDOOR DB (°C)																																																					
COMBINATION (%)	IDDB (°C)	ID WB (°C)	-15				-7				0				10				15				21				25				27				30				35				40				45				50			
			Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT								
120%	21	18	5.29	3.75	0.71	905	5.23	3.72	0.71	913	5.18	3.68	0.71	922	5.11	3.63	0.71	929	5.06	3.59	0.71	934	5.00	3.55	0.71	965	4.94	3.50	0.71	1008	4.85	3.44	0.71	1076	4.73	3.36	0.71	1126	4.60	3.26	0.71	1169	4.22	3.00	0.71	1242	3.48	2.47	0.71	1289	2.87	2.04	0.71	1339
	21	20	5.50	3.25	0.59	929	5.45	3.21	0.59	937	5.39	3.18	0.59	945	5.32	3.14	0.59	953	5.27	3.11	0.59	958	5.21	3.07	0.59	989	5.14	3.03	0.59	1031	5.05	2.98	0.59	1100	4.93	2.91	0.59	1150	4.79	2.82	0.59	1192	4.39	2.59	0.59	1265	3.62	2.14	0.59	1313	2.99	1.76	0.59	1362
	22	18	5.45	4.09	0.75	914	5.40	4.05	0.75	923	5.34	4.00	0.75	931	5.27	3.95	0.75	939	5.22	3.91	0.75	943	5.16	3.87	0.75	975	5.09	3.82	0.75	1018	5.00	3.75	0.75	1087	4.88	3.66	0.75	1138	4.74	3.55	0.75	1180	4.35	3.26	0.75	1254	3.59	2.69	0.75	1302	2.96	2.22	0.75	1352
	22	20	5.62	3.54	0.63	938	5.56	3.50	0.63	946	5.50	3.46	0.63	955	5.43	3.42	0.63	962	5.38	3.39	0.63	967	5.32	3.35	0.63	999	5.24	3.30	0.63	1042	5.15	3.24	0.63	1111	5.03	3.17	0.63	1161	4.88	3.08	0.63	1204	4.48	2.82	0.63	1278	3.70	2.33	0.63	1326	3.05	1.92	0.63	1376
	22	22	5.71	2.91	0.51	954	5.65	2.88	0.51	963	5.59	2.85	0.51	971	5.52	2.82	0.51	979	5.47	2.79	0.51	983	5.41	2.76	0.51	1015	5.33	2.72	0.51	1058	5.24	2.67	0.51	1127	5.12	2.61	0.51	1178	4.97	2.53	0.51	1220	4.56	2.33	0.51	1294	3.76	1.92	0.51	1342	3.10	1.58	0.51	1392
	23	18	5.56	4.39	0.79	923	5.51	4.35	0.79	932	5.45	4.30	0.79	940	5.38	4.25	0.79	948	5.32	4.20	0.79	953	5.26	4.16	0.79	985	5.19	4.10	0.79	1028	5.10	4.03	0.79	1098	4.98	3.93	0.79	1149	4.84	3.82	0.79	1192	4.44	3.51	0.79	1267	3.66	2.89	0.79	1315	3.02	2.39	0.79	1366
	23	20	5.73	3.84	0.67	947	5.67	3.80	0.67	956	5.61	3.76	0.67	964	5.54	3.71	0.67	972	5.49	3.68	0.67	977	5.43	3.64	0.67	1009	5.35	3.58	0.67	1052	5.26	3.52	0.67	1122	5.13	3.44	0.67	1173	4.98	3.34	0.67	1216	4.57	3.06	0.67	1291	3.77	2.53	0.67	1339	3.11	2.09	0.67	1390
	23	22	5.83	3.21	0.55	964	5.77	3.17	0.55	972	5.71	3.14	0.55	981	5.63	3.10	0.55	988	5.58	3.07	0.55	993	5.52	3.03	0.55	1025	5.44	2.99	0.55	1069	5.35	2.94	0.55	1138	5.22	2.87	0.55	1189	5.07	2.79	0.55	1233	4.65	2.56	0.55	1307	3.84	2.11	0.55	1356	3.17	1.74	0.55	1406
	24	18	5.67	4.71	0.83	933	5.62	4.66	0.83	941	5.56	4.61	0.83	950	5.49	4.55	0.83	958	5.43	4.51	0.83	963	5.37	4.46	0.83	995	5.30	4.40	0.83	1039	5.20	4.32	0.83	1109	5.08	4.22	0.83	1161	4.93	4.10	0.83	1204	4.53	3.76	0.83	1280	3.74	3.10	0.83	1329	3.08	2.56	0.83	1380
	24	20	5.85	4.15	0.71	957	5.79	4.11	0.71	966	5.73	4.07	0.71	974	5.65	4.01	0.71	982	5.60	3.97	0.71	987	5.54	3.93	0.71	1019	5.46	3.88	0.71	1063	5.36	3.81	0.71	1133	5.24	3.72	0.71	1185	5.08	3.61	0.71	1229	4.67	3.31	0.71	1304	3.85	2.73	0.71	1353	3.18	2.26	0.71	1404
	24	22	5.95	3.51	0.59	974	5.89	3.47	0.59	982	5.82	3.44	0.59	991	5.75	3.39	0.59	998	5.69	3.36	0.59	1003	5.63	3.32	0.59	1035	5.55	3.28	0.59	1079	5.45	3.22	0.59	1150	5.33	3.14	0.59	1201	5.17	3.05	0.59	1245	4.75	2.80	0.59	1320	3.92	2.31	0.59	1369	3.23	1.91	0.59	1420
	24	24	6.03	2.83	0.47	993	5.97	2.81	0.47	1001	5.91	2.78	0.47	1010	5.83	2.74	0.47	1018	5.77	2.71	0.47	1023	5.71	2.68	0.47	1055	5.63	2.65	0.47	1099	5.53	2.60	0.47	1169	5.40	2.54	0.47	1221	5.24	2.46	0.47	1265	4.81	2.26	0.47	1340	3.97	1.87	0.47	1389	3.28	1.54	0.47	1440
	25	18	5.85	5.09	0.87	942	5.79	5.04	0.87	951	5.73	4.98	0.87	960	5.65	4.92	0.87	967	5.60	4.87	0.87	972	5.54	4.82	0.87	1005	5.46	4.75	0.87	1049	5.36	4.67	0.87	1120	5.24	4.56	0.87	1172	5.09	4.43	0.87	1217	4.67	4.06	0.87	1293	3.85	3.35	0.87	1342	3.18	2.76	0.87	1394
	25	20	6.03	4.52	0.75	967	5.97	4.48	0.75	975	5.90	4.43	0.75	984	5.83	4.37	0.75	992	5.77	4.33	0.75	997	5.71	4.28	0.75	1029	5.63	4.22	0.75	1074	5.53	4.15	0.75	1145	5.40	4.05	0.75	1197	5.24	3.93	0.75	1241	4.81	3.61	0.75	1317	3.97	2.98	0.75	1367	3.28	2.46	0.75	1418
	25	22	6.13	3.86	0.63	983	6.07	3.82	0.63	992	6.00	3.78	0.63	1001	5.93	3.73	0.63	1009	5.87	3.70	0.63	1013	5.80	3.66	0.63	1046	5.72	3.61	0.63	1090	5.62	3.54	0.63	1162	5.49	3.46	0.63	1214	5.33	3.36	0.63	1258	4.89	3.08	0.63	1334	4.04	2.54	0.63	1383	3.33	2.10	0.63	1435
	25	24	6.22	3.17	0.51	1003	6.15	3.14	0.51	1012	6.09	3.10	0.51	1020	6.01	3.07	0.51	1028	5.95	3.03	0.51	1033	5.89	3.00	0.51	1066	5.80	2.96	0.51	1110	5.70	2.91	0.51	1181	5.57	2.84	0.51	1233	5.41	2.76	0.51	1277	4.96	2.53	0.51	1353	4.09	2.09	0.51	1403	3.38	1.72	0.51	1454
	26	18	6.03	5.49	0.91	952	5.97	5.43	0.91	960	5.91	5.37	0.91	969	5.83	5.30	0.91	977	5.77	5.25	0.91	982	5.71	5.20	0.91	1015	5.63	5.12	0.91	1060	5.53	5.03	0.91	1132	5.40	4.91	0.91	1184	5.24	4.77	0.91	1229	4.81	4.38	0.91	1306	3.97	3.61	0.91	1356	3.28	2.98	0.91	1408
	26	20	6.21	4.91	0.79	976	6.15	4.86	0.79	985	6.09	4.81	0.79	994	6.01	4.75	0.79	1002	5.95	4.70	0.79	1007	5.88	4.65	0.79	1040	5.80	4.58	0.79	1085	5.70	4.50	0.79	1157	5.57	4.40	0.79	1209	5.40	4.27</														

4. CAPACITIES AND SELECTION DATA

				Cooling Operation PERFORMANCE DATA																																																		
				OUTDOOR DB (°C)																																																		
COMBINATION (%)	IDDB (°C)	ID WB (°C)	-15				-7				0				10				15				21				25				27				30				35				40				45				50			
			Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT								
110%	21	18	5.18	3.68	0.71	896	5.13	3.64	0.71	904	5.08	3.61	0.71	913	5.01	3.56	0.71	920	4.96	3.52	0.71	925	4.91	3.49	0.71	956	4.84	3.44	0.71	998	4.76	3.38	0.71	1066	4.64	3.30	0.71	1115	4.51	3.20	0.71	1157	4.14	2.94	0.71	1230	3.41	2.42	0.71	1277	2.82	2.00	0.71	1326
	21	20	5.40	3.19	0.59	920	5.35	3.15	0.59	928	5.29	3.12	0.59	936	5.22	3.08	0.59	944	5.17	3.05	0.59	948	5.11	3.02	0.59	979	5.04	2.97	0.59	1022	4.95	2.92	0.59	1089	4.84	2.85	0.59	1139	4.69	2.77	0.59	1181	4.31	2.54	0.59	1253	3.56	2.10	0.59	1300	2.93	1.73	0.59	1349
	22	18	5.35	4.01	0.75	905	5.29	3.97	0.75	914	5.23	3.93	0.75	922	5.17	3.88	0.75	929	5.12	3.84	0.75	934	5.06	3.80	0.75	965	4.99	3.74	0.75	1008	4.90	3.68	0.75	1077	4.79	3.59	0.75	1127	4.65	3.49	0.75	1169	4.27	3.20	0.75	1242	3.52	2.64	0.75	1290	2.90	2.18	0.75	1339
	22	20	5.51	3.47	0.63	929	5.45	3.44	0.63	937	5.39	3.40	0.63	946	5.33	3.36	0.63	953	5.27	3.32	0.63	958	5.22	3.29	0.63	989	5.14	3.24	0.63	1032	5.05	3.18	0.63	1100	4.93	3.11	0.63	1150	4.79	3.02	0.63	1193	4.40	2.77	0.63	1266	3.63	2.29	0.63	1313	2.99	1.89	0.63	1363
	22	22	5.60	2.86	0.51	945	5.55	2.83	0.51	954	5.49	2.80	0.51	962	5.42	2.76	0.51	969	5.36	2.73	0.51	974	5.30	2.71	0.51	1005	5.23	2.67	0.51	1048	5.14	2.62	0.51	1117	5.02	2.56	0.51	1166	4.87	2.48	0.51	1209	4.47	2.28	0.51	1282	3.69	1.88	0.51	1330	3.04	1.55	0.51	1379
	23	18	5.45	4.31	0.79	914	5.40	4.27	0.79	923	5.34	4.22	0.79	931	5.27	4.17	0.79	939	5.22	4.12	0.79	944	5.16	4.08	0.79	975	5.09	4.02	0.79	1018	5.00	3.95	0.79	1087	4.89	3.86	0.79	1138	4.74	3.75	0.79	1181	4.35	3.44	0.79	1255	3.59	2.84	0.79	1303	2.96	2.34	0.79	1352
	23	20	5.62	3.77	0.67	938	5.57	3.73	0.67	947	5.51	3.69	0.67	955	5.43	3.64	0.67	963	5.38	3.61	0.67	968	5.32	3.57	0.67	999	5.25	3.52	0.67	1042	5.16	3.45	0.67	1111	5.03	3.37	0.67	1162	4.89	3.28	0.67	1205	4.49	3.01	0.67	1279	3.70	2.48	0.67	1327	3.05	2.05	0.67	1377
	23	22	5.72	3.14	0.55	955	5.66	3.11	0.55	963	5.60	3.08	0.55	972	5.53	3.04	0.55	979	5.47	3.01	0.55	984	5.41	2.98	0.55	1016	5.34	2.94	0.55	1059	5.24	2.88	0.55	1128	5.12	2.82	0.55	1178	4.97	2.73	0.55	1221	4.56	2.51	0.55	1295	3.77	2.07	0.55	1343	3.11	1.71	0.55	1393
	24	18	5.57	4.62	0.83	924	5.51	4.57	0.83	932	5.45	4.52	0.83	941	5.38	4.47	0.83	948	5.33	4.42	0.83	953	5.27	4.37	0.83	985	5.20	4.31	0.83	1029	5.10	4.24	0.83	1098	4.99	4.14	0.83	1149	4.84	4.02	0.83	1193	4.44	3.69	0.83	1267	3.67	3.04	0.83	1316	3.02	2.51	0.83	1366
	24	20	5.74	4.07	0.71	948	5.68	4.03	0.71	956	5.62	3.99	0.71	965	5.55	3.94	0.71	973	5.49	3.90	0.71	977	5.43	3.86	0.71	1009	5.36	3.80	0.71	1053	5.26	3.74	0.71	1123	5.14	3.65	0.71	1174	4.99	3.54	0.71	1217	4.58	3.25	0.71	1292	3.78	2.68	0.71	1340	3.12	2.21	0.71	1390
	24	22	5.83	3.44	0.59	964	5.78	3.41	0.59	973	5.71	3.37	0.59	981	5.64	3.33	0.59	989	5.58	3.29	0.59	994	5.52	3.26	0.59	1026	5.45	3.21	0.59	1069	5.35	3.16	0.59	1139	5.23	3.08	0.59	1190	5.07	2.99	0.59	1233	4.66	2.75	0.59	1308	3.84	2.27	0.59	1357	3.17	1.87	0.59	1407
	24	24	5.92	2.78	0.47	984	5.86	2.75	0.47	992	5.79	2.72	0.47	1001	5.72	2.69	0.47	1009	5.66	2.66	0.47	1013	5.60	2.63	0.47	1045	5.52	2.60	0.47	1089	5.43	2.55	0.47	1159	5.30	2.49	0.47	1210	5.14	2.42	0.47	1253	4.72	2.22	0.47	1327	3.90	1.83	0.47	1376	3.21	1.51	0.47	1426
	25	18	5.74	4.99	0.87	933	5.68	4.94	0.87	942	5.62	4.89	0.87	950	5.55	4.83	0.87	958	5.49	4.78	0.87	963	5.43	4.73	0.87	995	5.36	4.66	0.87	1039	5.26	4.58	0.87	1110	5.14	4.47	0.87	1161	4.99	4.34	0.87	1205	4.58	3.98	0.87	1280	3.78	3.29	0.87	1329	3.12	2.71	0.87	1380
	25	20	5.91	4.44	0.75	957	5.85	4.39	0.75	966	5.79	4.34	0.75	975	5.72	4.29	0.75	982	5.66	4.25	0.75	987	5.60	4.20	0.75	1019	5.52	4.14	0.75	1064	5.42	4.07	0.75	1134	5.30	3.97	0.75	1186	5.14	3.86	0.75	1229	4.72	3.54	0.75	1305	3.89	2.92	0.75	1354	3.21	2.41	0.75	1404
	25	22	6.01	3.79	0.63	974	5.95	3.75	0.63	983	5.89	3.71	0.63	991	5.81	3.66	0.63	999	5.76	3.63	0.63	1004	5.69	3.59	0.63	1036	5.62	3.54	0.63	1080	5.52	3.48	0.63	1151	5.39	3.39	0.63	1202	5.23	3.29	0.63	1246	4.80	3.02	0.63	1321	3.96	2.50	0.63	1370	3.27	2.06	0.63	1421
	25	24	6.10	3.11	0.51	994	6.04	3.08	0.51	1002	5.97	3.05	0.51	1011	5.90	3.01	0.51	1019	5.84	2.98	0.51	1024	5.77	2.94	0.51	1056	5.69	2.90	0.51	1100	5.59	2.85	0.51	1170	5.46	2.79	0.51	1222	5.30	2.70	0.51	1266	4.87	2.48	0.51	1341	4.02	2.05	0.51	1390	3.31	1.69	0.51	1441
	26	18	5.92	5.38	0.91	942	5.86	5.33	0.91	951	5.79	5.27	0.91	960	5.72	5.20	0.91	968	5.66	5.15	0.91	973	5.60	5.10	0.91	1005	5.52	5.03	0.91	1049	5.43	4.94	0.91	1121	5.30	4.82	0.91	1173	5.14	4.68	0.91	1217	4.72	4.30	0.91	1293	3.90	3.55	0.91	1343	3.21	2.92	0.91	1394
	26	20	6.10	4.82	0.79	967	6.04	4.77	0.79	976	5.97	4.72	0.79	985	5.89	4.66	0.79	992	5.84	4.61	0.79	997	5.77	4.56	0.79	1030	5.69	4.50	0.79	1074	5.59	4.42	0.79	1145	5.46	4.31	0.79	1198	5.30	4.19	0.79	1241												

4. CAPACITIES AND SELECTION DATA

	Cooling Operation PERFORMANCE DATA																																																					
	OUTDOOR DB (°C)																																																					
COMBINATION (%)	IDDB (°C)	ID WB (°C)	-15				-7				0				10				15				21				25				27				30				35				40				45				50			
			Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT												
100%	21	18	5.03	3.57	0.71	874	4.98	3.54	0.71	882	4.93	3.50	0.71	890	4.87	3.46	0.71	898	4.82	3.42	0.71	902	4.77	3.38	0.71	932	4.70	3.34	0.71	973	4.62	3.28	0.71	1040	4.51	3.20	0.71	1088	4.38	3.11	0.71	1129	4.02	2.85	0.71	1199	3.32	2.35	0.71	1245	2.74	1.94	0.71	1293
	21	20	5.24	3.09	0.59	898	5.19	3.06	0.59	906	5.13	3.03	0.59	914	5.07	2.99	0.59	921	5.02	2.96	0.59	926	4.96	2.93	0.59	956	4.89	2.89	0.59	997	4.81	2.84	0.59	1063	4.69	2.77	0.59	1111	4.56	2.69	0.59	1152	4.18	2.47	0.59	1223	3.45	2.04	0.59	1269	2.85	1.68	0.59	1317
	22	18	5.19	3.89	0.75	883	5.14	3.85	0.75	891	5.08	3.81	0.75	899	5.02	3.76	0.75	907	4.97	3.73	0.75	911	4.91	3.68	0.75	942	4.85	3.63	0.75	983	4.76	3.57	0.75	1050	4.65	3.49	0.75	1099	4.51	3.38	0.75	1140	4.14	3.11	0.75	1212	3.42	2.56	0.75	1258	2.82	2.11	0.75	1306
	22	20	5.35	3.37	0.63	907	5.30	3.34	0.63	915	5.24	3.30	0.63	923	5.17	3.26	0.63	930	5.12	3.23	0.63	935	5.06	3.19	0.63	965	4.99	3.15	0.63	1007	4.91	3.09	0.63	1074	4.79	3.02	0.63	1123	4.65	2.93	0.63	1164	4.27	2.69	0.63	1235	3.52	2.22	0.63	1282	2.91	1.83	0.63	1330
	22	22	5.44	2.77	0.51	923	5.39	2.75	0.51	931	5.33	2.72	0.51	939	5.26	2.68	0.51	947	5.21	2.66	0.51	951	5.15	2.63	0.51	982	5.08	2.59	0.51	1023	4.99	2.54	0.51	1090	4.87	2.48	0.51	1139	4.73	2.41	0.51	1180	4.34	2.21	0.51	1251	3.58	1.83	0.51	1298	2.96	1.51	0.51	1346
	23	18	5.30	4.18	0.79	892	5.24	4.14	0.79	900	5.19	4.10	0.79	908	5.12	4.04	0.79	916	5.07	4.00	0.79	920	5.01	3.96	0.79	951	4.94	3.91	0.79	993	4.86	3.84	0.79	1061	4.74	3.75	0.79	1110	4.60	3.64	0.79	1152	4.23	3.34	0.79	1224	3.49	2.76	0.79	1271	2.88	2.27	0.79	1319
	23	20	5.46	3.66	0.67	916	5.40	3.62	0.67	924	5.34	3.58	0.67	932	5.28	3.54	0.67	940	5.22	3.50	0.67	944	5.17	3.46	0.67	975	5.10	3.41	0.67	1017	5.01	3.35	0.67	1085	4.89	3.28	0.67	1134	4.75	3.18	0.67	1176	4.36	2.92	0.67	1248	3.59	2.41	0.67	1295	2.97	1.99	0.67	1343
	23	22	5.55	3.05	0.55	932	5.50	3.02	0.55	940	5.44	2.99	0.55	949	5.37	2.95	0.55	956	5.31	2.92	0.55	961	5.25	2.89	0.55	991	5.18	2.85	0.55	1034	5.09	2.80	0.55	1101	4.97	2.73	0.55	1150	4.83	2.65	0.55	1192	4.43	2.44	0.55	1264	3.66	2.01	0.55	1311	3.02	1.66	0.55	1360
	24	18	5.40	4.48	0.83	901	5.35	4.44	0.83	909	5.29	4.39	0.83	918	5.22	4.34	0.83	925	5.17	4.29	0.83	930	5.12	4.25	0.83	961	5.05	4.19	0.83	1003	4.96	4.11	0.83	1071	4.84	4.02	0.83	1121	4.70	3.90	0.83	1163	4.31	3.58	0.83	1236	3.56	2.95	0.83	1283	2.94	2.44	0.83	1333
	24	20	5.57	3.95	0.71	925	5.51	3.91	0.71	933	5.45	3.87	0.71	942	5.38	3.82	0.71	949	5.33	3.78	0.71	954	5.27	3.74	0.71	985	5.20	3.69	0.71	1028	5.11	3.63	0.71	1096	4.99	3.54	0.71	1145	4.84	3.44	0.71	1188	4.45	3.16	0.71	1260	3.67	2.60	0.71	1308	3.03	2.15	0.71	1357
	24	22	5.66	3.34	0.59	942	5.61	3.31	0.59	950	5.55	3.27	0.59	958	5.48	3.23	0.59	966	5.42	3.20	0.59	970	5.36	3.16	0.59	1001	5.29	3.12	0.59	1044	5.19	3.06	0.59	1112	5.07	2.99	0.59	1162	4.93	2.91	0.59	1204	4.52	2.67	0.59	1277	3.73	2.20	0.59	1324	3.08	1.82	0.59	1373
	24	24	5.74	2.70	0.47	961	5.69	2.67	0.47	969	5.62	2.64	0.47	978	5.55	2.61	0.47	985	5.50	2.58	0.47	990	5.44	2.56	0.47	1021	5.36	2.52	0.47	1063	5.27	2.48	0.47	1132	5.14	2.42	0.47	1181	4.99	2.35	0.47	1224	4.58	2.15	0.47	1296	3.78	1.78	0.47	1344	3.12	1.47	0.47	1393
	25	18	5.57	4.85	0.87	910	5.52	4.80	0.87	918	5.46	4.75	0.87	927	5.39	4.69	0.87	934	5.33	4.64	0.87	939	5.27	4.59	0.87	970	5.20	4.53	0.87	1013	5.11	4.45	0.87	1082	4.99	4.34	0.87	1132	4.84	4.21	0.87	1175	4.45	3.87	0.87	1249	3.67	3.19	0.87	1296	3.03	2.63	0.87	1346
	25	20	5.74	4.31	0.75	935	5.68	4.26	0.75	943	5.62	4.22	0.75	951	5.55	4.16	0.75	959	5.50	4.12	0.75	964	5.44	4.08	0.75	995	5.36	4.02	0.75	1038	5.27	3.95	0.75	1107	5.14	3.86	0.75	1157	4.99	3.74	0.75	1200	4.58	3.44	0.75	1273	3.78	2.84	0.75	1321	3.12	2.34	0.75	1371
	25	22	5.84	3.68	0.63	951	5.78	3.64	0.63	960	5.72	3.60	0.63	968	5.64	3.56	0.63	976	5.59	3.52	0.63	980	5.53	3.48	0.63	1012	5.45	3.43	0.63	1055	5.36	3.37	0.63	1123	5.23	3.29	0.63	1174	5.08	3.20	0.63	1216	4.66	2.94	0.63	1290	3.85	2.42	0.63	1338	3.17	2.00	0.63	1387
	25	24	5.92	3.02	0.51	971	5.86	2.99	0.51	979	5.80	2.96	0.51	988	5.72	2.92	0.51	995	5.67	2.89	0.51	1000	5.61	2.86	0.51	1031	5.53	2.82	0.51	1074	5.43	2.77	0.51	1143	5.30	2.70	0.51	1193	5.15	2.63	0.51	1236	4.73	2.41	0.51	1309	3.90	1.99	0.51	1357	3.22	1.64	0.51	1407
	26	18	5.74	5.23	0.91	919	5.69	5.17	0.91	928	5.62	5.12	0.91	936	5.55	5.05	0.91	944	5.50	5.00	0.91	949	5.44	4.95	0.91	980	5.36	4.88	0.91	1024	5.27	4.79	0.91	1093	5.14	4.68	0.91	1144	4.99	4.54	0.91	1187	4.58	4.17	0.91	1261	3.78	3.44	0.91	1310	3.12	2.84	0.91	1360
	26	20	5.92	4.68	0.79	944	5.86	4.63	0.79	952	5.80	4.58	0.79	961	5.72	4.52	0.79	969	5.67	4.48	0.79	973	5.60																															

4. CAPACITIES AND SELECTION DATA

	Cooling Operation PERFORMANCE DATA																																																					
	OUTDOOR DB (°C)																																																					
COMBINATION (%)	IDDB (°C)	ID WB (°C)	-15				-7				0				10				15				21				25				27				30				35				40				45				50			
			Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT												
90%	21	18	4.93	3.50	0.71	865	4.88	3.47	0.71	873	4.83	3.43	0.71	881	4.77	3.39	0.71	888	4.72	3.35	0.71	893	4.67	3.32	0.71	923	4.61	3.27	0.71	964	4.52	3.21	0.71	1029	4.42	3.14	0.71	1077	4.29	3.05	0.71	1117	3.94	2.80	0.71	1187	3.25	2.31	0.71	1233	2.68	1.90	0.71	1280
	21	20	5.14	3.03	0.59	889	5.09	3.00	0.59	897	5.03	2.97	0.59	905	4.97	2.93	0.59	912	4.92	2.90	0.59	916	4.86	2.87	0.59	946	4.80	2.83	0.59	987	4.71	2.78	0.59	1053	4.60	2.71	0.59	1100	4.47	2.64	0.59	1141	4.10	2.42	0.59	1211	3.38	2.00	0.59	1256	2.79	1.65	0.59	1304
	22	18	5.09	3.81	0.75	874	5.04	3.78	0.75	882	4.98	3.74	0.75	890	4.92	3.69	0.75	897	4.87	3.65	0.75	902	4.82	3.61	0.75	932	4.75	3.56	0.75	973	4.66	3.50	0.75	1039	4.56	3.42	0.75	1088	4.42	3.32	0.75	1129	4.06	3.04	0.75	1199	3.35	2.51	0.75	1245	2.76	2.07	0.75	1293
	22	20	5.24	3.30	0.63	898	5.19	3.27	0.63	906	5.13	3.23	0.63	914	5.07	3.19	0.63	921	5.02	3.16	0.63	926	4.96	3.13	0.63	956	4.89	3.08	0.63	997	4.81	3.03	0.63	1063	4.69	2.96	0.63	1112	4.56	2.87	0.63	1153	4.18	2.64	0.63	1223	3.45	2.17	0.63	1269	2.85	1.79	0.63	1317
	22	22	5.33	2.72	0.51	914	5.28	2.69	0.51	922	5.22	2.66	0.51	930	5.15	2.63	0.51	937	5.10	2.60	0.51	942	5.05	2.57	0.51	972	4.98	2.54	0.51	1013	4.89	2.49	0.51	1079	4.77	2.44	0.51	1128	4.64	2.36	0.51	1169	4.26	2.17	0.51	1239	3.51	1.79	0.51	1285	2.90	1.48	0.51	1333
	23	18	5.19	4.10	0.79	883	5.14	4.06	0.79	891	5.08	4.01	0.79	899	5.02	3.96	0.79	906	4.97	3.92	0.79	911	4.91	3.88	0.79	942	4.85	3.83	0.79	983	4.76	3.76	0.79	1050	4.65	3.67	0.79	1099	4.51	3.57	0.79	1140	4.14	3.27	0.79	1211	3.42	2.70	0.79	1258	2.82	2.23	0.79	1306
	23	20	5.35	3.58	0.67	907	5.30	3.55	0.67	915	5.24	3.51	0.67	923	5.17	3.46	0.67	931	5.12	3.43	0.67	935	5.06	3.39	0.67	966	4.99	3.35	0.67	1007	4.91	3.29	0.67	1074	4.79	3.21	0.67	1123	4.65	3.12	0.67	1164	4.27	2.86	0.67	1235	3.52	2.36	0.67	1282	2.91	1.95	0.67	1330
	23	22	5.44	2.99	0.55	923	5.39	2.96	0.55	931	5.33	2.93	0.55	940	5.26	2.89	0.55	947	5.21	2.86	0.55	951	5.15	2.83	0.55	982	5.08	2.79	0.55	1024	4.99	2.74	0.55	1090	4.87	2.68	0.55	1139	4.73	2.60	0.55	1180	4.34	2.39	0.55	1252	3.58	1.97	0.55	1298	2.96	1.63	0.55	1346
	24	18	5.30	4.40	0.83	892	5.24	4.35	0.83	900	5.19	4.30	0.83	908	5.12	4.25	0.83	916	5.07	4.21	0.83	920	5.01	4.16	0.83	951	4.94	4.10	0.83	993	4.86	4.03	0.83	1061	4.74	3.94	0.83	1110	4.60	3.82	0.83	1152	4.23	3.51	0.83	1224	3.49	2.89	0.83	1271	2.88	2.39	0.83	1319
	24	20	5.46	3.87	0.71	916	5.40	3.84	0.71	924	5.34	3.79	0.71	933	5.28	3.75	0.71	940	5.22	3.71	0.71	945	5.17	3.67	0.71	975	5.10	3.62	0.71	1017	5.01	3.55	0.71	1085	4.89	3.47	0.71	1134	4.75	3.37	0.71	1176	4.36	3.09	0.71	1248	3.59	2.55	0.71	1295	2.97	2.11	0.71	1343
	24	22	5.55	3.27	0.59	933	5.50	3.24	0.59	941	5.44	3.21	0.59	949	5.37	3.17	0.59	956	5.31	3.13	0.59	961	5.25	3.10	0.59	992	5.18	3.06	0.59	1034	5.09	3.00	0.59	1101	4.97	2.93	0.59	1151	4.83	2.85	0.59	1192	4.43	2.61	0.59	1264	3.66	2.16	0.59	1311	3.02	1.78	0.59	1360
	24	24	5.63	2.65	0.47	952	5.57	2.62	0.47	960	5.51	2.59	0.47	968	5.44	2.56	0.47	976	5.39	2.53	0.47	980	5.33	2.50	0.47	1011	5.25	2.47	0.47	1053	5.16	2.43	0.47	1121	5.04	2.37	0.47	1170	4.89	2.30	0.47	1212	4.49	2.11	0.47	1284	3.71	1.74	0.47	1331	3.06	1.44	0.47	1379
	25	18	5.46	4.75	0.87	901	5.41	4.70	0.87	909	5.35	4.65	0.87	917	5.28	4.59	0.87	925	5.23	4.55	0.87	930	5.17	4.50	0.87	961	5.10	4.43	0.87	1003	5.01	4.36	0.87	1071	4.89	4.25	0.87	1121	4.75	4.13	0.87	1163	4.36	3.79	0.87	1236	3.60	3.13	0.87	1283	2.97	2.58	0.87	1333
	25	20	5.63	4.22	0.75	925	5.57	4.18	0.75	934	5.51	4.13	0.75	942	5.44	4.08	0.75	949	5.39	4.04	0.75	954	5.33	4.00	0.75	985	5.25	3.94	0.75	1028	5.16	3.87	0.75	1096	5.04	3.78	0.75	1146	4.89	3.67	0.75	1188	4.49	3.37	0.75	1261	3.71	2.78	0.75	1308	3.06	2.29	0.75	1357
	25	22	5.72	3.60	0.63	942	5.67	3.57	0.63	950	5.60	3.53	0.63	959	5.53	3.49	0.63	966	5.48	3.45	0.63	971	5.42	3.41	0.63	1002	5.34	3.37	0.63	1044	5.25	3.31	0.63	1112	5.13	3.23	0.63	1162	4.98	3.13	0.63	1204	4.57	2.88	0.63	1277	3.77	2.37	0.63	1325	3.11	1.96	0.63	1374
	25	24	5.80	2.96	0.51	962	5.74	2.93	0.51	970	5.68	2.90	0.51	978	5.61	2.86	0.51	986	5.55	2.83	0.51	990	5.49	2.80	0.51	1021	5.42	2.76	0.51	1064	5.32	2.71	0.51	1132	5.20	2.65	0.51	1182	5.05	2.57	0.51	1224	4.63	2.36	0.51	1297	3.82	1.95	0.51	1344	3.15	1.61	0.51	1393
	26	18	5.63	5.12	0.91	910	5.57	5.07	0.91	918	5.51	5.02	0.91	927	5.44	4.95	0.91	934	5.39	4.90	0.91	939	5.33	4.85	0.91	970	5.25	4.78	0.91	1013	5.16	4.70	0.91	1082	5.04	4.59	0.91	1132	4.89	4.45	0.91	1175	4.49	4.09	0.91	1249	3.71	3.37	0.91	1296	3.06	2.78	0.91	1346
	26	20	5.80	4.58	0.79	935	5.74	4.54	0.79	943	5.68	4.49	0.79	951	5.61	4.43	0.79	959	5.55	4.39	0.79	964	5.49	4																														

4. CAPACITIES AND SELECTION DATA

				Cooling Operation PERFORMANCE DATA																																																		
				OUTDOOR DB (°C)																																																		
COMBINATION (%)	IDDB (°C)	ID WB (°C)	-15				-7				0				10				15				21				25				27				30				35				40				45				50			
			Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT								
80%	21	18	4.78	3.40	0.71	856	4.73	3.36	0.71	864	4.68	3.33	0.71	872	4.62	3.28	0.71	879	4.58	3.25	0.71	884	4.53	3.21	0.71	913	4.47	3.17	0.71	954	4.39	3.11	0.71	1019	4.28	3.04	0.71	1066	4.16	2.95	0.71	1106	3.82	2.71	0.71	1175	3.15	2.24	0.71	1220	2.60	1.84	0.71	1267
	21	20	4.98	2.94	0.59	880	4.93	2.91	0.59	888	4.88	2.88	0.59	896	4.81	2.84	0.59	903	4.77	2.81	0.59	907	4.71	2.78	0.59	937	4.65	2.74	0.59	977	4.57	2.69	0.59	1042	4.46	2.63	0.59	1089	4.33	2.55	0.59	1130	3.98	2.35	0.59	1199	3.28	1.93	0.59	1244	2.71	1.60	0.59	1291
	22	18	4.93	3.70	0.75	865	4.88	3.66	0.75	873	4.83	3.62	0.75	881	4.77	3.57	0.75	888	4.72	3.54	0.75	893	4.67	3.50	0.75	923	4.60	3.45	0.75	963	4.52	3.39	0.75	1029	4.42	3.31	0.75	1077	4.29	3.22	0.75	1117	3.94	2.95	0.75	1187	3.25	2.44	0.75	1233	2.68	2.01	0.75	1280
	22	20	5.08	3.20	0.63	889	5.03	3.17	0.63	897	4.98	3.13	0.63	905	4.91	3.09	0.63	912	4.86	3.06	0.63	917	4.81	3.03	0.63	946	4.74	2.99	0.63	987	4.66	2.94	0.63	1053	4.55	2.87	0.63	1100	4.42	2.78	0.63	1141	4.06	2.56	0.63	1211	3.35	2.11	0.63	1256	2.76	1.74	0.63	1304
	22	22	5.17	2.64	0.51	905	5.12	2.61	0.51	913	5.06	2.58	0.51	921	5.00	2.55	0.51	928	4.95	2.52	0.51	933	4.89	2.50	0.51	963	4.82	2.46	0.51	1003	4.74	2.42	0.51	1069	4.63	2.36	0.51	1117	4.49	2.29	0.51	1157	4.13	2.10	0.51	1227	3.40	1.74	0.51	1273	2.81	1.43	0.51	1320
	23	18	5.03	3.97	0.79	874	4.98	3.93	0.79	882	4.93	3.89	0.79	890	4.86	3.84	0.79	897	4.82	3.80	0.79	902	4.76	3.76	0.79	932	4.70	3.71	0.79	973	4.61	3.65	0.79	1039	4.51	3.56	0.79	1088	4.37	3.46	0.79	1129	4.02	3.17	0.79	1199	3.31	2.62	0.79	1245	2.73	2.16	0.79	1293
	23	20	5.18	3.47	0.67	898	5.13	3.44	0.67	906	5.08	3.40	0.67	914	5.01	3.36	0.67	921	4.96	3.33	0.67	926	4.91	3.29	0.67	956	4.84	3.24	0.67	997	4.76	3.19	0.67	1063	4.64	3.11	0.67	1112	4.51	3.02	0.67	1153	4.14	2.77	0.67	1223	3.41	2.29	0.67	1269	2.82	1.89	0.67	1317
	23	22	5.27	2.90	0.55	914	5.22	2.87	0.55	922	5.16	2.84	0.55	930	5.10	2.80	0.55	938	5.05	2.78	0.55	942	4.99	2.75	0.55	972	4.92	2.71	0.55	1014	4.84	2.66	0.55	1080	4.72	2.60	0.55	1128	4.59	2.52	0.55	1169	4.21	2.32	0.55	1239	3.47	1.91	0.55	1285	2.86	1.58	0.55	1333
	24	18	5.13	4.26	0.83	883	5.08	4.22	0.83	891	5.03	4.17	0.83	899	4.96	4.12	0.83	906	4.91	4.08	0.83	911	4.86	4.03	0.83	941	4.79	3.98	0.83	983	4.71	3.91	0.83	1050	4.60	3.82	0.83	1099	4.46	3.71	0.83	1140	4.10	3.40	0.83	1211	3.38	2.81	0.83	1258	2.79	2.32	0.83	1306
	24	20	5.29	3.76	0.71	907	5.24	3.72	0.71	915	5.18	3.68	0.71	923	5.11	3.63	0.71	931	5.06	3.60	0.71	935	5.01	3.56	0.71	966	4.94	3.51	0.71	1007	4.85	3.45	0.71	1074	4.74	3.36	0.71	1123	4.60	3.27	0.71	1164	4.22	3.00	0.71	1235	3.48	2.47	0.71	1282	2.87	2.04	0.71	1330
	24	22	5.38	3.17	0.59	923	5.33	3.14	0.59	932	5.27	3.11	0.59	940	5.20	3.07	0.59	947	5.15	3.04	0.59	952	5.09	3.01	0.59	982	5.02	2.96	0.59	1024	4.93	2.91	0.59	1091	4.82	2.84	0.59	1139	4.68	2.76	0.59	1181	4.30	2.53	0.59	1252	3.54	2.09	0.59	1298	2.92	1.72	0.59	1347
	24	24	5.46	2.56	0.47	943	5.40	2.54	0.47	951	5.34	2.51	0.47	959	5.27	2.48	0.47	966	5.22	2.45	0.47	971	5.17	2.43	0.47	1001	5.09	2.39	0.47	1043	5.00	2.35	0.47	1110	4.89	2.30	0.47	1159	4.74	2.23	0.47	1200	4.36	2.05	0.47	1271	3.59	1.69	0.47	1318	2.96	1.39	0.47	1366
	25	18	5.29	4.60	0.87	892	5.24	4.56	0.87	900	5.18	4.51	0.87	908	5.12	4.45	0.87	915	5.07	4.41	0.87	920	5.01	4.36	0.87	951	4.94	4.30	0.87	993	4.85	4.22	0.87	1060	4.74	4.12	0.87	1110	4.60	4.00	0.87	1151	4.22	3.68	0.87	1223	3.49	3.03	0.87	1270	2.88	2.50	0.87	1319
	25	20	5.45	4.09	0.75	916	5.40	4.05	0.75	924	5.34	4.01	0.75	933	5.27	3.95	0.75	940	5.22	3.92	0.75	945	5.16	3.87	0.75	975	5.09	3.82	0.75	1017	5.00	3.75	0.75	1085	4.89	3.66	0.75	1134	4.74	3.56	0.75	1176	4.35	3.27	0.75	1248	3.59	2.69	0.75	1295	2.96	2.22	0.75	1343
	25	22	5.55	3.49	0.63	933	5.49	3.46	0.63	941	5.43	3.42	0.63	949	5.36	3.38	0.63	957	5.31	3.34	0.63	961	5.25	3.31	0.63	992	5.18	3.26	0.63	1034	5.09	3.21	0.63	1102	4.97	3.13	0.63	1151	4.82	3.04	0.63	1193	4.43	2.79	0.63	1265	3.65	2.30	0.63	1311	3.01	1.90	0.63	1360
	25	24	5.62	2.87	0.51	952	5.57	2.84	0.51	961	5.51	2.81	0.51	969	5.44	2.77	0.51	976	5.38	2.75	0.51	981	5.33	2.72	0.51	1012	5.25	2.68	0.51	1054	5.16	2.63	0.51	1121	5.04	2.57	0.51	1170	4.89	2.49	0.51	1212	4.49	2.29	0.51	1284	3.70	1.89	0.51	1331	3.06	1.56	0.51	1380
	26	18	5.46	4.96	0.91	901	5.40	4.92	0.91	909	5.34	4.86	0.91	917	5.27	4.80	0.91	925	5.22	4.75	0.91	929	5.17	4.70	0.91	960	5.09	4.64	0.91	1003	5.00	4.55	0.91	1071	4.89	4.45	0.91	1121	4.74	4.32	0.91	1163	4.36	3.96	0.91	1236	3.59	3.27	0.91	1283	2.96	2.70	0.91	1332
	26	20	5.62	4.44	0.79	925	5.57	4.40	0.79	934	5.51	4.35	0.79	942	5.44	4.29	0.79	949	5.38	4.25	0.79	954	5.32	4.21	0.79	985	5.25	4.15	0.79	1028	5.16	4.07	0.79	1096	5.04	3.98	0.79	1146	4.89	3.86	0.79	1188	4.49	3.										

4. CAPACITIES AND SELECTION DATA

18K(Up to 3 indoor units series)

HEATING PERFORMANCE DATA

COMBINATION (%)	INDOOR DB(°C)	OUTDOOR WB(°C)															
		-15		-10		-5		0		5		10		15		20	
		Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT
100%	15	3.97	1272	4.67	1312	5.19	1325	5.70	1352	6.20	1423	6.69	1494	7.03	1539	7.24	1570
	16	3.92	1283	4.61	1322	5.13	1336	5.63	1363	6.12	1435	6.61	1507	6.94	1552	7.15	1583
	17	3.88	1293	4.56	1333	5.07	1347	5.57	1374	6.05	1446	6.54	1519	6.86	1564	7.07	1596
	18	3.83	1304	4.51	1344	5.01	1357	5.50	1385	5.98	1458	6.46	1531	6.78	1577	6.98	1608
	19	3.78	1314	4.45	1355	4.95	1368	5.44	1396	5.91	1470	6.38	1543	6.70	1590	6.90	1621
	20	3.75	1325	4.41	1366	4.90	1379	5.38	1408	5.85	1482	6.32	1556	6.63	1602	6.83	1634
	21	3.70	1339	4.35	1381	4.84	1395	5.32	1423	5.78	1498	6.24	1573	6.55	1620	6.75	1652
	22	3.66	1354	4.30	1396	4.78	1410	5.25	1439	5.71	1514	6.17	1590	6.48	1638	6.67	1671
	23	3.61	1369	4.25	1411	4.72	1425	5.19	1455	5.64	1531	6.09	1608	6.40	1656	6.59	1689
	24	3.57	1384	4.20	1427	4.67	1441	5.13	1471	5.57	1548	6.02	1625	6.32	1674	6.51	1708
	25	3.53	1399	4.15	1442	4.61	1457	5.07	1487	5.51	1565	5.95	1643	6.25	1692	6.43	1726
	26	3.48	1415	4.10	1458	4.56	1473	5.01	1503	5.44	1582	5.88	1661	6.17	1711	6.36	1745
	27	3.44	1430	4.05	1474	4.50	1489	4.95	1520	5.38	1600	5.81	1680	6.10	1730	6.28	1765
	28	3.40	1446	4.00	1491	4.45	1506	4.89	1536	5.31	1617	5.74	1698	6.02	1749	6.20	1784
	29	3.36	1462	3.95	1507	4.39	1522	4.83	1553	5.25	1635	5.67	1717	5.95	1768	6.13	1804
	30	3.32	1478	3.91	1523	4.34	1539	4.77	1570	5.18	1653	5.60	1736	5.88	1788	6.06	1823
COMBINATION (%)	INDOOR DB(°C)	OUTDOOR WB(°C)															
		-15		-10		-5		0		5		10		15		20	
		Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT
90%	15	3.83	1250	4.51	1288	5.01	1301	5.50	1328	5.98	1398	6.46	1468	6.78	1512	6.99	1542
	16	3.78	1260	4.45	1299	4.95	1312	5.44	1339	5.91	1409	6.38	1479	6.70	1524	6.90	1554
	17	3.74	1270	4.40	1309	4.89	1322	5.37	1349	5.84	1420	6.31	1491	6.62	1536	6.82	1567
	18	3.70	1280	4.35	1320	4.83	1333	5.31	1360	5.77	1432	6.23	1503	6.54	1548	6.74	1579
	19	3.65	1290	4.30	1330	4.77	1344	5.25	1371	5.70	1443	6.16	1515	6.47	1561	6.66	1592
	20	3.62	1301	4.25	1341	4.73	1355	5.19	1382	5.65	1455	6.10	1528	6.40	1574	6.59	1605
	21	3.57	1315	4.20	1356	4.67	1369	5.13	1397	5.58	1471	6.02	1545	6.32	1591	6.51	1623
	22	3.53	1330	4.15	1371	4.61	1385	5.07	1413	5.51	1487	5.95	1562	6.25	1608	6.44	1641
	23	3.49	1344	4.10	1386	4.56	1400	5.01	1428	5.44	1504	5.88	1579	6.17	1626	6.36	1659
	24	3.45	1359	4.05	1401	4.50	1415	4.95	1444	5.38	1520	5.81	1596	6.10	1644	6.28	1677
	25	3.40	1374	4.00	1416	4.45	1431	4.89	1460	5.31	1537	5.74	1614	6.03	1662	6.21	1695
	26	3.36	1389	3.96	1432	4.40	1446	4.83	1476	5.25	1554	5.67	1631	5.95	1680	6.13	1714
	27	3.32	1404	3.91	1448	4.34	1462	4.77	1492	5.19	1571	5.60	1649	5.88	1699	6.06	1733
	28	3.28	1420	3.86	1464	4.29	1478	4.72	1509	5.13	1588	5.54	1667	5.81	1717	5.99	1752
	29	3.24	1435	3.82	1480	4.24	1495	4.66	1525	5.06	1606	5.47	1686	5.74	1736	5.91	1771
	30	3.20	1451	3.77	1496	4.19	1511	4.60	1542	5.00	1623	5.40	1704	5.67	1755	5.84	1791
COMBINATION (%)	INDOOR DB(°C)	OUTDOOR WB(°C)															
		-15	-10	-5	0	5	10	15	20	-15	-10	-5	0	5	10	15	20
		Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT
80%	15	3.72	1237	4.37	1275	4.86	1288	5.34	1315	5.80	1384	6.27	1453	6.58	1496	6.78	1526
	16	3.67	1247	4.32	1286	4.80	1299	5.27	1325	5.73	1395	6.19	1465	6.50	1509	6.70	1539
	17	3.63	1257	4.27	1296	4.74	1309	5.21	1336	5.66	1406	6.12	1476	6.42	1521	6.62	1551
	18	3.58	1267	4.22	1306	4.69	1320	5.15	1347	5.60	1417	6.04	1488	6.35	1533	6.54	1564
	19	3.54	1277	4.17	1317	4.63	1330	5.09	1357	5.53	1429	5.97	1500	6.27	1545	6.46	1576
	20	3.51	1288	4.13	1328	4.58	1341	5.04	1368	5.48	1440	5.91	1512	6.21	1558	6.40	1589
	21	3.46	1302	4.08	1342	4.53	1356	4.98	1383	5.41	1456	5.84	1529	6.14	1575	6.32	1606
	22	3.42	1316	4.03	1357	4.48	1371	4.92	1399	5.35	1472	5.77	1546	6.06	1592	6.24	1624
	23	3.38	1331	3.98	1372	4.42	1386	4.86	1414	5.28	1488	5.70	1563	5.99	1610	6.17	1642
	24	3.34	1345	3.93	1387	4.37	1401	4.80	1430	5.22	1505	5.64	1580	5.92	1627	6.09	1660
	25	3.30	1360	3.88	1402	4.32	1416	4.74	1445	5.16	1521	5.57	1597	5.85	1645	6.02	1678
	26	3.26	1375	3.84	1418	4.26	1432	4.69	1461	5.09	1538	5.50	1615	5.78	1664	5.95	1697
	27	3.22	1390	3.79	1433	4.21	1448	4.63	1477	5.03	1555	5.43	1633	5.71	1682	5.88	1715
	28	3.18	1406	3.75	1449	4.16	1464	4.57	1494	4.97	1572	5.37	1651	5.64	1700	5.81	1734
	29	3.15	1421	3.70	1465	4.11	1480	4.52	1510	4.91	1589	5.31	1669	5.57	1719	5.74	1753
	30	3.11	1437	3.66	1481	4.06	1496	4.46	1527	4.85	1607	5.24	1687	5.50	1738	5.67	1773

4. CAPACITIES AND SELECTION DATA

COMBINATION (%)	INDOOR DB(°C)	OUTDOOR WB(°C)															
		-15		-10		-5		0		5		10		15		20	
		Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT
100%	15	3.04	887	3.58	914	3.98	923	4.37	942	4.75	992	5.13	1041	5.39	1072	5.55	1094
	16	3.01	894	3.54	921	3.93	931	4.32	950	4.69	1000	5.07	1050	5.32	1081	5.48	1103
	17	2.97	901	3.50	929	3.88	938	4.27	957	4.64	1008	5.01	1058	5.26	1090	5.42	1112
	18	2.94	908	3.45	936	3.84	946	4.22	965	4.58	1016	4.95	1067	5.20	1099	5.35	1121
	19	2.90	915	3.41	944	3.79	953	4.17	973	4.53	1024	4.89	1075	5.14	1107	5.29	1130
	20	2.87	923	3.38	951	3.75	961	4.13	981	4.49	1032	4.84	1084	5.09	1116	5.24	1139
	21	2.84	933	3.34	962	3.71	972	4.08	991	4.43	1044	4.79	1096	5.02	1129	5.18	1151
	22	2.80	943	3.30	972	3.67	982	4.03	1002	4.38	1055	4.73	1108	4.96	1141	5.11	1164
	23	2.77	954	3.26	983	3.62	993	3.98	1013	4.33	1067	4.67	1120	4.91	1154	5.05	1177
	24	2.74	964	3.22	994	3.58	1004	3.93	1024	4.27	1078	4.62	1132	4.85	1166	4.99	1190
	25	2.70	975	3.18	1005	3.53	1015	3.88	1036	4.22	1090	4.56	1145	4.79	1179	4.93	1203
	26	2.67	985	3.14	1016	3.49	1026	3.84	1047	4.17	1102	4.51	1157	4.73	1192	4.87	1216
	27	2.64	996	3.11	1027	3.45	1037	3.79	1059	4.12	1114	4.45	1170	4.67	1205	4.81	1229
	28	2.61	1007	3.07	1038	3.41	1049	3.75	1070	4.07	1127	4.40	1183	4.62	1218	4.76	1243
	29	2.58	1018	3.03	1050	3.37	1060	3.70	1082	4.02	1139	4.35	1196	4.56	1232	4.70	1256
	30	2.55	1030	3.00	1061	3.33	1072	3.66	1094	3.97	1152	4.29	1209	4.51	1245	4.64	1270
90%	15	2.94	871	3.45	897	3.84	907	4.22	925	4.58	974	4.95	1022	5.20	1053	5.36	1074
	16	2.90	878	3.41	905	3.79	914	4.17	933	4.53	982	4.89	1031	5.14	1062	5.29	1083
	17	2.87	885	3.37	912	3.75	921	4.12	940	4.48	989	4.83	1039	5.08	1070	5.23	1092
	18	2.83	892	3.33	919	3.70	929	4.07	948	4.42	997	4.78	1047	5.02	1079	5.17	1100
	19	2.80	899	3.29	927	3.66	936	4.02	955	4.37	1006	4.72	1056	4.96	1087	5.11	1109
	20	2.77	906	3.26	934	3.62	944	3.98	963	4.33	1014	4.67	1064	4.91	1096	5.06	1118
	21	2.74	916	3.22	945	3.58	954	3.93	974	4.28	1025	4.62	1076	4.85	1108	4.99	1130
	22	2.71	926	3.18	955	3.54	965	3.89	984	4.22	1036	4.56	1088	4.79	1120	4.93	1143
	23	2.67	936	3.15	965	3.49	975	3.84	995	4.17	1047	4.51	1100	4.73	1133	4.88	1155
	24	2.64	947	3.11	976	3.45	986	3.79	1006	4.12	1059	4.45	1112	4.68	1145	4.82	1168
	25	2.61	957	3.07	987	3.41	997	3.75	1017	4.07	1071	4.40	1124	4.62	1158	4.76	1181
	26	2.58	968	3.03	998	3.37	1008	3.70	1028	4.03	1082	4.35	1137	4.57	1171	4.70	1194
	27	2.55	978	3.00	1009	3.33	1019	3.66	1040	3.98	1094	4.30	1149	4.51	1183	4.65	1207
	28	2.52	989	2.96	1020	3.29	1030	3.62	1051	3.93	1106	4.24	1162	4.46	1197	4.59	1220
	29	2.49	1000	2.93	1031	3.25	1041	3.57	1063	3.88	1119	4.19	1174	4.40	1210	4.53	1234
	30	2.46	1011	2.89	1042	3.21	1053	3.53	1074	3.84	1131	4.14	1187	4.35	1223	4.48	1247
80%	15	2.85	862	3.35	889	3.72	897	4.09	916	4.45	964	4.80	1012	5.04	1043	5.19	1063
	16	2.81	869	3.31	896	3.68	905	4.04	923	4.39	972	4.75	1020	4.98	1051	5.13	1072
	17	2.78	876	3.27	903	3.64	912	4.00	931	4.34	980	4.69	1029	4.92	1059	5.07	1081
	18	2.75	883	3.23	910	3.59	919	3.95	938	4.29	988	4.63	1037	4.87	1068	5.01	1089
	19	2.72	890	3.19	918	3.55	927	3.90	946	4.24	995	4.58	1045	4.81	1077	4.95	1098
	20	2.69	897	3.16	925	3.51	934	3.86	953	4.20	1003	4.53	1054	4.76	1085	4.90	1107
	21	2.66	907	3.13	935	3.47	945	3.82	964	4.15	1015	4.48	1065	4.70	1097	4.84	1119
	22	2.62	917	3.09	945	3.43	955	3.77	974	4.10	1026	4.43	1077	4.65	1109	4.79	1131
	23	2.59	927	3.05	956	3.39	965	3.72	985	4.05	1037	4.37	1089	4.59	1121	4.73	1144
	24	2.56	937	3.01	966	3.35	976	3.68	996	4.00	1048	4.32	1101	4.54	1134	4.67	1157
	25	2.53	948	2.98	977	3.31	987	3.64	1007	3.95	1060	4.27	1113	4.48	1146	4.62	1169
	26	2.50	958	2.94	988	3.27	998	3.59	1018	3.90	1072	4.22	1125	4.43	1159	4.56	1182
	27	2.47	969	2.91	999	3.23	1009	3.55	1029	3.86	1083	4.17	1138	4.37	1172	4.51	1195
	28	2.44	979	2.87	1010	3.19	1020	3.51	1041	3.81	1095	4.12	1150	4.32	1185	4.45	1208
	29	2.41	990	2.84	1021	3.15	1031	3.46	1052	3.77	1107	4.07	1163	4.27	1198	4.40	1222
	30	2.38	1001	2.80	1032	3.12	1042	3.42	1064	3.72	1120	4.02	1175	4.22	1211	4.35	1235

Remarks:
 Q: Total Cooling Capacity (Gross) **kW**
 INPUT: Power Input (including the compressor, evap. fan motor & cond. **W**
 DB: Dry Bulb Temperature
 WB: Wet Bulb Temperature

3AMW72U4RJC

-

UE MULTI 3 POSTES 7,2 KW

4. CAPACITIES AND SELECTION DATA

24K (Up to 3IDUs)

	Cooling Operation PERFORMANCE DATA																																																					
	OUTDOOR DB (°C)																																																					
COMBINATION (%)	IDDB (°C)	ID WB (°C)	-15				-7				0				10				15				21				25				27				30				35				40				45				50			
			Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT								
130%	21	18	5.31	3.06	0.58	526	5.31	3.06	0.58	584	5.31	3.06	0.58	643	5.90	3.40	0.58	682	5.90	3.40	0.58	760	8.98	5.17	0.58	1575	8.59	4.95	0.58	1656	8.26	4.76	0.58	1732	7.95	4.58	0.58	1812	7.50	4.32	0.58	1929	6.88	3.96	0.58	2049	6.37	3.67	0.58	2127	5.28	3.04	0.58	2208
	21	20	5.59	2.55	0.46	566	5.59	2.55	0.46	624	5.59	2.55	0.46	683	6.20	2.83	0.46	722	6.20	2.83	0.46	800	9.44	4.30	0.46	1607	9.03	4.12	0.46	1690	8.69	3.96	0.46	1768	8.35	3.81	0.46	1849	7.88	3.59	0.46	1969	7.23	3.30	0.46	2092	6.69	3.05	0.46	2171	5.55	2.53	0.46	2253
	22	18	5.31	3.27	0.62	526	5.31	3.27	0.62	584	5.31	3.27	0.62	643	5.90	3.64	0.62	682	5.90	3.64	0.62	760	8.98	5.53	0.62	1575	8.59	5.29	0.62	1656	8.26	5.09	0.62	1732	7.95	4.89	0.62	1812	7.50	4.62	0.62	1929	6.88	4.24	0.62	2049	6.37	3.92	0.62	2127	5.28	3.25	0.62	2208
	22	20	5.59	2.77	0.50	566	5.59	2.77	0.50	624	5.59	2.77	0.50	683	6.20	3.08	0.50	722	6.20	3.08	0.50	800	9.44	4.68	0.50	1607	9.03	4.48	0.50	1690	8.69	4.31	0.50	1768	8.35	4.14	0.50	1849	7.88	3.91	0.50	1969	7.23	3.59	0.50	2092	6.69	3.32	0.50	2171	5.55	2.75	0.50	2253
	22	22	5.92	2.23	0.38	605	5.92	2.23	0.38	663	5.92	2.23	0.38	722	6.58	2.47	0.38	761	6.58	2.47	0.38	839	10.01	3.76	0.38	1639	9.57	3.60	0.38	1724	9.21	3.46	0.38	1803	8.85	3.33	0.38	1886	8.35	3.14	0.38	2008	7.67	2.88	0.38	2133	7.09	2.67	0.38	2214	5.89	2.21	0.38	2298
	23	18	5.31	3.49	0.66	526	5.31	3.49	0.66	584	5.31	3.49	0.66	643	5.90	3.87	0.66	682	5.90	3.87	0.66	760	8.98	5.89	0.66	1575	8.59	5.64	0.66	1656	8.26	5.42	0.66	1732	7.95	5.21	0.66	1812	7.50	4.92	0.66	1929	6.88	4.51	0.66	2049	6.37	4.18	0.66	2127	5.28	3.47	0.66	2208
	23	20	5.59	2.99	0.54	566	5.59	2.99	0.54	624	5.59	2.99	0.54	683	6.20	3.33	0.54	722	6.20	3.33	0.54	800	9.44	5.06	0.54	1607	9.03	4.84	0.54	1690	8.69	4.65	0.54	1768	8.35	4.48	0.54	1849	7.88	4.22	0.54	1969	7.23	3.88	0.54	2092	6.69	3.59	0.54	2171	5.55	2.98	0.54	2253
	23	22	5.92	2.46	0.42	605	5.92	2.46	0.42	663	5.92	2.46	0.42	722	6.58	2.74	0.42	761	6.58	2.74	0.42	839	10.01	4.16	0.42	1639	9.57	3.98	0.42	1724	9.21	3.83	0.42	1803	8.85	3.68	0.42	1886	8.35	3.47	0.42	2008	7.67	3.19	0.42	2133	7.09	2.95	0.42	2214	5.89	2.45	0.42	2298
	24	18	5.31	3.70	0.70	526	5.31	3.70	0.70	584	5.31	3.70	0.70	643	5.90	4.11	0.70	682	5.90	4.11	0.70	760	8.98	6.25	0.70	1575	8.59	5.98	0.70	1656	8.26	5.75	0.70	1732	7.95	5.53	0.70	1812	7.50	5.22	0.70	1929	6.88	4.79	0.70	2049	6.37	4.43	0.70	2127	5.28	3.68	0.70	2208
	24	20	5.59	3.22	0.58	566	5.59	3.22	0.58	624	5.59	3.22	0.58	683	6.20	3.57	0.58	722	6.20	3.57	0.58	800	9.44	5.44	0.58	1607	9.03	5.20	0.58	1690	8.69	5.00	0.58	1768	8.35	4.81	0.58	1849	7.88	4.54	0.58	1969	7.23	4.17	0.58	2092	6.69	3.85	0.58	2171	5.55	3.20	0.58	2253
	24	22	5.92	2.70	0.46	605	5.92	2.70	0.46	663	5.92	2.70	0.46	722	6.58	3.00	0.46	761	6.58	3.00	0.46	839	10.01	4.56	0.46	1639	9.57	4.37	0.46	1724	9.21	4.20	0.46	1803	8.85	4.04	0.46	1886	8.35	3.81	0.46	2008	7.67	3.50	0.46	2133	7.09	3.23	0.46	2214	5.89	2.68	0.46	2298
	24	24	6.28	2.11	0.34	645	6.28	2.11	0.34	703	6.28	2.11	0.34	762	6.97	2.34	0.34	801	6.97	2.34	0.34	879	10.61	3.56	0.34	1672	10.15	3.41	0.34	1758	9.76	3.28	0.34	1839	9.38	3.15	0.34	1923	8.85	2.97	0.34	2048	8.13	2.73	0.34	2175	7.52	2.53	0.34	2258	6.24	2.10	0.34	2344
	25	18	5.31	3.91	0.74	526	5.31	3.91	0.74	584	5.31	3.91	0.74	643	5.90	4.34	0.74	682	5.90	4.34	0.74	760	8.98	6.61	0.74	1575	8.59	6.32	0.74	1656	8.26	6.08	0.74	1732	7.95	5.85	0.74	1812	7.50	5.52	0.74	1929	6.88	5.06	0.74	2049	6.37	4.68	0.74	2127	5.28	3.89	0.74	2208
	25	20	5.59	3.44	0.62	566	5.59	3.44	0.62	624	5.59	3.44	0.62	683	6.20	3.82	0.62	722	6.20	3.82	0.62	800	9.44	5.81	0.62	1607	9.03	5.56	0.62	1690	8.69	5.35	0.62	1768	8.35	5.14	0.62	1849	7.88	4.85	0.62	1969	7.23	4.45	0.62	2092	6.69	4.12	0.62	2171	5.55	3.42	0.62	2253
	25	22	5.92	2.94	0.50	605	5.92	2.94	0.50	663	5.92	2.94	0.50	722	6.58	3.26	0.50	761	6.58	3.26	0.50	839	10.01	4.96	0.50	1639	9.57	4.75	0.50	1724	9.21	4.57	0.50	1803	8.85	4.39	0.50	1886	8.35	4.14	0.50	2008	7.67	3.80	0.50	2133	7.09	3.52	0.50	2214	5.89	2.92	0.50	2298
	25	24	6.28	2.36	0.38	645	6.28	2.36	0.38	703	6.28	2.36	0.38	762	6.97	2.62	0.38	801	6.97	2.62	0.38	879	10.61	3.99	0.38	1672	10.15	3.82	0.38	1758	9.76	3.67	0.38	1839	9.38	3.53	0.38	1923	8.85	3.33	0.38	2048	8.13	3.05	0.38	2175	7.52	2.83	0.38	2258	6.24	2.35	0.38	2344
	26	18	5.31	4.12	0.78	526	5.31	4.12	0.78	584	5.31	4.12	0.78	643	5.90	4.58	0.78	682	5.90	4.58	0.78	760	8.98	6.97	0.78	1575	8.59	6.67	0.78	1656	8.26	6.41	0.78	1732	7.95	6.17	0.78	1812	7.50	5.82	0.78	1929	6.88	5.34	0.78	2049	6.37	4.94	0.78	2127	5.28	4.10	0.78	2208
	26	20	5.59	3.66	0.66	566	5.59	3.66	0.66	624	5.59	3.66	0.66	683	6.20	4.07	0.66	722	6.20	4.07	0.66	800	9.44	6.19	0.66	1607	9.03	5.92	0.66	1690	8.69	5.70	0.66	1768	8.35	5.48	0.66	1849	7.88	5.17	0.66	1969	7.23	4.74	0.66	2092	6.69	4						

4. CAPACITIES AND SELECTION DATA

				Cooling Operation PERFORMANCE DATA																																																		
				OUTDOOR DB (°C)																																																		
COMBINATION (%)	IDDB (°C)	ID WB (°C)	-15				-7				0				10				15				21				25				27				30				35				40				45				50			
			Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT								
120%	21	18	5.16	3.09	0.60	500	5.16	3.09	0.60	556	5.16	3.09	0.60	611	5.73	3.43	0.60	648	5.73	3.43	0.60	723	8.72	5.23	0.60	1499	8.34	5.00	0.60	1576	8.02	4.81	0.60	1649	7.71	4.62	0.60	1725	7.28	4.36	0.60	1837	6.68	4.00	0.60	1950	6.18	3.70	0.60	2025	5.13	3.07	0.60	2101
	21	20	5.42	2.60	0.48	540	5.42	2.60	0.48	596	5.42	2.60	0.48	651	6.02	2.89	0.48	688	6.02	2.89	0.48	763	9.16	4.39	0.48	1532	8.77	4.20	0.48	1610	8.43	4.04	0.48	1685	8.11	3.89	0.48	1762	7.65	3.67	0.48	1877	7.02	3.37	0.48	1993	6.50	3.11	0.48	2069	5.39	2.58	0.48	2147
	22	18	5.16	3.30	0.64	500	5.16	3.30	0.64	556	5.16	3.30	0.64	611	5.73	3.66	0.64	648	5.73	3.66	0.64	723	8.72	5.57	0.64	1499	8.34	5.33	0.64	1576	8.02	5.13	0.64	1649	7.71	4.93	0.64	1725	7.28	4.65	0.64	1837	6.68	4.27	0.64	1950	6.18	3.95	0.64	2025	5.13	3.28	0.64	2101
	22	20	5.42	2.82	0.52	540	5.42	2.82	0.52	596	5.42	2.82	0.52	651	6.02	3.13	0.52	688	6.02	3.13	0.52	763	9.16	4.76	0.52	1532	8.77	4.55	0.52	1610	8.43	4.38	0.52	1685	8.11	4.21	0.52	1762	7.65	3.97	0.52	1877	7.02	3.65	0.52	1993	6.50	3.37	0.52	2069	5.39	2.80	0.52	2147
	22	22	5.75	2.30	0.40	579	5.75	2.30	0.40	635	5.75	2.30	0.40	690	6.39	2.55	0.40	727	6.39	2.55	0.40	802	9.71	3.88	0.40	1563	9.30	3.71	0.40	1644	8.94	3.57	0.40	1720	8.59	3.43	0.40	1799	8.11	3.24	0.40	1916	7.44	2.97	0.40	2034	6.88	2.75	0.40	2112	5.71	2.28	0.40	2192
	23	18	5.16	3.51	0.68	500	5.16	3.51	0.68	556	5.16	3.51	0.68	611	5.73	3.89	0.68	648	5.73	3.89	0.68	723	8.72	5.92	0.68	1499	8.34	5.67	0.68	1576	8.02	5.45	0.68	1649	7.71	5.24	0.68	1725	7.28	4.94	0.68	1837	6.68	4.54	0.68	1950	6.18	4.20	0.68	2025	5.13	3.48	0.68	2101
	23	20	5.42	3.03	0.56	540	5.42	3.03	0.56	596	5.42	3.03	0.56	651	6.02	3.37	0.56	688	6.02	3.37	0.56	763	9.16	5.13	0.56	1532	8.77	4.90	0.56	1610	8.43	4.72	0.56	1685	8.11	4.53	0.56	1762	7.65	4.28	0.56	1877	7.02	3.93	0.56	1993	6.50	3.63	0.56	2069	5.39	3.02	0.56	2147
	23	22	5.75	2.53	0.44	579	5.75	2.53	0.44	635	5.75	2.53	0.44	690	6.39	2.80	0.44	727	6.39	2.80	0.44	802	9.71	4.27	0.44	1563	9.30	4.08	0.44	1644	8.94	3.93	0.44	1720	8.59	3.78	0.44	1799	8.11	3.56	0.44	1916	7.44	3.27	0.44	2034	6.88	3.02	0.44	2112	5.71	2.51	0.44	2192
	24	18	5.16	3.71	0.72	500	5.16	3.71	0.72	556	5.16	3.71	0.72	611	5.73	4.12	0.72	648	5.73	4.12	0.72	723	8.72	6.27	0.72	1499	8.34	6.00	0.72	1576	8.02	5.77	0.72	1649	7.71	5.55	0.72	1725	7.28	5.23	0.72	1837	6.68	4.81	0.72	1950	6.18	4.45	0.72	2025	5.13	3.69	0.72	2101
	24	20	5.42	3.25	0.60	540	5.42	3.25	0.60	596	5.42	3.25	0.60	651	6.02	3.61	0.60	688	6.02	3.61	0.60	763	9.16	5.49	0.60	1532	8.77	5.26	0.60	1610	8.43	5.05	0.60	1685	8.11	4.86	0.60	1762	7.65	4.58	0.60	1877	7.02	4.21	0.60	1993	6.50	3.89	0.60	2069	5.39	3.23	0.60	2147
	24	22	5.75	2.76	0.48	579	5.75	2.76	0.48	635	5.75	2.76	0.48	690	6.39	3.06	0.48	727	6.39	3.06	0.48	802	9.71	4.66	0.48	1563	9.30	4.46	0.48	1644	8.94	4.28	0.48	1720	8.59	4.12	0.48	1799	8.11	3.89	0.48	1916	7.44	3.57	0.48	2034	6.88	3.30	0.48	2112	5.71	2.74	0.48	2192
	24	24	6.09	2.19	0.36	619	6.09	2.19	0.36	675	6.09	2.19	0.36	730	6.77	2.43	0.36	767	6.77	2.43	0.36	842	10.30	3.70	0.36	1596	9.85	3.54	0.36	1678	9.47	3.40	0.36	1755	9.11	3.27	0.36	1836	8.59	3.09	0.36	1956	7.89	2.83	0.36	2077	7.30	2.62	0.36	2156	6.06	2.18	0.36	2238
	25	18	5.16	3.92	0.76	500	5.16	3.92	0.76	556	5.16	3.92	0.76	611	5.73	4.35	0.76	648	5.73	4.35	0.76	723	8.72	6.62	0.76	1499	8.34	6.34	0.76	1576	8.02	6.09	0.76	1649	7.71	5.86	0.76	1725	7.28	5.53	0.76	1837	6.68	5.07	0.76	1950	6.18	4.69	0.76	2025	5.13	3.89	0.76	2101
	25	20	5.42	3.47	0.64	540	5.42	3.47	0.64	596	5.42	3.47	0.64	651	6.02	3.85	0.64	688	6.02	3.85	0.64	763	9.16	5.86	0.64	1532	8.77	5.61	0.64	1610	8.43	5.39	0.64	1685	8.11	5.18	0.64	1762	7.65	4.89	0.64	1877	7.02	4.49	0.64	1993	6.50	4.15	0.64	2069	5.39	3.45	0.64	2147
	25	22	5.75	2.99	0.52	579	5.75	2.99	0.52	635	5.75	2.99	0.52	690	6.39	3.32	0.52	727	6.39	3.32	0.52	802	9.71	5.04	0.52	1563	9.30	4.83	0.52	1644	8.94	4.64	0.52	1720	8.59	4.46	0.52	1799	8.11	4.21	0.52	1916	7.44	3.87	0.52	2034	6.88	3.58	0.52	2112	5.71	2.97	0.52	2192
	25	24	6.09	2.43	0.40	619	6.09	2.43	0.40	675	6.09	2.43	0.40	730	6.77	2.70	0.40	767	6.77	2.70	0.40	842	10.30	4.11	0.40	1596	9.85	3.93	0.40	1678	9.47	3.78	0.40	1755	9.11	3.64	0.40	1836	8.59	3.43	0.40	1956	7.89	3.15	0.40	2077	7.30	2.91	0.40	2156	6.06	2.42	0.40	2238
	26	18	5.16	4.12	0.80	500	5.16	4.12	0.80	556	5.16	4.12	0.80	611	5.73	4.58	0.80	648	5.73	4.58	0.80	723	8.72	6.97	0.80	1499	8.34	6.67	0.80	1576	8.02	6.41	0.80	1649	7.71	6.17	0.80	1725	7.28	5.82	0.80	1837	6.68	5.34	0.80	1950	6.18	4.94	0.80	2025	5.13	4.10	0.80	2101
	26	20	5.42	3.68	0.68	540	5.42	3.68	0.68	596	5.42	3.68	0.68	651	6.02	4.09	0.68	688	6.02	4.09	0.68	763	9.16	6.23	0.68	1532	8.77	5.96	0.68	1610	8.43	5.73	0.68	1685	8.11	5.51	0.68	1762	7.65	5.20	0.68	1877	7.02	4.77	0.68	1993	6.50	4.41	0.68	2069	5.39	3.66	0.68	2147
	26	22	5.75	3.22	0.56	579	5.75	3.22	0.56	635	5.75	3.22	0.56	690	6.39	3.57	0.56	727	6.39	3.57	0.56	802	9.71	5.43	0.56	1563	9.30	5.20	0.56	1644	8.94	5.00	0.56	1720																				

4. CAPACITIES AND SELECTION DATA

	Cooling Operation PERFORMANCE DATA																																																					
	OUTDOOR DB (°C)																																																					
COMBINATION (%)	IDDB (°C)	ID WB (°C)	-15				-7				0				10				15				21				25				27				30				35				40				45				50			
			Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT								
110%	21	18	5.01	3.12	0.62	485	5.01	3.12	0.62	539	5.01	3.12	0.62	593	5.56	3.47	0.62	629	5.56	3.47	0.62	701	8.47	5.28	0.62	1455	8.10	5.05	0.62	1530	7.79	4.86	0.62	1600	7.49	4.67	0.62	1674	7.07	4.40	0.62	1783	6.49	4.04	0.62	1893	6.00	3.74	0.62	1965	4.98	3.10	0.62	2040
	21	20	5.27	2.65	0.50	525	5.27	2.65	0.50	579	5.27	2.65	0.50	633	5.85	2.94	0.50	669	5.85	2.94	0.50	741	8.90	4.48	0.50	1487	8.51	4.29	0.50	1564	8.19	4.12	0.50	1636	7.87	3.96	0.50	1711	7.43	3.74	0.50	1823	6.82	3.43	0.50	1935	6.31	3.17	0.50	2009	5.23	2.63	0.50	2085
	22	18	5.01	3.32	0.66	485	5.01	3.32	0.66	539	5.01	3.32	0.66	593	5.56	3.69	0.66	629	5.56	3.69	0.66	701	8.47	5.62	0.66	1455	8.10	5.37	0.66	1530	7.79	5.17	0.66	1600	7.49	4.97	0.66	1674	7.07	4.69	0.66	1783	6.49	4.30	0.66	1893	6.00	3.98	0.66	1965	4.98	3.30	0.66	2040
	22	20	5.27	2.86	0.54	525	5.27	2.86	0.54	579	5.27	2.86	0.54	633	5.85	3.18	0.54	669	5.85	3.18	0.54	741	8.90	4.83	0.54	1487	8.51	4.63	0.54	1564	8.19	4.45	0.54	1636	7.87	4.28	0.54	1711	7.43	4.04	0.54	1823	6.82	3.70	0.54	1935	6.31	3.43	0.54	2009	5.23	2.84	0.54	2085
	22	22	5.58	2.36	0.42	564	5.58	2.36	0.42	618	5.58	2.36	0.42	672	6.20	2.62	0.42	708	6.20	2.62	0.42	780	9.43	3.99	0.42	1519	9.03	3.82	0.42	1598	8.68	3.67	0.42	1671	8.34	3.53	0.42	1748	7.87	3.33	0.42	1862	7.23	3.06	0.42	1977	6.68	2.83	0.42	2052	5.55	2.35	0.42	2130
	23	18	5.01	3.52	0.70	485	5.01	3.52	0.70	539	5.01	3.52	0.70	593	5.56	3.91	0.70	629	5.56	3.91	0.70	701	8.47	5.95	0.70	1455	8.10	5.70	0.70	1530	7.79	5.48	0.70	1600	7.49	5.27	0.70	1674	7.07	4.97	0.70	1783	6.49	4.56	0.70	1893	6.00	4.22	0.70	1965	4.98	3.50	0.70	2040
	23	20	5.27	3.07	0.58	525	5.27	3.07	0.58	579	5.27	3.07	0.58	633	5.85	3.41	0.58	669	5.85	3.41	0.58	741	8.90	5.19	0.58	1487	8.51	4.97	0.58	1564	8.19	4.78	0.58	1636	7.87	4.59	0.58	1711	7.43	4.33	0.58	1823	6.82	3.98	0.58	1935	6.31	3.68	0.58	2009	5.23	3.05	0.58	2085
	23	22	5.58	2.59	0.46	564	5.58	2.59	0.46	618	5.58	2.59	0.46	672	6.20	2.87	0.46	708	6.20	2.87	0.46	780	9.43	4.37	0.46	1519	9.03	4.18	0.46	1598	8.68	4.02	0.46	1671	8.34	3.87	0.46	1748	7.87	3.65	0.46	1862	7.23	3.35	0.46	1977	6.68	3.10	0.46	2052	5.55	2.57	0.46	2130
	24	18	5.01	3.72	0.74	485	5.01	3.72	0.74	539	5.01	3.72	0.74	593	5.56	4.14	0.74	629	5.56	4.14	0.74	701	8.47	6.29	0.74	1455	8.10	6.02	0.74	1530	7.79	5.79	0.74	1600	7.49	5.57	0.74	1674	7.07	5.25	0.74	1783	6.49	4.82	0.74	1893	6.00	4.46	0.74	1965	4.98	3.70	0.74	2040
	24	20	5.27	3.28	0.62	525	5.27	3.28	0.62	579	5.27	3.28	0.62	633	5.85	3.65	0.62	669	5.85	3.65	0.62	741	8.90	5.55	0.62	1487	8.51	5.31	0.62	1564	8.19	5.10	0.62	1636	7.87	4.91	0.62	1711	7.43	4.63	0.62	1823	6.82	4.25	0.62	1935	6.31	3.93	0.62	2009	5.23	3.26	0.62	2085
	24	22	5.58	2.81	0.50	564	5.58	2.81	0.50	618	5.58	2.81	0.50	672	6.20	3.12	0.50	708	6.20	3.12	0.50	780	9.43	4.75	0.50	1519	9.03	4.54	0.50	1598	8.68	4.37	0.50	1671	8.34	4.20	0.50	1748	7.87	3.96	0.50	1862	7.23	3.64	0.50	1977	6.68	3.36	0.50	2052	5.55	2.79	0.50	2130
	24	24	5.92	2.27	0.38	604	5.92	2.27	0.38	658	5.92	2.27	0.38	712	6.57	2.52	0.38	748	6.57	2.52	0.38	820	10.00	3.83	0.38	1552	9.57	3.67	0.38	1632	9.20	3.53	0.38	1707	8.84	3.39	0.38	1786	8.34	3.20	0.38	1902	7.66	2.94	0.38	2019	7.09	2.72	0.38	2096	5.88	2.25	0.38	2176
	25	18	5.01	3.92	0.78	485	5.01	3.92	0.78	539	5.01	3.92	0.78	593	5.56	4.36	0.78	629	5.56	4.36	0.78	701	8.47	6.63	0.78	1455	8.10	6.35	0.78	1530	7.79	6.10	0.78	1600	7.49	5.87	0.78	1674	7.07	5.54	0.78	1783	6.49	5.08	0.78	1893	6.00	4.70	0.78	1965	4.98	3.90	0.78	2040
	25	20	5.27	3.49	0.66	525	5.27	3.49	0.66	579	5.27	3.49	0.66	633	5.85	3.88	0.66	669	5.85	3.88	0.66	741	8.90	5.90	0.66	1487	8.51	5.65	0.66	1564	8.19	5.43	0.66	1636	7.87	5.22	0.66	1711	7.43	4.93	0.66	1823	6.82	4.52	0.66	1935	6.31	4.18	0.66	2009	5.23	3.47	0.66	2085
	25	22	5.58	3.03	0.54	564	5.58	3.03	0.54	618	5.58	3.03	0.54	672	6.20	3.37	0.54	708	6.20	3.37	0.54	780	9.43	5.12	0.54	1519	9.03	4.90	0.54	1598	8.68	4.72	0.54	1671	8.34	4.53	0.54	1748	7.87	4.28	0.54	1862	7.23	3.93	0.54	1977	6.68	3.63	0.54	2052	5.55	3.01	0.54	2130
	25	24	5.92	2.50	0.42	604	5.92	2.50	0.42	658	5.92	2.50	0.42	712	6.57	2.78	0.42	748	6.57	2.78	0.42	820	10.00	4.23	0.42	1552	9.57	4.05	0.42	1632	9.20	3.89	0.42	1707	8.84	3.74	0.42	1786	8.34	3.53	0.42	1902	7.66	3.24	0.42	2019	7.09	3.00	0.42	2096	5.88	2.49	0.42	2176
	26	18	5.01	4.12	0.82	485	5.01	4.12	0.82	539	5.01	4.12	0.82	593	5.56	4.58	0.82	629	5.56	4.58	0.82	701	8.47	6.97	0.82	1455	8.10	6.67	0.82	1530	7.79	6.41	0.82	1600	7.49	6.17	0.82	1674	7.07	5.82	0.82	1783	6.49	5.34	0.82	1893	6.00	4.94	0.82	1965	4.98	4.10	0.82	2040
	26	20	5.27	3.70	0.70	525	5.27	3.70	0.70	579	5.27	3.70	0.70	633	5.85	4.11	0.70	669	5.85	4.11	0.70	741	8.90	6.26	0.70	1487	8.51	5.99	0.70	1564	8.19	5.76	0.70	1636	7.87	5.54	0.70	1711	7.43	5.22	0.70	1823	6.82											

4. CAPACITIES AND SELECTION DATA

	Cooling Operation PERFORMANCE DATA																																																					
	OUTDOOR DB (°C)																																																					
COMBINATION (%)	IDDB (°C)	ID WB (°C)	-15				-7				0				10				15				21				25				27				30				35				40				45				50			
			Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT												
100%	21	18	4.86	2.92	0.60	470	4.86	2.92	0.60	523	4.86	2.92	0.60	575	5.40	3.24	0.60	610	5.40	3.24	0.60	680	8.22	4.93	0.60	1412	7.86	4.72	0.60	1485	7.56	4.54	0.60	1553	7.27	4.36	0.60	1624	6.86	4.12	0.60	1730	6.30	3.78	0.60	1837	5.83	3.50	0.60	1907	4.83	2.90	0.60	1980
	21	20	5.11	2.45	0.48	510	5.11	2.45	0.48	563	5.11	2.45	0.48	615	5.68	2.73	0.48	650	5.68	2.73	0.48	720	8.64	4.15	0.48	1445	8.27	3.97	0.48	1519	7.95	3.82	0.48	1589	7.64	3.67	0.48	1662	7.21	3.46	0.48	1770	6.62	3.18	0.48	1880	6.12	2.94	0.48	1951	5.08	2.44	0.48	2025
	22	18	4.86	3.11	0.64	470	4.86	3.11	0.64	523	4.86	3.11	0.64	575	5.40	3.46	0.64	610	5.40	3.46	0.64	680	8.22	5.26	0.64	1412	7.86	5.03	0.64	1485	7.56	4.84	0.64	1553	7.27	4.65	0.64	1624	6.86	4.39	0.64	1730	6.30	4.03	0.64	1837	5.83	3.73	0.64	1907	4.83	3.09	0.64	1980
	22	20	5.11	2.66	0.52	510	5.11	2.66	0.52	563	5.11	2.66	0.52	615	5.68	2.95	0.52	650	5.68	2.95	0.52	720	8.64	4.49	0.52	1445	8.27	4.30	0.52	1519	7.95	4.13	0.52	1589	7.64	3.97	0.52	1662	7.21	3.75	0.52	1770	6.62	3.44	0.52	1880	6.12	3.18	0.52	1951	5.08	2.64	0.52	2025
	22	22	5.42	2.17	0.40	549	5.42	2.17	0.40	602	5.42	2.17	0.40	654	6.02	2.41	0.40	689	6.02	2.41	0.40	759	9.16	3.66	0.40	1476	8.76	3.50	0.40	1552	8.43	3.37	0.40	1624	8.10	3.24	0.40	1699	7.64	3.06	0.40	1809	7.02	2.81	0.40	1921	6.49	2.60	0.40	1994	5.39	2.15	0.40	2070
	23	18	4.86	3.31	0.68	470	4.86	3.31	0.68	523	4.86	3.31	0.68	575	5.40	3.67	0.68	610	5.40	3.67	0.68	680	8.22	5.59	0.68	1412	7.86	5.35	0.68	1485	7.56	5.14	0.68	1553	7.27	4.94	0.68	1624	6.86	4.66	0.68	1730	6.30	4.28	0.68	1837	5.83	3.96	0.68	1907	4.83	3.29	0.68	1980
	23	20	5.11	2.86	0.56	510	5.11	2.86	0.56	563	5.11	2.86	0.56	615	5.68	3.18	0.56	650	5.68	3.18	0.56	720	8.64	4.84	0.56	1445	8.27	4.63	0.56	1519	7.95	4.45	0.56	1589	7.64	4.28	0.56	1662	7.21	4.04	0.56	1770	6.62	3.71	0.56	1880	6.12	3.43	0.56	1951	5.08	2.85	0.56	2025
	23	22	5.42	2.38	0.44	549	5.42	2.38	0.44	602	5.42	2.38	0.44	654	6.02	2.65	0.44	689	6.02	2.65	0.44	759	9.16	4.03	0.44	1476	8.76	3.86	0.44	1552	8.43	3.71	0.44	1624	8.10	3.56	0.44	1699	7.64	3.36	0.44	1809	7.02	3.09	0.44	1921	6.49	2.86	0.44	1994	5.39	2.37	0.44	2070
	24	18	4.86	3.50	0.72	470	4.86	3.50	0.72	523	4.86	3.50	0.72	575	5.40	3.89	0.72	610	5.40	3.89	0.72	680	8.22	5.92	0.72	1412	7.86	5.66	0.72	1485	7.56	5.44	0.72	1553	7.27	5.24	0.72	1624	6.86	4.94	0.72	1730	6.30	4.53	0.72	1837	5.83	4.19	0.72	1907	4.83	3.48	0.72	1980
	24	20	5.11	3.07	0.60	510	5.11	3.07	0.60	563	5.11	3.07	0.60	615	5.68	3.41	0.60	650	5.68	3.41	0.60	720	8.64	5.18	0.60	1445	8.27	4.96	0.60	1519	7.95	4.77	0.60	1589	7.64	4.59	0.60	1662	7.21	4.33	0.60	1770	6.62	3.97	0.60	1880	6.12	3.67	0.60	1951	5.08	3.05	0.60	2025
	24	22	5.42	2.60	0.48	549	5.42	2.60	0.48	602	5.42	2.60	0.48	654	6.02	2.89	0.48	689	6.02	2.89	0.48	759	9.16	4.40	0.48	1476	8.76	4.21	0.48	1552	8.43	4.04	0.48	1624	8.10	3.89	0.48	1699	7.64	3.67	0.48	1809	7.02	3.37	0.48	1921	6.49	3.12	0.48	1994	5.39	2.59	0.48	2070
	24	24	5.74	2.07	0.36	589	5.74	2.07	0.36	642	5.74	2.07	0.36	694	6.38	2.30	0.36	729	6.38	2.30	0.36	799	9.71	3.49	0.36	1509	9.29	3.34	0.36	1587	8.93	3.22	0.36	1660	8.59	3.09	0.36	1736	8.10	2.92	0.36	1849	7.44	2.68	0.36	1964	6.88	2.48	0.36	2038	5.71	2.06	0.36	2116
	25	18	4.86	3.70	0.76	470	4.86	3.70	0.76	523	4.86	3.70	0.76	575	5.40	4.11	0.76	610	5.40	4.11	0.76	680	8.22	6.25	0.76	1412	7.86	5.98	0.76	1485	7.56	5.75	0.76	1553	7.27	5.53	0.76	1624	6.86	5.21	0.76	1730	6.30	4.79	0.76	1837	5.83	4.43	0.76	1907	4.83	3.67	0.76	1980
	25	20	5.11	3.27	0.64	510	5.11	3.27	0.64	563	5.11	3.27	0.64	615	5.68	3.63	0.64	650	5.68	3.63	0.64	720	8.64	5.53	0.64	1445	8.27	5.29	0.64	1519	7.95	5.09	0.64	1589	7.64	4.89	0.64	1662	7.21	4.61	0.64	1770	6.62	4.24	0.64	1880	6.12	3.92	0.64	1951	5.08	3.25	0.64	2025
	25	22	5.42	2.82	0.52	549	5.42	2.82	0.52	602	5.42	2.82	0.52	654	6.02	3.13	0.52	689	6.02	3.13	0.52	759	9.16	4.76	0.52	1476	8.76	4.56	0.52	1552	8.43	4.38	0.52	1624	8.10	4.21	0.52	1699	7.64	3.97	0.52	1809	7.02	3.65	0.52	1921	6.49	3.37	0.52	1994	5.39	2.80	0.52	2070
	25	24	5.74	2.30	0.40	589	5.74	2.30	0.40	642	5.74	2.30	0.40	694	6.38	2.55	0.40	729	6.38	2.55	0.40	799	9.71	3.88	0.40	1509	9.29	3.72	0.40	1587	8.93	3.57	0.40	1660	8.59	3.43	0.40	1736	8.10	3.24	0.40	1849	7.44	2.97	0.40	1964	6.88	2.75	0.40	2038	5.71	2.28	0.40	2116
	26	18	4.86	3.89	0.80	470	4.86	3.89	0.80	523	4.86	3.89	0.80	575	5.40	4.32	0.80	610	5.40	4.32	0.80	680	8.22	6.58	0.80	1412	7.86	6.29	0.80	1485	7.56	6.05	0.80	1553	7.27	5.82	0.80	1624	6.86	5.49	0.80	1730	6.30	5.04	0.80	1837	5.83	4.66	0.80	1907	4.83	3.87	0.80	1980
	26	20	5.11	3.48	0.68	510	5.11	3.48	0.68	563	5.11	3.48	0.68	615	5.68	3.86	0.68	650	5.68	3.86	0.68	720	8.64	5.87	0.68	1445	8.27	5.62	0.68	1519	7.95	5.40	0.68																					

4. CAPACITIES AND SELECTION DATA

	Cooling Operation PERFORMANCE DATA																																																					
	OUTDOOR DB (°C)																																																					
COMBINATION (%)	IDDB (°C)	ID WB (°C)	-15				-7				0				10				15				21				25				27				30				35				40				45				50			
			Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT												
90%	21	18	4.57	2.56	0.56	441	4.57	2.56	0.56	490	4.57	2.56	0.56	539	5.08	2.85	0.56	572	5.08	2.85	0.56	638	7.73	4.33	0.56	1326	7.39	4.15	0.56	1395	7.11	3.99	0.56	1459	6.84	3.83	0.56	1526	6.45	3.62	0.56	1625	5.92	3.32	0.56	1726	5.48	3.07	0.56	1791	4.54	2.55	0.56	1859
	21	20	4.81	2.12	0.44	481	4.81	2.12	0.44	530	4.81	2.12	0.44	579	5.34	2.35	0.44	612	5.34	2.35	0.44	678	8.12	3.58	0.44	1359	7.77	3.43	0.44	1429	7.47	3.29	0.44	1495	7.18	3.17	0.44	1563	6.78	2.99	0.44	1665	6.22	2.74	0.44	1768	5.76	2.54	0.44	1835	4.78	2.11	0.44	1905
	22	18	4.57	2.75	0.60	441	4.57	2.75	0.60	490	4.57	2.75	0.60	539	5.08	3.05	0.60	572	5.08	3.05	0.60	638	7.73	4.64	0.60	1326	7.39	4.44	0.60	1395	7.11	4.27	0.60	1459	6.84	4.11	0.60	1526	6.45	3.88	0.60	1625	5.92	3.56	0.60	1726	5.48	3.29	0.60	1791	4.54	2.73	0.60	1859
	22	20	4.81	2.31	0.48	481	4.81	2.31	0.48	530	4.81	2.31	0.48	579	5.34	2.57	0.48	612	5.34	2.57	0.48	678	8.12	3.91	0.48	1359	7.77	3.74	0.48	1429	7.47	3.59	0.48	1495	7.18	3.46	0.48	1563	6.78	3.26	0.48	1665	6.22	2.99	0.48	1768	5.76	2.77	0.48	1835	4.78	2.30	0.48	1905
	22	22	5.09	1.84	0.36	520	5.09	1.84	0.36	569	5.09	1.84	0.36	618	5.66	2.04	0.36	651	5.66	2.04	0.36	717	8.61	3.11	0.36	1391	8.24	2.97	0.36	1462	7.92	2.86	0.36	1530	7.62	2.75	0.36	1600	7.18	2.59	0.36	1704	6.59	2.38	0.36	1810	6.10	2.20	0.36	1878	5.06	1.83	0.36	1950
	23	18	4.57	2.93	0.64	441	4.57	2.93	0.64	490	4.57	2.93	0.64	539	5.08	3.26	0.64	572	5.08	3.26	0.64	638	7.73	4.95	0.64	1326	7.39	4.74	0.64	1395	7.11	4.56	0.64	1459	6.84	4.38	0.64	1526	6.45	4.13	0.64	1625	5.92	3.79	0.64	1726	5.48	3.51	0.64	1791	4.54	2.91	0.64	1859
	23	20	4.81	2.50	0.52	481	4.81	2.50	0.52	530	4.81	2.50	0.52	579	5.34	2.78	0.52	612	5.34	2.78	0.52	678	8.12	4.23	0.52	1359	7.77	4.05	0.52	1429	7.47	3.89	0.52	1495	7.18	3.74	0.52	1563	6.78	3.53	0.52	1665	6.22	3.24	0.52	1768	5.76	3.00	0.52	1835	4.78	2.49	0.52	1905
	23	22	5.09	2.04	0.40	520	5.09	2.04	0.40	569	5.09	2.04	0.40	618	5.66	2.27	0.40	651	5.66	2.27	0.40	717	8.61	3.45	0.40	1391	8.24	3.30	0.40	1462	7.92	3.18	0.40	1530	7.62	3.05	0.40	1600	7.18	2.88	0.40	1704	6.59	2.64	0.40	1810	6.10	2.45	0.40	1878	5.06	2.03	0.40	1950
	24	18	4.57	3.11	0.68	441	4.57	3.11	0.68	490	4.57	3.11	0.68	539	5.08	3.46	0.68	572	5.08	3.46	0.68	638	7.73	5.26	0.68	1326	7.39	5.03	0.68	1395	7.11	4.84	0.68	1459	6.84	4.65	0.68	1526	6.45	4.39	0.68	1625	5.92	4.03	0.68	1726	5.48	3.73	0.68	1791	4.54	3.10	0.68	1859
	24	20	4.81	2.70	0.56	481	4.81	2.70	0.56	530	4.81	2.70	0.56	579	5.34	2.99	0.56	612	5.34	2.99	0.56	678	8.12	4.56	0.56	1359	7.77	4.36	0.56	1429	7.47	4.19	0.56	1495	7.18	4.03	0.56	1563	6.78	3.80	0.56	1665	6.22	3.49	0.56	1768	5.76	3.23	0.56	1835	4.78	2.68	0.56	1905
	24	22	5.09	2.25	0.44	520	5.09	2.25	0.44	569	5.09	2.25	0.44	618	5.66	2.49	0.44	651	5.66	2.49	0.44	717	8.61	3.80	0.44	1391	8.24	3.63	0.44	1462	7.92	3.49	0.44	1530	7.62	3.36	0.44	1600	7.18	3.17	0.44	1704	6.59	2.91	0.44	1810	6.10	2.69	0.44	1878	5.06	2.23	0.44	1950
	24	24	5.40	1.73	0.32	560	5.40	1.73	0.32	609	5.40	1.73	0.32	658	6.00	1.92	0.32	691	6.00	1.92	0.32	757	9.12	2.93	0.32	1423	8.73	2.80	0.32	1497	8.39	2.69	0.32	1566	8.07	2.59	0.32	1638	7.62	2.44	0.32	1744	6.99	2.24	0.32	1852	6.47	2.08	0.32	1923	5.37	1.72	0.32	1996
	25	18	4.57	3.30	0.72	441	4.57	3.30	0.72	490	4.57	3.30	0.72	539	5.08	3.66	0.72	572	5.08	3.66	0.72	638	7.73	5.57	0.72	1326	7.39	5.33	0.72	1395	7.11	5.13	0.72	1459	6.84	4.93	0.72	1526	6.45	4.65	0.72	1625	5.92	4.27	0.72	1726	5.48	3.95	0.72	1791	4.54	3.28	0.72	1859
	25	20	4.81	2.89	0.60	481	4.81	2.89	0.60	530	4.81	2.89	0.60	579	5.34	3.21	0.60	612	5.34	3.21	0.60	678	8.12	4.88	0.60	1359	7.77	4.67	0.60	1429	7.47	4.49	0.60	1495	7.18	4.32	0.60	1563	6.78	4.07	0.60	1665	6.22	3.74	0.60	1768	5.76	3.46	0.60	1835	4.78	2.87	0.60	1905
	25	22	5.09	2.45	0.48	520	5.09	2.45	0.48	569	5.09	2.45	0.48	618	5.66	2.72	0.48	651	5.66	2.72	0.48	717	8.61	4.14	0.48	1391	8.24	3.96	0.48	1462	7.92	3.81	0.48	1530	7.62	3.66	0.48	1600	7.18	3.46	0.48	1704	6.59	3.17	0.48	1810	6.10	2.93	0.48	1878	5.06	2.44	0.48	1950
	25	24	5.40	1.95	0.36	560	5.40	1.95	0.36	609	5.40	1.95	0.36	658	6.00	2.16	0.36	691	6.00	2.16	0.36	757	9.12	3.29	0.36	1423	8.73	3.15	0.36	1497	8.39	3.03	0.36	1566	8.07	2.91	0.36	1638	7.62	2.75	0.36	1744	6.99	2.52	0.36	1852	6.47	2.33	0.36	1923	5.37	1.94	0.36	1996
	26	18	4.57	3.48	0.76	441	4.57	3.48	0.76	490	4.57	3.48	0.76	539	5.08	3.86	0.76	572	5.08	3.86	0.76	638	7.73	5.88	0.76	1326	7.39	5.63	0.76	1395	7.11	5.41	0.76	1459	6.84	5.20	0.76	1526	6.45	4.91	0.76	1625	5.92	4.50	0.76	1726	5.48	4.17	0.76	1791	4.54	3.46	0.76	1859
	26	20	4.81	3.08	0.64	481	4.81	3.08	0.64	530	4.81	3.08	0.64	579	5.34	3.42	0.64	612	5.34	3.42	0.64	678	8.12	5.20	0.64	1359	7.77	4.98	0.64	1429	7.47	4.79	0.64																					

4. CAPACITIES AND SELECTION DATA

				Cooling Operation PERFORMANCE DATA																																																		
				OUTDOOR DB (°C)																																																		
COMBINATION (%)	IDDB (°C)	ID WB (°C)	-15				-7				0				10				15				21				25				27				30				35				40				45				50			
			Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT								
80%	21	18	4.39	2.36	0.54	395	4.39	2.36	0.54	439	4.39	2.36	0.54	483	4.87	2.63	0.54	513	4.87	2.63	0.54	572	7.42	4.00	0.54	1192	7.10	3.82	0.54	1253	6.82	3.68	0.54	1311	6.56	3.54	0.54	1371	6.19	3.34	0.54	1461	5.68	3.06	0.54	1551	5.26	2.83	0.54	1610	4.36	2.35	0.54	1671
	21	20	4.61	1.93	0.42	435	4.61	1.93	0.42	479	4.61	1.93	0.42	523	5.12	2.15	0.42	553	5.12	2.15	0.42	612	7.80	3.26	0.42	1225	7.46	3.12	0.42	1288	7.17	3.00	0.42	1347	6.90	2.89	0.42	1409	6.51	2.72	0.42	1501	5.97	2.50	0.42	1594	5.52	2.31	0.42	1654	4.59	1.92	0.42	1717
	22	18	4.39	2.54	0.58	395	4.39	2.54	0.58	439	4.39	2.54	0.58	483	4.87	2.82	0.58	513	4.87	2.82	0.58	572	7.42	4.29	0.58	1192	7.10	4.11	0.58	1253	6.82	3.95	0.58	1311	6.56	3.80	0.58	1371	6.19	3.58	0.58	1461	5.68	3.29	0.58	1551	5.26	3.04	0.58	1610	4.36	2.53	0.58	1671
	22	20	4.61	2.12	0.46	435	4.61	2.12	0.46	479	4.61	2.12	0.46	523	5.12	2.35	0.46	553	5.12	2.35	0.46	612	7.80	3.58	0.46	1225	7.46	3.42	0.46	1288	7.17	3.29	0.46	1347	6.90	3.16	0.46	1409	6.51	2.98	0.46	1501	5.97	2.74	0.46	1594	5.52	2.53	0.46	1654	4.59	2.10	0.46	1717
	22	22	4.89	1.66	0.34	474	4.89	1.66	0.34	518	4.89	1.66	0.34	562	5.43	1.84	0.34	592	5.43	1.84	0.34	651	8.26	2.80	0.34	1256	7.91	2.68	0.34	1321	7.60	2.58	0.34	1382	7.31	2.48	0.34	1446	6.90	2.34	0.34	1540	6.33	2.14	0.34	1635	5.86	1.98	0.34	1697	4.86	1.65	0.34	1762
	23	18	4.39	2.72	0.62	395	4.39	2.72	0.62	439	4.39	2.72	0.62	483	4.87	3.02	0.62	513	4.87	3.02	0.62	572	7.42	4.59	0.62	1192	7.10	4.39	0.62	1253	6.82	4.22	0.62	1311	6.56	4.06	0.62	1371	6.19	3.83	0.62	1461	5.68	3.52	0.62	1551	5.26	3.25	0.62	1610	4.36	2.70	0.62	1671
	23	20	4.61	2.30	0.50	435	4.61	2.30	0.50	479	4.61	2.30	0.50	523	5.12	2.56	0.50	553	5.12	2.56	0.50	612	7.80	3.89	0.50	1225	7.46	3.72	0.50	1288	7.17	3.58	0.50	1347	6.90	3.44	0.50	1409	6.51	3.25	0.50	1501	5.97	2.98	0.50	1594	5.52	2.76	0.50	1654	4.59	2.29	0.50	1717
	23	22	4.89	1.85	0.38	474	4.89	1.85	0.38	518	4.89	1.85	0.38	562	5.43	2.06	0.38	592	5.43	2.06	0.38	651	8.26	3.13	0.38	1256	7.91	2.99	0.38	1321	7.60	2.88	0.38	1382	7.31	2.77	0.38	1446	6.90	2.61	0.38	1540	6.33	2.40	0.38	1635	5.86	2.22	0.38	1697	4.86	1.84	0.38	1762
	24	18	4.39	2.89	0.66	395	4.39	2.89	0.66	439	4.39	2.89	0.66	483	4.87	3.21	0.66	513	4.87	3.21	0.66	572	7.42	4.89	0.66	1192	7.10	4.68	0.66	1253	6.82	4.50	0.66	1311	6.56	4.32	0.66	1371	6.19	4.08	0.66	1461	5.68	3.74	0.66	1551	5.26	3.46	0.66	1610	4.36	2.87	0.66	1671
	24	20	4.61	2.49	0.54	435	4.61	2.49	0.54	479	4.61	2.49	0.54	523	5.12	2.76	0.54	553	5.12	2.76	0.54	612	7.80	4.20	0.54	1225	7.46	4.02	0.54	1288	7.17	3.86	0.54	1347	6.90	3.72	0.54	1409	6.51	3.51	0.54	1501	5.97	3.22	0.54	1594	5.52	2.98	0.54	1654	4.59	2.47	0.54	1717
	24	22	4.89	2.05	0.42	474	4.89	2.05	0.42	518	4.89	2.05	0.42	562	5.43	2.27	0.42	592	5.43	2.27	0.42	651	8.26	3.46	0.42	1256	7.91	3.31	0.42	1321	7.60	3.18	0.42	1382	7.31	3.06	0.42	1446	6.90	2.89	0.42	1540	6.33	2.65	0.42	1635	5.86	2.45	0.42	1697	4.86	2.04	0.42	1762
	24	24	5.18	1.55	0.30	514	5.18	1.55	0.30	558	5.18	1.55	0.30	602	5.76	1.72	0.30	632	5.76	1.72	0.30	691	8.76	2.62	0.30	1289	8.38	2.50	0.30	1356	8.06	2.41	0.30	1418	7.75	2.32	0.30	1483	7.31	2.18	0.30	1580	6.71	2.01	0.30	1677	6.21	1.85	0.30	1741	5.15	1.54	0.30	1807
	25	18	4.39	3.07	0.70	395	4.39	3.07	0.70	439	4.39	3.07	0.70	483	4.87	3.41	0.70	513	4.87	3.41	0.70	572	7.42	5.18	0.70	1192	7.10	4.96	0.70	1253	6.82	4.77	0.70	1311	6.56	4.59	0.70	1371	6.19	4.33	0.70	1461	5.68	3.97	0.70	1551	5.26	3.67	0.70	1610	4.36	3.05	0.70	1671
	25	20	4.61	2.67	0.58	435	4.61	2.67	0.58	479	4.61	2.67	0.58	523	5.12	2.97	0.58	553	5.12	2.97	0.58	612	7.80	4.51	0.58	1225	7.46	4.32	0.58	1288	7.17	4.15	0.58	1347	6.90	3.99	0.58	1409	6.51	3.77	0.58	1501	5.97	3.46	0.58	1594	5.52	3.20	0.58	1654	4.59	2.65	0.58	1717
	25	22	4.89	2.24	0.46	474	4.89	2.24	0.46	518	4.89	2.24	0.46	562	5.43	2.49	0.46	592	5.43	2.49	0.46	651	8.26	3.79	0.46	1256	7.91	3.63	0.46	1321	7.60	3.49	0.46	1382	7.31	3.35	0.46	1446	6.90	3.16	0.46	1540	6.33	2.90	0.46	1635	5.86	2.69	0.46	1697	4.86	2.23	0.46	1762
	25	24	5.18	1.76	0.34	514	5.18	1.76	0.34	558	5.18	1.76	0.34	602	5.76	1.95	0.34	632	5.76	1.95	0.34	691	8.76	2.97	0.34	1289	8.38	2.84	0.34	1356	8.06	2.73	0.34	1418	7.75	2.63	0.34	1483	7.31	2.48	0.34	1580	6.71	2.27	0.34	1677	6.21	2.10	0.34	1741	5.15	1.75	0.34	1807
	26	18	4.39	3.24	0.74	395	4.39	3.24	0.74	439	4.39	3.24	0.74	483	4.87	3.60	0.74	513	4.87	3.60	0.74	572	7.42	5.48	0.74	1192	7.10	5.24	0.74	1253	6.82	5.04	0.74	1311	6.56	4.85	0.74	1371	6.19	4.57	0.74	1461	5.68	4.20	0.74	1551	5.26	3.88	0.74	1610	4.36	3.22	0.74	1671
	26	20	4.61	2.85	0.62	435	4.61	2.85	0.62	479	4.61	2.85	0.62	523	5.12	3.17	0.62	553	5.12	3.17	0.62	612	7.80	4.82	0.62	1225	7.46	4.62	0.62	1288	7.17	4.44	0.62	1347	6.90	4.27	0.62	1409	6.51	4.03	0.62	150												

4. CAPACITIES AND SELECTION DATA

24K (Up to 3 IDUs)

HEATING PERFORMANCE DATA

COMBINATION (%)	INDOOR DB(°C)	OUTDOOR WB(°C)															
		-15		-10		-5		0		5		10		15		20	
		Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT
130%	15	5.78	1872	6.80	1930	7.56	1949	8.31	1989	9.03	2093	9.75	2198	10.24	2264	10.55	2309
	16	5.71	1887	6.72	1945	7.47	1965	8.21	2005	8.92	2110	9.64	2216	10.12	2282	10.42	2328
	17	5.65	1902	6.64	1961	7.38	1981	8.11	2021	8.82	2127	9.52	2234	10.00	2301	10.30	2347
	18	5.58	1917	6.56	1977	7.29	1997	8.01	2037	8.71	2145	9.41	2252	9.88	2319	10.18	2366
	19	5.51	1933	6.49	1993	7.21	2013	7.92	2054	8.61	2162	9.30	2270	9.76	2338	10.05	2385
	20	5.46	1948	6.42	2009	7.14	2029	7.84	2070	8.52	2179	9.21	2288	9.67	2357	9.96	2404
	21	5.39	1970	6.35	2031	7.05	2051	7.75	2093	8.42	2203	9.09	2313	9.55	2383	9.84	2430
	22	5.33	1991	6.27	2053	6.97	2074	7.65	2116	8.32	2227	8.99	2339	9.43	2409	9.72	2457
	23	5.26	2013	6.19	2076	6.88	2097	7.56	2139	8.22	2252	8.88	2365	9.32	2435	9.60	2484
	24	5.20	2035	6.12	2098	6.80	2120	7.47	2163	8.12	2277	8.77	2391	9.21	2462	9.49	2512
	25	5.14	2058	6.05	2122	6.72	2143	7.38	2187	8.02	2302	8.67	2417	9.10	2489	9.37	2539
	26	5.08	2081	5.97	2145	6.64	2167	7.29	2211	7.93	2327	8.56	2443	8.99	2517	9.26	2567
	27	5.02	2103	5.90	2168	6.56	2190	7.21	2235	7.83	2353	8.46	2470	8.88	2544	9.15	2595
	28	4.96	2127	5.83	2192	6.48	2214	7.12	2260	7.74	2379	8.36	2498	8.78	2572	9.04	2624
	29	4.90	2150	5.76	2216	6.40	2239	7.03	2285	7.65	2405	8.26	2525	8.67	2601	8.93	2653
	30	4.84	2174	5.69	2241	6.32	2263	6.95	2310	7.55	2431	8.16	2553	8.57	2629	8.82	2682
COMBINATION (%)	INDOOR DB(°C)	OUTDOOR WB(°C)															
		-15		-10		-5		0		5		10		15		20	
		Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT
120%	15	5.61	1783	6.61	1838	7.34	1856	8.06	1894	8.77	1994	9.47	2093	9.94	2156	10.24	2199
	16	5.55	1797	6.53	1852	7.25	1871	7.97	1909	8.66	2010	9.36	2110	9.82	2174	10.12	2217
	17	5.48	1811	6.45	1867	7.17	1886	7.87	1925	8.56	2026	9.24	2127	9.71	2191	10.00	2235
	18	5.42	1826	6.37	1882	7.08	1901	7.78	1940	8.46	2042	9.13	2145	9.59	2209	9.88	2253
	19	5.35	1841	6.30	1898	7.00	1917	7.69	1956	8.36	2059	9.03	2162	9.48	2227	9.76	2271
	20	5.30	1856	6.24	1913	6.93	1932	7.61	1972	8.28	2075	8.94	2179	9.38	2245	9.67	2290
	21	5.24	1876	6.16	1934	6.84	1954	7.52	1993	8.18	2098	8.83	2203	9.27	2269	9.55	2315
	22	5.17	1897	6.09	1955	6.76	1975	7.43	2015	8.08	2121	8.72	2227	9.16	2294	9.43	2340
	23	5.11	1917	6.01	1977	6.68	1997	7.34	2037	7.98	2145	8.62	2252	9.05	2320	9.32	2366
	24	5.05	1939	5.94	1999	6.60	2019	7.25	2060	7.88	2168	8.52	2277	8.94	2345	9.21	2392
	25	4.99	1960	5.87	2021	6.52	2041	7.17	2083	7.79	2192	8.41	2302	8.83	2371	9.10	2418
	26	4.93	1981	5.80	2043	6.44	2063	7.08	2105	7.70	2216	8.31	2327	8.73	2397	8.99	2445
	27	4.87	2003	5.73	2065	6.37	2086	7.00	2129	7.60	2241	8.21	2353	8.62	2423	8.88	2472
	28	4.81	2025	5.66	2088	6.29	2109	6.91	2152	7.51	2265	8.11	2379	8.52	2450	8.78	2499
	29	4.75	2048	5.59	2111	6.21	2132	6.83	2176	7.42	2290	8.02	2405	8.42	2477	8.67	2526
	30	4.70	2070	5.53	2134	6.14	2156	6.75	2200	7.33	2315	7.92	2431	8.32	2504	8.57	2554
COMBINATION (%)	INDOOR DB(°C)	OUTDOOR WB(°C)															
		-15		-10		-5		0		5		10		15		20	
		Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT
110%	15	5.45	1748	6.41	1802	7.13	1820	7.83	1857	8.51	1955	9.19	2052	9.65	2114	9.94	2156
	16	5.39	1762	6.34	1816	7.04	1834	7.74	1872	8.41	1970	9.08	2069	9.54	2131	9.82	2174
	17	5.32	1776	6.26	1831	6.96	1849	7.65	1887	8.31	1986	8.98	2086	9.42	2148	9.71	2191
	18	5.26	1790	6.19	1846	6.87	1864	7.55	1902	8.21	2002	8.87	2102	9.31	2166	9.59	2209
	19	5.20	1805	6.11	1860	6.79	1879	7.47	1918	8.11	2019	8.76	2119	9.20	2183	9.48	2227
	20	5.15	1819	6.05	1875	6.73	1894	7.39	1933	8.03	2035	8.68	2137	9.11	2201	9.38	2245
	21	5.08	1839	5.98	1896	6.65	1915	7.30	1954	7.94	2057	8.57	2160	9.00	2225	9.27	2269
	22	5.02	1859	5.91	1917	6.57	1936	7.21	1976	7.84	2080	8.47	2184	8.89	2249	9.16	2294
	23	4.96	1880	5.84	1938	6.49	1958	7.13	1998	7.75	2103	8.37	2208	8.79	2274	9.05	2320
	24	4.90	1901	5.77	1959	6.41	1979	7.04	2020	7.66	2126	8.27	2232	8.68	2299	8.94	2345
	25	4.84	1921	5.70	1981	6.33	2001	6.96	2042	7.56	2149	8.17	2257	8.58	2324	8.83	2371
	26	4.79	1943	5.63	2003	6.26	2023	6.87	2064	7.47	2173	8.07	2281	8.47	2350	8.73	2397
	27	4.73	1964	5.56	2025	6.18	2045	6.79	2087	7.38	2197	7.97	2307	8.37	2376	8.62	2423
	28	4.67	1986	5.50	2047	6.11	2068	6.71	2110	7.29	2221	7.88	2332	8.27	2402	8.52	2450
	29	4.62	2007	5.43	2069	6.03	2090	6.63	2133	7.21	2245	7.78	2358	8.17	2428	8.42	2477
	30	4.56	2029	5.37	2092	5.96	2113	6.55	2157	7.12	2270	7.69	2384	8.07	2455	8.32	2504

4. CAPACITIES AND SELECTION DATA

COMBINATION (%)	INDOOR DB(°C)	OUTDOOR WB(°C)															
		-15		-10		-5		0		5		10		15		20	
		Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT
100%	15	5.29	1697	6.23	1749	6.92	1767	7.60	1803	8.26	1898	8.92	1993	9.37	2052	9.65	2093
	16	5.23	1710	6.15	1763	6.84	1781	7.51	1817	8.17	1913	8.82	2009	9.26	2069	9.54	2110
	17	5.17	1724	6.08	1777	6.75	1795	7.42	1832	8.07	1928	8.71	2025	9.15	2086	9.42	2127
	18	5.11	1738	6.01	1792	6.67	1810	7.33	1847	7.97	1944	8.61	2041	9.04	2102	9.31	2145
	19	5.05	1752	5.94	1806	6.60	1824	7.25	1862	7.88	1960	8.51	2058	8.93	2119	9.20	2162
	20	5.00	1766	5.88	1821	6.53	1839	7.18	1877	7.80	1976	8.42	2074	8.85	2137	9.11	2179
	21	4.94	1786	5.81	1841	6.45	1859	7.09	1897	7.71	1997	8.32	2097	8.74	2160	9.00	2203
	22	4.88	1805	5.74	1861	6.37	1880	7.00	1918	7.61	2019	8.22	2120	8.63	2184	8.89	2227
	23	4.82	1825	5.67	1882	6.30	1901	6.92	1939	7.52	2041	8.12	2144	8.53	2208	8.79	2252
	24	4.76	1845	5.60	1902	6.22	1921	6.84	1961	7.43	2064	8.03	2167	8.43	2232	8.68	2277
	25	4.70	1865	5.53	1923	6.15	1943	6.76	1982	7.34	2087	7.93	2191	8.33	2257	8.58	2302
	26	4.65	1886	5.47	1944	6.07	1964	6.67	2004	7.25	2110	7.84	2215	8.23	2281	8.47	2327
	27	4.59	1907	5.40	1966	6.00	1986	6.59	2026	7.17	2133	7.74	2239	8.13	2307	8.37	2353
	28	4.54	1928	5.34	1987	5.93	2007	6.52	2048	7.08	2156	7.65	2264	8.03	2332	8.27	2379
	29	4.48	1949	5.27	2009	5.86	2030	6.44	2071	7.00	2180	7.56	2289	7.93	2358	8.17	2405
	30	4.43	1970	5.21	2031	5.79	2052	6.36	2094	6.91	2204	7.47	2314	7.84	2384	8.07	2431
COMBINATION (%)	INDOOR DB(°C)	OUTDOOR WB(°C)															
		-15		-10		-5		0		5		10		15		20	
		Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT
90%	15	5.11	1666	6.01	1718	6.68	1735	7.34	1770	7.97	1864	8.61	1957	9.04	2015	9.31	2056
	16	5.05	1680	5.94	1732	6.60	1749	7.25	1785	7.88	1879	8.51	1973	8.94	2032	9.20	2072
	17	4.99	1693	5.87	1745	6.52	1763	7.16	1799	7.79	1894	8.41	1988	8.83	2048	9.09	2089
	18	4.93	1707	5.80	1760	6.44	1777	7.08	1814	7.69	1909	8.31	2004	8.72	2065	8.99	2106
	19	4.87	1721	5.73	1774	6.36	1792	6.99	1828	7.60	1924	8.21	2021	8.62	2081	8.88	2123
	20	4.82	1734	5.67	1788	6.30	1806	6.92	1843	7.53	1940	8.13	2037	8.54	2098	8.79	2140
	21	4.76	1753	5.60	1808	6.23	1826	6.84	1863	7.44	1961	8.03	2059	8.43	2121	8.69	2164
	22	4.71	1773	5.54	1828	6.15	1846	6.76	1884	7.35	1983	7.94	2082	8.33	2144	8.58	2187
	23	4.65	1792	5.47	1848	6.08	1866	6.68	1904	7.26	2005	7.84	2105	8.23	2168	8.48	2211
	24	4.59	1812	5.40	1868	6.00	1887	6.60	1925	7.17	2027	7.75	2128	8.13	2192	8.38	2236
	25	4.54	1832	5.34	1889	5.93	1908	6.52	1947	7.09	2049	7.65	2151	8.04	2216	8.28	2260
	26	4.48	1852	5.28	1909	5.86	1929	6.44	1968	7.00	2072	7.56	2175	7.94	2240	8.18	2285
	27	4.43	1872	5.21	1930	5.79	1950	6.36	1990	6.92	2094	7.47	2199	7.84	2265	8.08	2310
	28	4.38	1893	5.15	1952	5.72	1971	6.29	2012	6.83	2117	7.38	2223	7.75	2290	7.98	2336
	29	4.32	1914	5.09	1973	5.65	1993	6.21	2034	6.75	2141	7.29	2248	7.66	2315	7.89	2361
	30	4.27	1935	5.03	1995	5.58	2015	6.14	2056	6.67	2164	7.20	2272	7.56	2341	7.79	2387
COMBINATION (%)	INDOOR DB(°C)	OUTDOOR WB(°C)															
		-15	-10	-5	0	5	10	15	20	-15	-10	-5	0	5	10	15	20
		Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT
80%	15	4.95	1649	5.83	1700	6.48	1718	7.12	1753	7.73	1845	8.35	1937	8.77	1995	9.03	2035
	16	4.89	1663	5.76	1714	6.40	1732	7.03	1767	7.64	1860	8.25	1953	8.67	2011	8.93	2052
	17	4.84	1676	5.69	1728	6.32	1745	6.95	1781	7.55	1875	8.16	1969	8.56	2028	8.82	2068
	18	4.78	1690	5.62	1742	6.25	1760	6.87	1795	7.46	1890	8.06	1984	8.46	2044	8.72	2085
	19	4.72	1703	5.56	1756	6.17	1774	6.78	1810	7.37	1905	7.96	2000	8.36	2060	8.61	2102
	20	4.68	1717	5.50	1770	6.11	1788	6.72	1825	7.30	1921	7.89	2017	8.28	2077	8.53	2119
	21	4.62	1736	5.44	1790	6.04	1808	6.64	1845	7.21	1942	7.79	2039	8.18	2100	8.43	2142
	22	4.56	1755	5.37	1809	5.97	1828	6.56	1865	7.13	1963	7.70	2061	8.08	2123	8.32	2165
	23	4.51	1774	5.31	1829	5.90	1848	6.48	1885	7.04	1985	7.60	2084	7.99	2146	8.22	2189
	24	4.46	1794	5.24	1849	5.82	1868	6.40	1906	6.96	2006	7.51	2107	7.89	2170	8.13	2213
	25	4.40	1814	5.18	1870	5.75	1889	6.32	1927	6.87	2029	7.42	2130	7.79	2194	8.03	2238
	26	4.35	1834	5.12	1890	5.69	1909	6.25	1948	6.79	2051	7.33	2153	7.70	2218	7.93	2262
	27	4.30	1854	5.06	1911	5.62	1930	6.17	1970	6.71	2073	7.25	2177	7.61	2242	7.84	2287
	28	4.25	1874	4.99	1932	5.55	1952	6.10	1991	6.63	2096	7.16	2201	7.52	2267	7.74	2312
	29	4.19	1895	4.93	1953	5.48	1973	6.03	2013	6.55	2119	7.07	2225	7.43	2292	7.65	2338
	30	4.14	1916	4.88	1975	5.42	1995	5.95	2035	6.47	2143	6.99	2250	7.34	2317	7.56	2364

Remarks:
 Q: Total Cooling Capacity (Gross) **kW**
 INPUT: Power Input (including the compressor, evap. fan motor & cond. **W**
 DB: Dry Bulb Temperature
 WB: Wet Bulb Temperature

4AMW81U4RJC

-

UE MULTI 4 POSTES 8,1 KW

4. CAPACITIES AND SELECTION DATA

27K

	Cooling Operation PERFORMANCE DATA																																																					
	OUTDOOR DB (°C)																																																					
COMBINATION (%)	IDDB (°C)	ID WB (°C)	-15				-7				0				10				15				21				25				27				30				35				40				45				50			
			Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT												
130%	21	18	8.21	4.93	0.60	1629	8.13	4.88	0.60	1644	8.04	4.82	0.60	1659	7.94	4.76	0.60	1672	7.86	4.71	0.60	1681	7.77	4.66	0.60	1736	7.66	4.60	0.60	1813	7.53	4.52	0.60	1935	7.35	4.41	0.60	2025	7.14	4.28	0.60	2101	6.55	3.93	0.60	2232	5.41	3.24	0.60	2317	4.46	2.68	0.60	2405
	21	20	8.55	4.10	0.48	1652	8.46	4.06	0.48	1667	8.37	4.02	0.48	1682	8.26	3.97	0.48	1696	8.18	3.93	0.48	1704	8.09	3.88	0.48	1760	7.98	3.83	0.48	1836	7.84	3.76	0.48	1959	7.66	3.67	0.48	2049	7.43	3.57	0.48	2124	6.82	3.28	0.48	2255	5.63	2.70	0.48	2340	4.64	2.23	0.48	2429
	22	18	8.46	5.42	0.64	1645	8.38	5.36	0.64	1660	8.29	5.30	0.64	1675	8.18	5.24	0.64	1689	8.10	5.18	0.64	1697	8.01	5.13	0.64	1754	7.90	5.06	0.64	1831	7.76	4.97	0.64	1955	7.58	4.85	0.64	2045	7.36	4.71	0.64	2122	6.76	4.32	0.64	2254	5.57	3.57	0.64	2340	4.60	2.94	0.64	2430
	22	20	8.72	4.54	0.52	1669	8.64	4.49	0.52	1684	8.54	4.44	0.52	1699	8.43	4.38	0.52	1713	8.35	4.34	0.52	1721	8.26	4.29	0.52	1778	8.14	4.23	0.52	1855	8.00	4.16	0.52	1979	7.81	4.06	0.52	2069	7.58	3.94	0.52	2146	6.96	3.62	0.52	2278	5.74	2.99	0.52	2364	4.74	2.46	0.52	2453
	22	22	8.87	3.55	0.40	1685	8.78	3.51	0.40	1700	8.69	3.47	0.40	1715	8.58	3.43	0.40	1729	8.49	3.40	0.40	1737	8.40	3.36	0.40	1794	8.28	3.31	0.40	1871	8.14	3.25	0.40	1995	7.95	3.18	0.40	2085	7.71	3.09	0.40	2162	7.08	2.83	0.40	2294	5.84	2.34	0.40	2380	4.82	1.93	0.40	2470
	23	18	8.64	5.87	0.68	1662	8.55	5.81	0.68	1677	8.46	5.75	0.68	1692	8.35	5.68	0.68	1706	8.27	5.62	0.68	1715	8.18	5.56	0.68	1772	8.06	5.48	0.68	1850	7.92	5.39	0.68	1975	7.73	5.26	0.68	2066	7.51	5.11	0.68	2144	6.89	4.69	0.68	2277	5.69	3.87	0.68	2364	4.69	3.19	0.68	2454
	23	20	8.90	4.98	0.56	1686	8.81	4.93	0.56	1701	8.72	4.88	0.56	1716	8.60	4.82	0.56	1730	8.52	4.77	0.56	1739	8.43	4.72	0.56	1796	8.31	4.65	0.56	1874	8.16	4.57	0.56	1999	7.97	4.46	0.56	2090	7.74	4.33	0.56	2168	7.10	3.98	0.56	2301	5.86	3.28	0.56	2388	4.84	2.71	0.56	2478
	23	22	9.05	3.98	0.44	1702	8.96	3.94	0.44	1717	8.86	3.90	0.44	1733	8.75	3.85	0.44	1746	8.66	3.81	0.44	1755	8.57	3.77	0.44	1812	8.45	3.72	0.44	1890	8.30	3.65	0.44	2015	8.11	3.57	0.44	2106	7.87	3.46	0.44	2184	7.23	3.18	0.44	2317	5.96	2.62	0.44	2404	4.92	2.16	0.44	2495
	24	18	8.81	6.34	0.72	1679	8.72	6.28	0.72	1694	8.63	6.21	0.72	1709	8.52	6.13	0.72	1723	8.43	6.07	0.72	1732	8.34	6.01	0.72	1790	8.23	5.92	0.72	1868	8.08	5.82	0.72	1995	7.89	5.68	0.72	2087	7.66	5.52	0.72	2165	7.03	5.06	0.72	2300	5.80	4.18	0.72	2388	4.79	3.45	0.72	2479
	24	20	9.08	5.45	0.60	1703	8.99	5.40	0.60	1718	8.89	5.34	0.60	1734	8.78	5.27	0.60	1748	8.69	5.22	0.60	1756	8.60	5.16	0.60	1814	8.48	5.09	0.60	1893	8.33	5.00	0.60	2019	8.13	4.88	0.60	2111	7.90	4.74	0.60	2190	7.25	4.35	0.60	2324	5.98	3.59	0.60	2412	4.93	2.96	0.60	2503
	24	22	9.24	4.43	0.48	1719	9.14	4.39	0.48	1735	9.05	4.34	0.48	1750	8.93	4.29	0.48	1764	8.84	4.24	0.48	1773	8.74	4.20	0.48	1830	8.62	4.14	0.48	1909	8.47	4.07	0.48	2035	8.27	3.97	0.48	2128	8.03	3.86	0.48	2206	7.37	3.54	0.48	2341	6.08	2.92	0.48	2429	5.02	2.41	0.48	2520
	24	24	9.37	3.37	0.36	1739	9.27	3.34	0.36	1754	9.17	3.30	0.36	1770	9.05	3.26	0.36	1783	8.96	3.23	0.36	1792	8.87	3.19	0.36	1850	8.74	3.15	0.36	1929	8.59	3.09	0.36	2055	8.39	3.02	0.36	2147	8.14	2.93	0.36	2225	7.48	2.69	0.36	2360	6.17	2.22	0.36	2448	5.09	1.83	0.36	2539
	25	18	9.08	6.90	0.76	1696	8.99	6.84	0.76	1711	8.90	6.76	0.76	1727	8.78	6.67	0.76	1741	8.70	6.61	0.76	1749	8.60	6.54	0.76	1808	8.48	6.45	0.76	1887	8.33	6.33	0.76	2015	8.14	6.18	0.76	2108	7.90	6.00	0.76	2187	7.25	5.51	0.76	2323	5.98	4.55	0.76	2412	4.94	3.75	0.76	2504
	25	20	9.36	5.99	0.64	1720	9.27	5.93	0.64	1736	9.17	5.87	0.64	1751	9.05	5.79	0.64	1765	8.96	5.74	0.64	1774	8.86	5.67	0.64	1832	8.74	5.59	0.64	1912	8.59	5.50	0.64	2039	8.39	5.37	0.64	2133	8.14	5.21	0.64	2212	7.47	4.78	0.64	2348	6.17	3.95	0.64	2436	5.09	3.26	0.64	2529
	25	22	9.52	4.95	0.52	1737	9.43	4.90	0.52	1752	9.32	4.85	0.52	1768	9.21	4.79	0.52	1782	9.11	4.74	0.52	1791	9.01	4.69	0.52	1849	8.89	4.62	0.52	1928	8.73	4.54	0.52	2056	8.53	4.43	0.52	2149	8.28	4.31	0.52	2228	7.60	3.95	0.52	2364	6.27	3.26	0.52	2453	5.17	2.69	0.52	2545
	25	24	9.65	3.86	0.40	1756	9.56	3.82	0.40	1772	9.46	3.78	0.40	1787	9.33	3.73	0.40	1801	9.24	3.70	0.40	1810	9.14	3.66	0.40	1868	9.01	3.61	0.40	1948	8.86	3.54	0.40	2076	8.65	3.46	0.40	2169	8.40	3.36	0.40	2248	7.71	3.08	0.40	2384	6.36	2.54	0.40	2473	5.25	2.10	0.40	2565
	26	18	9.37	7.49	0.80	1713	9.27	7.42	0.80	1728	9.17	7.34	0.80	1744	9.05	7.24	0.80	1758	8.96	7.17	0.80	1767	8.87	7.09	0.80	1826	8.74	7.00	0.80	1906	8.59	6.87	0.80	2035	8.39	6.71	0.80	2129	8.14	6.52	0.80	2209	7.48	5.98	0.80	2347	6.17	4.93	0.80	2436	5.09	4.07	0.80	2529
	26	20	9.65	6.56	0.68	1737	9.56	6.50	0.68	1753	9.45	6.43	0.68	1769	9.33	6.35	0.68	1783	9.24	6.28	0.68	1792	9.14	6.21	0.68	1851	9.01	6.13	0.68	1931	8.85	6.02	0.68	2060	8.65	5.88	0.68	2																

4. CAPACITIES AND SELECTION DATA

			Cooling Operation PERFORMANCE DATA																																																			
			OUTDOOR DB (°C)																																																			
COMBINATION (%)	IDDB (°C)	ID WB (°C)	-15				-7				0				10				15				21				25				27				30				35				40				45				50			
			Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT												
120%	21	18	8.13	4.88	0.60	1613	8.05	4.83	0.60	1628	7.96	4.78	0.60	1643	7.86	4.72	0.60	1656	7.78	4.67	0.60	1664	7.70	4.62	0.60	1720	7.59	4.56	0.60	1795	7.46	4.47	0.60	1917	7.28	4.37	0.60	2005	7.07	4.24	0.60	2081	6.49	3.89	0.60	2210	5.36	3.21	0.60	2295	4.42	2.65	0.60	2382
	21	20	8.47	4.06	0.48	1637	8.38	4.02	0.48	1651	8.29	3.98	0.48	1666	8.19	3.93	0.48	1680	8.10	3.89	0.48	1688	8.02	3.85	0.48	1743	7.91	3.79	0.48	1819	7.77	3.73	0.48	1940	7.58	3.64	0.48	2029	7.36	3.53	0.48	2104	6.76	3.24	0.48	2234	5.58	2.68	0.48	2318	4.60	2.21	0.48	2406
	22	18	8.38	5.37	0.64	1629	8.30	5.31	0.64	1644	8.21	5.25	0.64	1659	8.10	5.19	0.64	1673	8.02	5.14	0.64	1681	7.94	5.08	0.64	1737	7.83	5.01	0.64	1814	7.69	4.92	0.64	1936	7.51	4.81	0.64	2026	7.29	4.67	0.64	2102	6.69	4.28	0.64	2233	5.52	3.53	0.64	2318	4.55	2.92	0.64	2406
	22	20	8.64	4.49	0.52	1653	8.55	4.45	0.52	1668	8.46	4.40	0.52	1683	8.35	4.34	0.52	1696	8.27	4.30	0.52	1705	8.18	4.25	0.52	1761	8.07	4.19	0.52	1837	7.92	4.12	0.52	1960	7.74	4.02	0.52	2050	7.51	3.91	0.52	2126	6.90	3.59	0.52	2256	5.69	2.96	0.52	2342	4.69	2.44	0.52	2430
	22	22	8.79	3.51	0.40	1669	8.70	3.48	0.40	1684	8.60	3.44	0.40	1699	8.49	3.40	0.40	1713	8.41	3.36	0.40	1721	8.32	3.33	0.40	1777	8.20	3.28	0.40	1854	8.06	3.22	0.40	1976	7.87	3.15	0.40	2066	7.64	3.06	0.40	2142	7.01	2.81	0.40	2273	5.79	2.31	0.40	2358	4.77	1.91	0.40	2446
	23	18	8.55	5.82	0.68	1646	8.47	5.76	0.68	1661	8.38	5.70	0.68	1676	8.27	5.62	0.68	1690	8.19	5.57	0.68	1698	8.10	5.51	0.68	1755	7.99	5.43	0.68	1832	7.85	5.34	0.68	1956	7.66	5.21	0.68	2046	7.44	5.06	0.68	2123	6.83	4.64	0.68	2255	5.63	3.83	0.68	2341	4.65	3.16	0.68	2431
	23	20	8.82	4.94	0.56	1670	8.73	4.89	0.56	1685	8.63	4.83	0.56	1700	8.52	4.77	0.56	1714	8.44	4.73	0.56	1722	8.35	4.67	0.56	1779	8.23	4.61	0.56	1856	8.09	4.53	0.56	1980	7.90	4.42	0.56	2070	7.67	4.29	0.56	2147	7.04	3.94	0.56	2279	5.81	3.25	0.56	2365	4.79	2.68	0.56	2455
	23	22	8.97	3.95	0.44	1686	8.88	3.91	0.44	1701	8.78	3.86	0.44	1716	8.67	3.81	0.44	1730	8.58	3.78	0.44	1738	8.49	3.74	0.44	1795	8.37	3.68	0.44	1872	8.22	3.62	0.44	1996	8.03	3.53	0.44	2087	7.80	3.43	0.44	2163	7.16	3.15	0.44	2296	5.90	2.60	0.44	2382	4.87	2.14	0.44	2471
	24	18	8.73	6.28	0.72	1662	8.64	6.22	0.72	1678	8.55	6.15	0.72	1693	8.44	6.08	0.72	1707	8.36	6.02	0.72	1715	8.26	5.95	0.72	1772	8.15	5.87	0.72	1850	8.01	5.76	0.72	1976	7.82	5.63	0.72	2067	7.59	5.47	0.72	2144	6.97	5.02	0.72	2278	5.75	4.14	0.72	2365	4.74	3.41	0.72	2455
	24	20	9.00	5.40	0.60	1687	8.91	5.34	0.60	1702	8.81	5.29	0.60	1717	8.70	5.22	0.60	1731	8.61	5.17	0.60	1740	8.52	5.11	0.60	1797	8.40	5.04	0.60	1875	8.25	4.95	0.60	2000	8.06	4.83	0.60	2091	7.82	4.69	0.60	2169	7.18	4.31	0.60	2302	5.92	3.55	0.60	2389	4.89	2.93	0.60	2479
	24	22	9.15	4.39	0.48	1703	9.06	4.35	0.48	1718	8.96	4.30	0.48	1734	8.84	4.25	0.48	1747	8.76	4.20	0.48	1756	8.66	4.16	0.48	1813	8.54	4.10	0.48	1891	8.39	4.03	0.48	2016	8.19	3.93	0.48	2108	7.96	3.82	0.48	2185	7.30	3.51	0.48	2319	6.03	2.89	0.48	2406	4.97	2.39	0.48	2496
	24	24	9.28	3.34	0.36	1723	9.19	3.31	0.36	1738	9.09	3.27	0.36	1753	8.97	3.23	0.36	1767	8.88	3.20	0.36	1775	8.78	3.16	0.36	1832	8.66	3.12	0.36	1911	8.51	3.06	0.36	2036	8.31	2.99	0.36	2127	8.07	2.90	0.36	2205	7.41	2.67	0.36	2338	6.11	2.20	0.36	2425	5.04	1.81	0.36	2515
	25	18	9.00	6.84	0.76	1679	8.91	6.77	0.76	1695	8.81	6.70	0.76	1710	8.70	6.61	0.76	1724	8.61	6.55	0.76	1733	8.52	6.47	0.76	1790	8.40	6.39	0.76	1869	8.25	6.27	0.76	1995	8.06	6.13	0.76	2088	7.83	5.95	0.76	2166	7.18	5.46	0.76	2301	5.93	4.50	0.76	2389	4.89	3.72	0.76	2480
	25	20	9.27	5.94	0.64	1704	9.18	5.88	0.64	1719	9.08	5.81	0.64	1735	8.97	5.74	0.64	1748	8.88	5.68	0.64	1757	8.78	5.62	0.64	1815	8.66	5.54	0.64	1894	8.51	5.44	0.64	2020	8.31	5.32	0.64	2112	8.06	5.16	0.64	2191	7.40	4.74	0.64	2326	6.11	3.91	0.64	2413	5.04	3.22	0.64	2504
	25	22	9.43	4.90	0.52	1720	9.34	4.86	0.52	1736	9.24	4.80	0.52	1751	9.12	4.74	0.52	1765	9.03	4.69	0.52	1774	8.93	4.64	0.52	1831	8.81	4.58	0.52	1910	8.65	4.50	0.52	2037	8.45	4.39	0.52	2129	8.20	4.27	0.52	2207	7.53	3.92	0.52	2342	6.21	3.23	0.52	2430	5.12	2.66	0.52	2521
	25	24	9.56	3.83	0.40	1740	9.47	3.79	0.40	1755	9.37	3.75	0.40	1771	9.25	3.70	0.40	1785	9.15	3.66	0.40	1793	9.05	3.62	0.40	1851	8.93	3.57	0.40	1930	8.77	3.51	0.40	2056	8.57	3.43	0.40	2149	8.32	3.33	0.40	2227	7.63	3.05	0.40	2362	6.30	2.52	0.40	2450	5.20	2.08	0.40	2541
	26	18	9.28	7.42	0.80	1696	9.19	7.35	0.80	1712	9.09	7.27	0.80	1727	8.97	7.17	0.80	1741	8.88	7.10	0.80	1750	8.78	7.03	0.80	1808	8.66	6.93	0.80	1888	8.51	6.81	0.80	2016	8.31	6.65	0.80	2109	8.07	6.45	0.80	2188	7.41	5.92	0.80	2324	6.11	4.89	0.80	2413	5.04	4.03	0.80	2505
	26	20	9.56	6.50	0.68	1721	9.47	6.44	0.68	1736	9.36	6.																																										

4. CAPACITIES AND SELECTION DATA

Cooling Operation PERFORMANCE DATA																																																						
COMBINATION (%)	IDDB (°C)	ID WB (°C)	OUTDOOR DB (°C)																																																			
			-15				-7				0				10				15				21				25				27				30				35				40				45				50			
			Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT								
110%	21	18	7.98	4.79	0.60	1597	7.90	4.74	0.60	1612	7.81	4.69	0.60	1627	7.71	4.63	0.60	1640	7.64	4.58	0.60	1648	7.55	4.53	0.60	1703	7.45	4.47	0.60	1778	7.32	4.39	0.60	1898	7.14	4.29	0.60	1986	6.94	4.16	0.60	2061	6.37	3.82	0.60	2189	5.25	3.15	0.60	2272	4.33	2.60	0.60	2359
	21	20	8.31	3.99	0.48	1621	8.22	3.95	0.48	1636	8.13	3.90	0.48	1650	8.03	3.85	0.48	1663	7.95	3.82	0.48	1672	7.86	3.77	0.48	1727	7.75	3.72	0.48	1802	7.62	3.66	0.48	1922	7.44	3.57	0.48	2010	7.22	3.47	0.48	2084	6.63	3.18	0.48	2212	5.47	2.63	0.48	2296	4.51	2.17	0.48	2383
	22	18	8.22	5.26	0.64	1614	8.14	5.21	0.64	1628	8.05	5.15	0.64	1643	7.95	5.09	0.64	1656	7.87	5.04	0.64	1665	7.79	4.98	0.64	1720	7.68	4.91	0.64	1796	7.54	4.83	0.64	1917	7.37	4.71	0.64	2006	7.15	4.58	0.64	2081	6.56	4.20	0.64	2211	5.42	3.47	0.64	2295	4.47	2.86	0.64	2383
	22	20	8.48	4.41	0.52	1637	8.39	4.36	0.52	1652	8.30	4.32	0.52	1667	8.19	4.26	0.52	1680	8.11	4.22	0.52	1689	8.02	4.17	0.52	1744	7.91	4.11	0.52	1820	7.77	4.04	0.52	1941	7.59	3.95	0.52	2030	7.37	3.83	0.52	2105	6.77	3.52	0.52	2235	5.58	2.90	0.52	2319	4.60	2.39	0.52	2407
	22	22	8.62	3.45	0.40	1653	8.53	3.41	0.40	1668	8.44	3.38	0.40	1683	8.33	3.33	0.40	1696	8.25	3.30	0.40	1705	8.16	3.26	0.40	1760	8.05	3.22	0.40	1836	7.91	3.16	0.40	1957	7.72	3.09	0.40	2046	7.50	3.00	0.40	2121	6.88	2.75	0.40	2251	5.68	2.27	0.40	2335	4.68	1.87	0.40	2423
	23	18	8.39	5.71	0.68	1630	8.31	5.65	0.68	1645	8.22	5.59	0.68	1660	8.11	5.52	0.68	1673	8.03	5.46	0.68	1682	7.94	5.40	0.68	1738	7.83	5.33	0.68	1814	7.70	5.23	0.68	1937	7.52	5.11	0.68	2026	7.30	4.96	0.68	2102	6.70	4.56	0.68	2233	5.53	3.76	0.68	2319	4.56	3.10	0.68	2407
	23	20	8.65	4.84	0.56	1654	8.56	4.79	0.56	1669	8.47	4.74	0.56	1684	8.36	4.68	0.56	1697	8.28	4.64	0.56	1706	8.19	4.59	0.56	1762	8.07	4.52	0.56	1838	7.93	4.44	0.56	1961	7.75	4.34	0.56	2050	7.52	4.21	0.56	2126	6.90	3.87	0.56	2257	5.70	3.19	0.56	2343	4.70	2.63	0.56	2431
	23	22	8.80	3.87	0.44	1670	8.71	3.83	0.44	1685	8.61	3.79	0.44	1700	8.50	3.74	0.44	1714	8.42	3.70	0.44	1722	8.33	3.66	0.44	1778	8.21	3.61	0.44	1854	8.07	3.55	0.44	1977	7.88	3.47	0.44	2067	7.65	3.37	0.44	2143	7.02	3.09	0.44	2274	5.79	2.55	0.44	2359	4.78	2.10	0.44	2447
	24	18	8.56	6.16	0.72	1646	8.48	6.10	0.72	1661	8.39	6.04	0.72	1676	8.28	5.96	0.72	1690	8.20	5.90	0.72	1699	8.11	5.84	0.72	1755	7.99	5.76	0.72	1832	7.85	5.65	0.72	1956	7.67	5.52	0.72	2047	7.45	5.36	0.72	2124	6.84	4.92	0.72	2256	5.64	4.06	0.72	2342	4.65	3.35	0.72	2431
	24	20	8.82	5.29	0.60	1671	8.74	5.24	0.60	1686	8.64	5.19	0.60	1701	8.53	5.12	0.60	1714	8.45	5.07	0.60	1723	8.35	5.01	0.60	1779	8.24	4.94	0.60	1857	8.09	4.86	0.60	1981	7.90	4.74	0.60	2071	7.67	4.60	0.60	2148	7.04	4.23	0.60	2280	5.81	3.49	0.60	2366	4.79	2.88	0.60	2456
	24	22	8.97	4.31	0.48	1687	8.89	4.27	0.48	1702	8.79	4.22	0.48	1717	8.68	4.16	0.48	1731	8.59	4.12	0.48	1739	8.50	4.08	0.48	1796	8.38	4.02	0.48	1873	8.23	3.95	0.48	1997	8.04	3.86	0.48	2088	7.80	3.75	0.48	2164	7.16	3.44	0.48	2297	5.91	2.84	0.48	2383	4.88	2.34	0.48	2472
	24	24	9.10	3.28	0.36	1706	9.01	3.24	0.36	1721	8.91	3.21	0.36	1737	8.80	3.17	0.36	1750	8.71	3.14	0.36	1759	8.62	3.10	0.36	1815	8.50	3.06	0.36	1893	8.35	3.00	0.36	2016	8.15	2.93	0.36	2107	7.91	2.85	0.36	2184	7.26	2.62	0.36	2316	5.99	2.16	0.36	2402	4.94	1.78	0.36	2492
	25	18	8.83	6.71	0.76	1663	8.74	6.64	0.76	1678	8.64	6.57	0.76	1693	8.53	6.49	0.76	1707	8.45	6.42	0.76	1716	8.36	6.35	0.76	1773	8.24	6.26	0.76	1851	8.10	6.15	0.76	1976	7.91	6.01	0.76	2067	7.68	5.83	0.76	2145	7.05	5.36	0.76	2279	5.81	4.42	0.76	2366	4.80	3.65	0.76	2456
	25	20	9.10	5.82	0.64	1687	9.01	5.76	0.64	1703	8.91	5.70	0.64	1718	8.80	5.63	0.64	1732	8.71	5.57	0.64	1740	8.61	5.51	0.64	1797	8.49	5.44	0.64	1875	8.34	5.34	0.64	2001	8.15	5.22	0.64	2092	7.91	5.06	0.64	2170	7.26	4.65	0.64	2303	5.99	3.83	0.64	2390	4.94	3.16	0.64	2480
	25	22	9.25	4.81	0.52	1704	9.16	4.76	0.52	1719	9.06	4.71	0.52	1735	8.94	4.65	0.52	1748	8.86	4.61	0.52	1757	8.76	4.56	0.52	1814	8.64	4.49	0.52	1892	8.49	4.41	0.52	2017	8.29	4.31	0.52	2109	8.05	4.18	0.52	2186	7.39	3.84	0.52	2320	6.09	3.17	0.52	2407	5.03	2.61	0.52	2497
	25	24	9.38	3.75	0.40	1724	9.29	3.72	0.40	1739	9.19	3.68	0.40	1754	9.07	3.63	0.40	1768	8.98	3.59	0.40	1777	8.88	3.55	0.40	1834	8.76	3.50	0.40	1912	8.60	3.44	0.40	2037	8.40	3.36	0.40	2128	8.16	3.26	0.40	2206	7.49	3.00	0.40	2339	6.18	2.47	0.40	2426	5.10	2.04	0.40	2517
	26	18	9.10	7.28	0.80	1680	9.01	7.21	0.80	1695	8.91	7.13	0.80	1711	8.80	7.04	0.80	1724	8.71	6.97	0.80	1733	8.62	6.89	0.80	1791	8.50	6.80	0.80	1870	8.35	6.68	0.80	1996	8.15	6.52	0.80	2088	7.91	6.33	0.80	2167	7.26	5.81	0.80	2302	5.99	4.79	0.80	2390	4.94	3.96	0.80	2481
	26	20	9.38	6.38	0.68	1704	9.29	6.31	0.68	1720	9.19	6.25	0.68	1735	9.07	6.17	0.68	1749	8.98	6.10	0.68	1758	8.88	6.04	0.68	1815	8.76	5.95	0.68</																									

4. CAPACITIES AND SELECTION DATA

			Cooling Operation PERFORMANCE DATA																																																			
			OUTDOOR DB (°C)																																																			
COMBINATION (%)	IDDB (°C)	ID WB (°C)	-15				-7				0				10				15				21				25				27				30				35				40				45				50			
			Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT								
100%	21	18	7.74	4.65	0.60	1558	7.67	4.60	0.60	1572	7.58	4.55	0.60	1587	7.49	4.49	0.60	1600	7.41	4.45	0.60	1608	7.33	4.40	0.60	1661	7.23	4.34	0.60	1734	7.10	4.26	0.60	1852	6.94	4.16	0.60	1937	6.73	4.04	0.60	2010	6.18	3.71	0.60	2135	5.10	3.06	0.60	2217	4.21	2.52	0.60	2301
	21	20	8.06	3.87	0.48	1582	7.98	3.83	0.48	1596	7.90	3.79	0.48	1610	7.80	3.74	0.48	1623	7.72	3.70	0.48	1631	7.63	3.66	0.48	1685	7.53	3.61	0.48	1758	7.40	3.55	0.48	1875	7.22	3.47	0.48	1961	7.01	3.37	0.48	2034	6.44	3.09	0.48	2159	5.31	2.55	0.48	2240	4.38	2.10	0.48	2325
	22	18	7.98	5.11	0.64	1574	7.90	5.06	0.64	1588	7.82	5.00	0.64	1603	7.72	4.94	0.64	1616	7.64	4.89	0.64	1624	7.56	4.84	0.64	1678	7.45	4.77	0.64	1752	7.32	4.69	0.64	1870	7.15	4.58	0.64	1957	6.94	4.44	0.64	2030	6.37	4.08	0.64	2157	5.26	3.37	0.64	2239	4.34	2.78	0.64	2325
	22	20	8.23	4.28	0.52	1598	8.15	4.24	0.52	1612	8.06	4.19	0.52	1627	7.95	4.14	0.52	1640	7.88	4.10	0.52	1648	7.79	4.05	0.52	1702	7.68	4.00	0.52	1776	7.55	3.92	0.52	1894	7.37	3.83	0.52	1981	7.16	3.72	0.52	2054	6.57	3.42	0.52	2181	5.42	2.82	0.52	2263	4.47	2.32	0.52	2348
	22	22	8.37	3.35	0.40	1614	8.29	3.31	0.40	1628	8.20	3.28	0.40	1643	8.09	3.24	0.40	1656	8.01	3.20	0.40	1664	7.92	3.17	0.40	1718	7.81	3.13	0.40	1792	7.68	3.07	0.40	1910	7.50	3.00	0.40	1997	7.28	2.91	0.40	2070	6.68	2.67	0.40	2197	5.51	2.20	0.40	2279	4.55	1.82	0.40	2365
	23	18	8.15	5.54	0.68	1590	8.07	5.49	0.68	1604	7.98	5.43	0.68	1619	7.88	5.36	0.68	1632	7.80	5.30	0.68	1640	7.71	5.24	0.68	1695	7.61	5.17	0.68	1770	7.47	5.08	0.68	1889	7.30	4.96	0.68	1977	7.08	4.82	0.68	2051	6.50	4.42	0.68	2179	5.37	3.65	0.68	2262	4.43	3.01	0.68	2348
	23	20	8.40	4.70	0.56	1614	8.31	4.66	0.56	1628	8.22	4.60	0.56	1643	8.12	4.55	0.56	1656	8.04	4.50	0.56	1664	7.95	4.45	0.56	1719	7.84	4.39	0.56	1794	7.70	4.31	0.56	1913	7.52	4.21	0.56	2001	7.30	4.09	0.56	2075	6.70	3.75	0.56	2203	5.53	3.10	0.56	2286	4.56	2.55	0.56	2372
	23	22	8.54	3.76	0.44	1630	8.45	3.72	0.44	1645	8.36	3.68	0.44	1659	8.26	3.63	0.44	1672	8.17	3.60	0.44	1681	8.08	3.56	0.44	1735	7.97	3.51	0.44	1810	7.83	3.45	0.44	1930	7.65	3.37	0.44	2017	7.43	3.27	0.44	2091	6.82	3.00	0.44	2219	5.62	2.47	0.44	2302	4.64	2.04	0.44	2388
	24	18	8.31	5.99	0.72	1606	8.23	5.93	0.72	1621	8.14	5.86	0.72	1635	8.04	5.79	0.72	1649	7.96	5.73	0.72	1657	7.87	5.67	0.72	1712	7.76	5.59	0.72	1788	7.62	5.49	0.72	1908	7.45	5.36	0.72	1997	7.23	5.20	0.72	2072	6.64	4.78	0.72	2201	5.47	3.94	0.72	2285	4.52	3.25	0.72	2372
	24	20	8.57	5.14	0.60	1630	8.48	5.09	0.60	1645	8.39	5.03	0.60	1660	8.28	4.97	0.60	1673	8.20	4.92	0.60	1681	8.11	4.87	0.60	1736	8.00	4.80	0.60	1812	7.86	4.71	0.60	1933	7.67	4.60	0.60	2021	7.45	4.47	0.60	2096	6.84	4.10	0.60	2225	5.64	3.39	0.60	2309	4.66	2.79	0.60	2396
	24	22	8.71	4.18	0.48	1647	8.63	4.14	0.48	1661	8.53	4.10	0.48	1676	8.42	4.04	0.48	1689	8.34	4.00	0.48	1698	8.25	3.96	0.48	1753	8.14	3.91	0.48	1828	7.99	3.84	0.48	1949	7.80	3.75	0.48	2037	7.58	3.64	0.48	2112	6.96	3.34	0.48	2241	5.74	2.75	0.48	2325	4.73	2.27	0.48	2413
	24	24	8.84	3.18	0.36	1666	8.75	3.15	0.36	1681	8.65	3.11	0.36	1696	8.54	3.07	0.36	1709	8.46	3.04	0.36	1717	8.36	3.01	0.36	1772	8.25	2.97	0.36	1848	8.10	2.92	0.36	1969	7.91	2.85	0.36	2057	7.68	2.77	0.36	2132	7.05	2.54	0.36	2261	5.82	2.09	0.36	2345	4.80	1.73	0.36	2432
	25	18	8.57	6.51	0.76	1622	8.49	6.45	0.76	1637	8.39	6.38	0.76	1652	8.29	6.30	0.76	1665	8.20	6.23	0.76	1674	8.11	6.17	0.76	1729	8.00	6.08	0.76	1806	7.86	5.97	0.76	1928	7.68	5.83	0.76	2017	7.45	5.66	0.76	2093	6.84	5.20	0.76	2223	5.64	4.29	0.76	2308	4.66	3.54	0.76	2396
	25	20	8.83	5.65	0.64	1647	8.75	5.60	0.64	1661	8.65	5.54	0.64	1676	8.54	5.46	0.64	1690	8.45	5.41	0.64	1698	8.36	5.35	0.64	1754	8.25	5.28	0.64	1830	8.10	5.18	0.64	1952	7.91	5.06	0.64	2041	7.68	4.92	0.64	2117	7.05	4.51	0.64	2247	5.82	3.72	0.64	2332	4.80	3.07	0.64	2420
	25	22	8.98	4.67	0.52	1663	8.89	4.62	0.52	1678	8.80	4.57	0.52	1693	8.68	4.52	0.52	1706	8.60	4.47	0.52	1715	8.50	4.42	0.52	1771	8.39	4.36	0.52	1847	8.24	4.28	0.52	1969	8.05	4.18	0.52	2058	7.81	4.06	0.52	2134	7.17	3.73	0.52	2264	5.92	3.08	0.52	2349	4.88	2.54	0.52	2437
	25	24	9.11	3.64	0.40	1683	9.02	3.61	0.40	1698	8.92	3.57	0.40	1713	8.81	3.52	0.40	1726	8.72	3.49	0.40	1734	8.62	3.45	0.40	1790	8.50	3.40	0.40	1866	8.35	3.34	0.40	1988	8.16	3.26	0.40	2078	7.92	3.17	0.40	2153	7.27	2.91	0.40	2284	6.00	2.40	0.40	2368	4.95	1.98	0.40	2457
	26	18	8.84	7.07	0.80	1638	8.75	7.00	0.80	1653	8.65	6.92	0.80	1669	8.54	6.83	0.80	1682	8.46	6.77	0.80	1691	8.36	6.69	0.80	1747	8.25	6.60	0.80	1824	8.10	6.48	0.80	1947	7.91	6.33	0.80	2037	7.68	6.15	0.80	2114	7.05	5.64	0.80	2245	5.82	4.66	0.80	2331	4.80	3.84	0.80	2420
	26	20	9.11	6.19	0.68	1663	9.02	6.13	0.68	1678	8.92	6.06	0.68	1693	8.80	5.99	0.68	1707	8.72	5.93	0.68	1715	8.62	5.86	0.68	1772	8.50	5.78	0.68	1849	8.35	5.68	0.																					

4. CAPACITIES AND SELECTION DATA

Cooling Operation PERFORMANCE DATA																																																						
COMBINATION (%)	OUTDOOR DB (°C)																																																					
	IDDB (°C)	ID WB (°C)	-15				-7				0				10				15				21				25				27				30				35				40				45				50			
			Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT												
90%	21	18	7.59	4.55	0.60	1543	7.51	4.51	0.60	1557	7.43	4.46	0.60	1571	7.34	4.40	0.60	1584	7.26	4.36	0.60	1592	7.19	4.31	0.60	1645	7.09	4.25	0.60	1717	6.96	4.18	0.60	1833	6.80	4.08	0.60	1918	6.60	3.96	0.60	1990	6.06	3.64	0.60	2114	5.00	3.00	0.60	2195	4.12	2.47	0.60	2278
	21	20	7.90	3.79	0.48	1566	7.82	3.76	0.48	1580	7.74	3.71	0.48	1594	7.64	3.67	0.48	1607	7.56	3.63	0.48	1615	7.48	3.59	0.48	1668	7.38	3.54	0.48	1741	7.25	3.48	0.48	1857	7.08	3.40	0.48	1941	6.87	3.30	0.48	2013	6.31	3.03	0.48	2137	5.20	2.50	0.48	2218	4.29	2.06	0.48	2302
	22	18	7.82	5.01	0.64	1558	7.75	4.96	0.64	1572	7.66	4.90	0.64	1587	7.56	4.84	0.64	1600	7.49	4.79	0.64	1608	7.41	4.74	0.64	1661	7.31	4.68	0.64	1734	7.18	4.59	0.64	1852	7.01	4.49	0.64	1937	6.80	4.35	0.64	2010	6.25	4.00	0.64	2135	5.15	3.30	0.64	2217	4.25	2.72	0.64	2301
	22	20	8.06	4.19	0.52	1582	7.98	4.15	0.52	1596	7.90	4.11	0.52	1610	7.80	4.05	0.52	1623	7.72	4.01	0.52	1631	7.63	3.97	0.52	1685	7.53	3.92	0.52	1758	7.40	3.85	0.52	1875	7.22	3.76	0.52	1961	7.01	3.65	0.52	2034	6.44	3.35	0.52	2159	5.31	2.76	0.52	2240	4.38	2.28	0.52	2325
	22	22	8.20	3.28	0.40	1598	8.12	3.25	0.40	1612	8.03	3.21	0.40	1627	7.93	3.17	0.40	1640	7.85	3.14	0.40	1648	7.76	3.11	0.40	1701	7.66	3.06	0.40	1774	7.52	3.01	0.40	1892	7.35	2.94	0.40	1977	7.13	2.85	0.40	2050	6.55	2.62	0.40	2175	5.40	2.16	0.40	2257	4.46	1.78	0.40	2341
	23	18	7.98	5.43	0.68	1574	7.90	5.38	0.68	1588	7.82	5.32	0.68	1603	7.72	5.25	0.68	1616	7.64	5.20	0.68	1624	7.56	5.14	0.68	1678	7.45	5.07	0.68	1752	7.32	4.98	0.68	1870	7.15	4.86	0.68	1957	6.94	4.72	0.68	2030	6.37	4.33	0.68	2157	5.26	3.58	0.68	2239	4.34	2.95	0.68	2325
	23	20	8.23	4.61	0.56	1598	8.15	4.56	0.56	1612	8.06	4.51	0.56	1627	7.95	4.45	0.56	1640	7.88	4.41	0.56	1648	7.79	4.36	0.56	1702	7.68	4.30	0.56	1776	7.55	4.23	0.56	1894	7.37	4.13	0.56	1981	7.16	4.01	0.56	2054	6.57	3.68	0.56	2181	5.42	3.03	0.56	2263	4.47	2.50	0.56	2349
	23	22	8.37	3.68	0.44	1614	8.29	3.65	0.44	1629	8.20	3.61	0.44	1643	8.09	3.56	0.44	1656	8.01	3.52	0.44	1664	7.92	3.49	0.44	1718	7.81	3.44	0.44	1792	7.68	3.38	0.44	1911	7.50	3.30	0.44	1997	7.28	3.20	0.44	2071	6.68	2.94	0.44	2197	5.51	2.42	0.44	2279	4.55	2.00	0.44	2365
	24	18	8.15	5.87	0.72	1590	8.07	5.81	0.72	1604	7.98	5.74	0.72	1619	7.88	5.67	0.72	1632	7.80	5.61	0.72	1640	7.71	5.55	0.72	1695	7.61	5.48	0.72	1770	7.47	5.38	0.72	1889	7.30	5.25	0.72	1977	7.08	5.10	0.72	2051	6.50	4.68	0.72	2179	5.37	3.86	0.72	2262	4.43	3.19	0.72	2348
	24	20	8.40	5.04	0.60	1614	8.31	4.99	0.60	1629	8.22	4.93	0.60	1643	8.12	4.87	0.60	1656	8.04	4.82	0.60	1665	7.95	4.77	0.60	1719	7.84	4.70	0.60	1794	7.70	4.62	0.60	1913	7.52	4.51	0.60	2001	7.30	4.38	0.60	2075	6.70	4.02	0.60	2203	5.53	3.32	0.60	2286	4.56	2.74	0.60	2372
	24	22	8.54	4.10	0.48	1630	8.45	4.06	0.48	1645	8.36	4.01	0.48	1660	8.26	3.96	0.48	1673	8.17	3.92	0.48	1681	8.08	3.88	0.48	1736	7.97	3.83	0.48	1810	7.83	3.76	0.48	1930	7.65	3.67	0.48	2017	7.43	3.56	0.48	2092	6.82	3.27	0.48	2219	5.62	2.70	0.48	2302	4.64	2.23	0.48	2389
	24	24	8.66	3.12	0.36	1650	8.57	3.09	0.36	1664	8.48	3.05	0.36	1679	8.37	3.01	0.36	1692	8.29	2.98	0.36	1700	8.20	2.95	0.36	1755	8.08	2.91	0.36	1830	7.94	2.86	0.36	1949	7.76	2.79	0.36	2037	7.53	2.71	0.36	2111	6.91	2.49	0.36	2239	5.70	2.05	0.36	2322	4.70	1.69	0.36	2408
	25	18	8.40	6.38	0.76	1606	8.32	6.32	0.76	1620	8.23	6.25	0.76	1635	8.12	6.17	0.76	1649	8.04	6.11	0.76	1657	7.95	6.04	0.76	1712	7.84	5.96	0.76	1787	7.70	5.85	0.76	1908	7.52	5.72	0.76	1997	7.30	5.55	0.76	2071	6.70	5.10	0.76	2201	5.53	4.20	0.76	2285	4.56	3.47	0.76	2372
	25	20	8.66	5.54	0.64	1630	8.57	5.48	0.64	1645	8.48	5.43	0.64	1660	8.37	5.36	0.64	1673	8.29	5.30	0.64	1681	8.20	5.24	0.64	1736	8.08	5.17	0.64	1812	7.94	5.08	0.64	1933	7.75	4.96	0.64	2021	7.53	4.82	0.64	2096	6.91	4.42	0.64	2225	5.70	3.65	0.64	2309	4.70	3.01	0.64	2396
	25	22	8.80	4.58	0.52	1647	8.72	4.53	0.52	1662	8.62	4.48	0.52	1676	8.51	4.43	0.52	1690	8.43	4.38	0.52	1698	8.33	4.33	0.52	1753	8.22	4.27	0.52	1829	8.07	4.20	0.52	1949	7.88	4.10	0.52	2038	7.66	3.98	0.52	2113	7.03	3.65	0.52	2242	5.80	3.01	0.52	2326	4.78	2.49	0.52	2413
	25	24	8.93	3.57	0.40	1667	8.84	3.54	0.40	1681	8.74	3.50	0.40	1696	8.63	3.45	0.40	1709	8.54	3.42	0.40	1718	8.45	3.38	0.40	1773	8.33	3.33	0.40	1848	8.19	3.27	0.40	1969	8.00	3.20	0.40	2057	7.76	3.10	0.40	2132	7.13	2.85	0.40	2261	5.88	2.35	0.40	2345	4.85	1.94	0.40	2432
	26	18	8.66	6.93	0.80	1622	8.57	6.86	0.80	1637	8.48	6.78	0.80	1652	8.37	6.70	0.80	1665	8.29	6.63	0.80	1674	8.20	6.56	0.80	1729	8.08	6.47	0.80	1805	7.94	6.35	0.80	1928	7.76	6.20	0.80	2017	7.53	6.02	0.80	2092	6.91	5.53	0.80	2223	5.70	4.56	0.80	2308	4.70	3.76	0.80	2396
	26	20	8.92	6.07	0.68	1647	8.84	6.01	0.68	1662	8.74	5.94	0.68	1677	8.63	5.87	0.68	1690	8.54	5.81	0.68	1698	8.45	5.75	0.68	1754	8.33	5.67	0.68	1830	8.18	5.57	0.68</																					

4. CAPACITIES AND SELECTION DATA

	Cooling Operation PERFORMANCE DATA																																																					
	OUTDOOR DB (°C)																																																					
COMBINATION (%)	IDDB (°C)	ID WB (°C)	-15				-7				0				10				15				21				25				27				30				35				40				45				50			
			Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT								
80%	21	18	7.36	4.41	0.60	1527	7.28	4.37	0.60	1541	7.21	4.32	0.60	1555	7.11	4.27	0.60	1567	7.04	4.23	0.60	1575	6.97	4.18	0.60	1628	6.87	4.12	0.60	1700	6.75	4.05	0.60	1814	6.59	3.95	0.60	1898	6.40	3.84	0.60	1970	5.87	3.52	0.60	2092	4.85	2.91	0.60	2172	4.00	2.40	0.60	2255
	21	20	7.66	3.68	0.48	1550	7.58	3.64	0.48	1564	7.50	3.60	0.48	1578	7.41	3.55	0.48	1591	7.33	3.52	0.48	1599	7.25	3.48	0.48	1651	7.15	3.43	0.48	1723	7.03	3.37	0.48	1838	6.86	3.29	0.48	1922	6.66	3.20	0.48	1993	6.12	2.94	0.48	2116	5.05	2.42	0.48	2196	4.16	2.00	0.48	2279
	22	18	7.58	4.85	0.64	1542	7.51	4.81	0.64	1556	7.43	4.75	0.64	1571	7.33	4.69	0.64	1583	7.26	4.65	0.64	1591	7.18	4.60	0.64	1644	7.08	4.53	0.64	1717	6.96	4.45	0.64	1833	6.79	4.35	0.64	1918	6.60	4.22	0.64	1990	6.05	3.88	0.64	2114	5.00	3.20	0.64	2194	4.12	2.64	0.64	2278
	22	20	7.82	4.06	0.52	1566	7.74	4.02	0.52	1580	7.66	3.98	0.52	1594	7.56	3.93	0.52	1607	7.48	3.89	0.52	1615	7.40	3.85	0.52	1668	7.30	3.80	0.52	1741	7.17	3.73	0.52	1857	7.00	3.64	0.52	1941	6.80	3.53	0.52	2013	6.24	3.24	0.52	2137	5.15	2.68	0.52	2218	4.25	2.21	0.52	2302
	22	22	7.95	3.18	0.40	1582	7.87	3.15	0.40	1596	7.79	3.11	0.40	1611	7.69	3.07	0.40	1623	7.61	3.04	0.40	1631	7.53	3.01	0.40	1684	7.42	2.97	0.40	1757	7.29	2.92	0.40	1873	7.12	2.85	0.40	1958	6.91	2.77	0.40	2030	6.35	2.54	0.40	2153	5.24	2.09	0.40	2234	4.32	1.73	0.40	2318
	23	18	7.74	5.26	0.68	1558	7.66	5.21	0.68	1572	7.58	5.15	0.68	1586	7.48	5.09	0.68	1599	7.41	5.04	0.68	1607	7.33	4.98	0.68	1661	7.23	4.91	0.68	1734	7.10	4.83	0.68	1851	6.93	4.71	0.68	1937	6.73	4.58	0.68	2010	6.18	4.20	0.68	2135	5.10	3.47	0.68	2216	4.21	2.86	0.68	2301
	23	20	7.98	4.47	0.56	1582	7.90	4.42	0.56	1596	7.81	4.37	0.56	1610	7.71	4.32	0.56	1623	7.63	4.28	0.56	1631	7.55	4.23	0.56	1685	7.45	4.17	0.56	1758	7.32	4.10	0.56	1875	7.14	4.00	0.56	1961	6.94	3.88	0.56	2034	6.37	3.57	0.56	2159	5.25	2.94	0.56	2240	4.33	2.43	0.56	2325
	23	22	8.11	3.57	0.44	1598	8.03	3.53	0.44	1612	7.94	3.50	0.44	1627	7.84	3.45	0.44	1640	7.76	3.42	0.44	1648	7.68	3.38	0.44	1701	7.57	3.33	0.44	1774	7.44	3.27	0.44	1892	7.27	3.20	0.44	1977	7.05	3.10	0.44	2050	6.48	2.85	0.44	2175	5.34	2.35	0.44	2257	4.41	1.94	0.44	2341
	24	18	7.90	5.69	0.72	1574	7.82	5.63	0.72	1588	7.73	5.57	0.72	1602	7.63	5.50	0.72	1615	7.56	5.44	0.72	1624	7.48	5.38	0.72	1678	7.37	5.31	0.72	1752	7.24	5.22	0.72	1870	7.07	5.09	0.72	1957	6.87	4.94	0.72	2030	6.30	4.54	0.72	2156	5.20	3.74	0.72	2239	4.29	3.09	0.72	2324
	24	20	8.14	4.88	0.60	1598	8.06	4.84	0.60	1612	7.97	4.78	0.60	1627	7.87	4.72	0.60	1640	7.79	4.67	0.60	1648	7.71	4.62	0.60	1702	7.60	4.56	0.60	1776	7.47	4.48	0.60	1894	7.29	4.37	0.60	1981	7.08	4.25	0.60	2054	6.50	3.90	0.60	2181	5.36	3.22	0.60	2263	4.42	2.65	0.60	2348
	24	22	8.28	3.97	0.48	1614	8.20	3.93	0.48	1629	8.11	3.89	0.48	1643	8.00	3.84	0.48	1656	7.92	3.80	0.48	1664	7.84	3.76	0.48	1718	7.73	3.71	0.48	1792	7.59	3.64	0.48	1911	7.41	3.56	0.48	1997	7.20	3.46	0.48	2071	6.61	3.17	0.48	2197	5.45	2.62	0.48	2279	4.50	2.16	0.48	2365
	24	24	8.39	3.02	0.36	1634	8.31	2.99	0.36	1648	8.22	2.96	0.36	1663	8.11	2.92	0.36	1676	8.03	2.89	0.36	1684	7.95	2.86	0.36	1738	7.84	2.82	0.36	1812	7.70	2.77	0.36	1930	7.52	2.71	0.36	2017	7.30	2.63	0.36	2090	6.70	2.41	0.36	2217	5.53	1.99	0.36	2299	4.56	1.64	0.36	2384
	25	18	8.14	6.19	0.76	1589	8.06	6.13	0.76	1604	7.97	6.06	0.76	1619	7.87	5.98	0.76	1632	7.79	5.92	0.76	1640	7.71	5.86	0.76	1695	7.60	5.78	0.76	1769	7.47	5.68	0.76	1889	7.29	5.54	0.76	1976	7.08	5.38	0.76	2050	6.50	4.94	0.76	2178	5.36	4.08	0.76	2261	4.42	3.36	0.76	2348
	25	20	8.39	5.37	0.64	1614	8.31	5.32	0.64	1628	8.22	5.26	0.64	1643	8.11	5.19	0.64	1656	8.03	5.14	0.64	1665	7.94	5.08	0.64	1719	7.83	5.01	0.64	1794	7.70	4.93	0.64	1913	7.52	4.81	0.64	2001	7.30	4.67	0.64	2075	6.70	4.29	0.64	2203	5.53	3.54	0.64	2286	4.56	2.92	0.64	2372
	25	22	8.53	4.44	0.52	1631	8.45	4.39	0.52	1645	8.36	4.35	0.52	1660	8.25	4.29	0.52	1673	8.17	4.25	0.52	1681	8.08	4.20	0.52	1736	7.97	4.14	0.52	1810	7.83	4.07	0.52	1930	7.64	3.97	0.52	2017	7.42	3.86	0.52	2092	6.81	3.54	0.52	2219	5.62	2.92	0.52	2303	4.64	2.41	0.52	2389
	25	24	8.65	3.46	0.40	1650	8.57	3.43	0.40	1665	8.47	3.39	0.40	1679	8.37	3.35	0.40	1693	8.28	3.31	0.40	1701	8.19	3.28	0.40	1755	8.08	3.23	0.40	1830	7.94	3.17	0.40	1950	7.75	3.10	0.40	2037	7.52	3.01	0.40	2111	6.91	2.76	0.40	2239	5.70	2.28	0.40	2322	4.70	1.88	0.40	2408
	26	18	8.39	6.71	0.80	1606	8.31	6.65	0.80	1620	8.22	6.58	0.80	1635	8.11	6.49	0.80	1648	8.03	6.43	0.80	1657	7.95	6.36	0.80	1712	7.84	6.27	0.80	1787	7.70	6.16	0.80	1908	7.52	6.01	0.80	1996	7.30	5.84	0.80	2071	6.70	5.36	0.80	2200	5.53	4.42	0.80	2284	4.56	3.65	0.80	2371
	26	20	8.65	5.88	0.68	1630	8.56	5.82	0.68	1645	8.47	5.76	0.68	1660	8.36	5.69	0.68	1673	8.28	5.63	0.68	1681	8.19	5.57	0.68	1736	8.08	5.49	0.68	1812																								

4. CAPACITIES AND SELECTION DATA

27K

HEATING PERFORMANCE DATA

COMBINATION (%)	INDOOR DB(°C)	OUTDOOR WB(°C)															
		-15		-10		-5		0		5		10		15		20	
		Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT
130%	15	6.51	2054	7.65	2118	8.50	2139	9.35	2183	10.16	2298	10.97	2412	11.52	2485	11.86	2535
	16	6.43	2071	7.56	2135	8.40	2156	9.23	2200	10.04	2316	10.84	2432	11.38	2505	11.72	2555
	17	6.35	2087	7.47	2152	8.30	2174	9.12	2218	9.92	2335	10.71	2452	11.25	2525	11.58	2576
	18	6.28	2104	7.38	2169	8.21	2191	9.02	2236	9.80	2354	10.58	2471	11.11	2545	11.45	2596
	19	6.20	2121	7.30	2187	8.11	2209	8.91	2254	9.68	2373	10.46	2491	10.98	2566	11.31	2617
	20	6.14	2138	7.22	2204	8.03	2227	8.82	2272	9.59	2392	10.36	2511	10.87	2587	11.20	2638
	21	6.07	2162	7.14	2229	7.93	2251	8.72	2297	9.47	2418	10.23	2539	10.74	2615	11.07	2667
	22	5.99	2186	7.05	2253	7.84	2276	8.61	2322	9.36	2445	10.11	2567	10.61	2644	10.93	2697
	23	5.92	2210	6.97	2278	7.74	2301	8.51	2348	9.25	2472	9.99	2595	10.49	2673	10.80	2726
	24	5.85	2234	6.88	2303	7.65	2326	8.41	2374	9.14	2499	9.87	2624	10.36	2702	10.67	2756
	25	5.78	2259	6.80	2328	7.56	2352	8.30	2400	9.03	2526	9.75	2653	10.24	2732	10.54	2787
	26	5.71	2283	6.72	2354	7.47	2378	8.21	2426	8.92	2554	9.63	2682	10.11	2762	10.42	2817
	27	5.64	2308	6.64	2380	7.38	2404	8.11	2453	8.81	2582	9.52	2711	9.99	2793	10.29	2848
	28	5.58	2334	6.56	2406	7.29	2430	8.01	2480	8.71	2610	9.40	2741	9.87	2823	10.17	2880
	29	5.51	2360	6.48	2433	7.20	2457	7.91	2507	8.60	2639	9.29	2771	9.75	2854	10.05	2911
	30	5.44	2386	6.40	2459	7.11	2484	7.82	2535	8.50	2668	9.18	2802	9.64	2886	9.93	2943
COMBINATION (%)	INDOOR DB(°C)	OUTDOOR WB(°C)															
		-15		-10		-5		0		5		10		15		20	
		Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT
120%	15	6.32	1956	7.43	2017	8.26	2037	9.07	2079	9.86	2188	10.65	2298	11.18	2367	11.52	2414
	16	6.24	1972	7.34	2033	8.16	2054	8.97	2096	9.75	2206	10.52	2316	11.05	2386	11.38	2433
	17	6.17	1988	7.26	2049	8.06	2070	8.86	2112	9.63	2224	10.40	2335	10.92	2405	11.25	2453
	18	6.09	2004	7.17	2066	7.97	2087	8.75	2129	9.52	2242	10.28	2354	10.79	2424	11.11	2473
	19	6.02	2020	7.08	2083	7.87	2104	8.65	2147	9.40	2260	10.15	2373	10.66	2444	10.98	2493
	20	5.96	2036	7.01	2099	7.79	2121	8.56	2164	9.31	2278	10.05	2392	10.56	2463	10.87	2513
	21	5.89	2059	6.93	2123	7.70	2144	8.46	2188	9.20	2303	9.93	2418	10.43	2491	10.74	2540
	22	5.82	2082	6.85	2146	7.61	2168	8.36	2212	9.09	2328	9.81	2445	10.31	2518	10.61	2568
	23	5.75	2104	6.76	2170	7.52	2191	8.26	2236	8.98	2354	9.70	2472	10.18	2546	10.49	2597
	24	5.68	2128	6.68	2193	7.43	2216	8.16	2261	8.87	2380	9.58	2499	10.06	2574	10.36	2625
	25	5.61	2151	6.60	2218	7.34	2240	8.06	2286	8.76	2406	9.47	2526	9.94	2602	10.24	2654
	26	5.55	2175	6.52	2242	7.25	2265	7.97	2311	8.66	2432	9.35	2554	9.82	2631	10.11	2683
	27	5.48	2199	6.45	2267	7.16	2289	7.87	2336	8.56	2459	9.24	2582	9.70	2660	9.99	2713
	28	5.41	2223	6.37	2291	7.08	2315	7.78	2362	8.45	2486	9.13	2610	9.58	2689	9.87	2743
	29	5.35	2247	6.29	2317	6.99	2340	7.68	2388	8.35	2514	9.02	2639	9.47	2718	9.75	2773
	30	5.28	2272	6.22	2342	6.91	2366	7.59	2414	8.25	2541	8.91	2668	9.36	2748	9.64	2803
COMBINATION (%)	INDOOR DB(°C)	OUTDOOR WB(°C)															
		-15		-10		-5		0		5		10		15		20	
		Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT
110%	15	6.13	1918	7.21	1977	8.02	1997	8.81	2038	9.57	2145	10.34	2253	10.86	2320	11.18	2367
	16	6.06	1933	7.13	1993	7.92	2013	8.70	2054	9.46	2163	10.22	2271	10.73	2339	11.05	2386
	17	5.99	1949	7.04	2009	7.83	2030	8.60	2071	9.35	2180	10.10	2289	10.60	2358	10.92	2405
	18	5.92	1965	6.96	2025	7.73	2046	8.50	2088	9.24	2198	9.98	2307	10.48	2377	10.79	2424
	19	5.85	1981	6.88	2042	7.64	2062	8.40	2105	9.13	2215	9.86	2326	10.35	2396	10.66	2444
	20	5.79	1997	6.81	2058	7.57	2079	8.32	2122	9.04	2233	9.76	2345	10.25	2415	10.56	2463
	21	5.72	2019	6.73	2081	7.48	2102	8.22	2145	8.93	2258	9.64	2371	10.13	2442	10.43	2491
	22	5.65	2041	6.65	2104	7.39	2125	8.12	2168	8.82	2283	9.53	2397	10.00	2469	10.31	2518
	23	5.58	2063	6.57	2127	7.30	2148	8.02	2192	8.72	2308	9.41	2423	9.88	2496	10.18	2546
	24	5.52	2086	6.49	2150	7.21	2172	7.92	2216	8.61	2333	9.30	2450	9.77	2523	10.06	2574
	25	5.45	2109	6.41	2174	7.12	2196	7.83	2241	8.51	2359	9.19	2477	9.65	2551	9.94	2602
	26	5.38	2132	6.33	2198	7.04	2220	7.73	2265	8.41	2385	9.08	2504	9.53	2579	9.82	2631
	27	5.32	2155	6.26	2222	6.95	2245	7.64	2290	8.31	2411	8.97	2531	9.42	2607	9.70	2660
	28	5.26	2179	6.18	2247	6.87	2269	7.55	2316	8.21	2437	8.86	2559	9.31	2636	9.58	2689
	29	5.19	2203	6.11	2271	6.79	2294	7.46	2341	8.11	2464	8.76	2587	9.19	2665	9.47	2718
	30	5.13	2227	6.04	2296	6.71	2319	7.37	2367	8.01	2491	8.65	2616	9.08	2694	9.36	2748

4. CAPACITIES AND SELECTION DATA

COMBINATION (%)	INDOOR DB(°C)	OUTDOOR WB(°C)															
		-15		-10		-5		0		5		10		15		20	
		Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT
100%	15	5.95	1862	7.00	1920	7.78	1939	8.55	1979	9.30	2083	10.04	2187	10.54	2253	10.86	2298
	16	5.88	1877	6.92	1935	7.69	1955	8.45	1995	9.19	2100	9.92	2205	10.42	2271	10.73	2316
	17	5.81	1892	6.84	1951	7.60	1970	8.35	2011	9.08	2117	9.80	2222	10.29	2289	10.60	2335
	18	5.74	1908	6.76	1967	7.51	1986	8.25	2027	8.97	2134	9.69	2240	10.17	2307	10.48	2354
	19	5.68	1923	6.68	1982	7.42	2002	8.15	2043	8.86	2151	9.57	2258	10.05	2326	10.35	2373
	20	5.62	1938	6.61	1998	7.35	2019	8.07	2060	8.78	2168	9.48	2277	9.95	2345	10.25	2392
	21	5.55	1960	6.53	2020	7.26	2041	7.98	2082	8.67	2192	9.36	2302	9.83	2371	10.13	2418
	22	5.49	1981	6.45	2043	7.17	2063	7.88	2105	8.57	2216	9.25	2327	9.71	2397	10.00	2445
	23	5.42	2003	6.38	2065	7.09	2086	7.79	2128	8.46	2240	9.14	2352	9.60	2423	9.88	2472
	24	5.36	2025	6.30	2088	7.00	2109	7.69	2152	8.36	2265	9.03	2378	9.48	2450	9.77	2499
	25	5.29	2047	6.22	2111	6.92	2132	7.60	2176	8.26	2290	8.92	2405	9.37	2477	9.65	2526
	26	5.23	2070	6.15	2134	6.83	2155	7.51	2199	8.16	2315	8.81	2431	9.26	2504	9.53	2554
	27	5.16	2093	6.08	2157	6.75	2179	7.42	2224	8.06	2341	8.71	2458	9.14	2531	9.42	2582
	28	5.10	2116	6.00	2181	6.67	2203	7.33	2248	7.97	2366	8.60	2485	9.03	2559	9.31	2610
	29	5.04	2139	5.93	2205	6.59	2227	7.24	2273	7.87	2392	8.50	2512	8.93	2587	9.19	2639
	30	4.98	2162	5.86	2229	6.51	2252	7.15	2298	7.78	2419	8.40	2540	8.82	2616	9.08	2668
90%	15	5.75	1829	6.76	1885	7.51	1904	8.25	1943	8.97	2045	9.69	2148	10.17	2212	10.48	2256
	16	5.68	1843	6.68	1900	7.42	1920	8.16	1959	8.86	2062	9.57	2165	10.05	2230	10.35	2274
	17	5.61	1858	6.60	1916	7.33	1935	8.06	1974	8.76	2078	9.46	2182	9.93	2248	10.23	2293
	18	5.54	1873	6.52	1931	7.25	1951	7.96	1990	8.66	2095	9.35	2200	9.81	2266	10.11	2311
	19	5.48	1888	6.44	1947	7.16	1966	7.87	2006	8.55	2112	9.24	2218	9.70	2284	9.99	2330
	20	5.42	1904	6.38	1962	7.09	1982	7.79	2023	8.47	2129	9.15	2236	9.60	2303	9.89	2349
	21	5.36	1924	6.30	1984	7.00	2004	7.70	2045	8.37	2153	9.04	2260	9.49	2328	9.77	2375
	22	5.29	1946	6.23	2006	6.92	2026	7.60	2067	8.27	2176	8.93	2285	9.37	2354	9.65	2401
	23	5.23	1967	6.15	2028	6.84	2048	7.51	2090	8.17	2200	8.82	2310	9.26	2379	9.54	2427
	24	5.17	1989	6.08	2050	6.76	2071	7.42	2113	8.07	2224	8.71	2336	9.15	2406	9.42	2454
	25	5.11	2011	6.01	2073	6.67	2094	7.33	2136	7.97	2249	8.61	2361	9.04	2432	9.31	2481
	26	5.04	2033	5.93	2096	6.59	2117	7.25	2160	7.88	2274	8.51	2387	8.93	2459	9.20	2508
	27	4.98	2055	5.86	2119	6.51	2140	7.16	2184	7.78	2299	8.40	2413	8.82	2486	9.09	2536
	28	4.92	2078	5.79	2142	6.44	2163	7.07	2208	7.69	2324	8.30	2440	8.72	2513	8.98	2564
	29	4.86	2100	5.72	2165	6.36	2187	6.99	2232	7.60	2349	8.20	2467	8.61	2541	8.87	2592
	30	4.81	2124	5.65	2189	6.28	2211	6.90	2256	7.50	2375	8.11	2494	8.51	2569	8.77	2620
80%	15	5.57	1810	6.56	1866	7.28	1885	8.01	1924	8.70	2025	9.40	2126	9.87	2190	10.16	2234
	16	5.51	1825	6.48	1881	7.20	1900	7.91	1939	8.60	2041	9.29	2143	9.75	2208	10.04	2252
	17	5.44	1840	6.40	1896	7.11	1916	7.82	1955	8.50	2058	9.18	2161	9.63	2225	9.92	2270
	18	5.38	1854	6.33	1912	7.03	1931	7.72	1971	8.40	2074	9.07	2178	9.52	2243	9.81	2288
	19	5.31	1869	6.25	1927	6.95	1947	7.63	1986	8.30	2091	8.96	2196	9.41	2261	9.69	2307
	20	5.26	1884	6.19	1943	6.88	1962	7.56	2002	8.21	2108	8.87	2213	9.31	2280	9.59	2325
	21	5.20	1905	6.11	1964	6.79	1984	7.47	2024	8.12	2131	8.76	2238	9.20	2305	9.48	2351
	22	5.14	1926	6.04	1986	6.71	2006	7.38	2047	8.02	2154	8.66	2262	9.09	2330	9.37	2377
	23	5.07	1947	5.97	2008	6.63	2028	7.29	2069	7.92	2178	8.56	2287	8.98	2356	9.25	2403
	24	5.01	1969	5.90	2030	6.55	2050	7.20	2092	7.83	2202	8.45	2312	8.88	2382	9.14	2429
	25	4.95	1990	5.83	2052	6.47	2073	7.11	2115	7.73	2226	8.35	2338	8.77	2408	9.03	2456
	26	4.89	2012	5.76	2075	6.40	2096	7.03	2138	7.64	2251	8.25	2363	8.66	2434	8.92	2483
	27	4.83	2034	5.69	2097	6.32	2119	6.94	2162	7.55	2276	8.15	2389	8.56	2461	8.82	2510
	28	4.78	2057	5.62	2120	6.24	2142	6.86	2186	7.46	2301	8.05	2416	8.46	2488	8.71	2538
	29	4.72	2079	5.55	2144	6.17	2165	6.78	2210	7.37	2326	7.96	2442	8.36	2515	8.61	2566
	30	4.66	2102	5.49	2167	6.09	2189	6.70	2234	7.28	2351	7.86	2469	8.26	2543	8.50	2594

Remarks:
 Q: Total Cooling Capacity (Gross) **kW**
 INPUT: Power Input (including the compressor, evap. fan motor & cond. **W**
 DB: Dry Bulb Temperature
 WB: Wet Bulb Temperature

5AMW105U4RQC

-

UE MULTI 5 POSTES 10,5 KW

4. CAPACITIES AND SELECTION DATA

36K

	Cooling Operation PERFORMANCE DATA																																																					
	OUTDOOR DB (°C)																																																					
COMBINATION (%)	IDDB (°C)	ID WB (°C)	-15				-7				0				10				15				21				25				27				30				35				40				45				50			
			Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT												
130%	21	18	10.26	6.16	0.60	1976	10.16	6.10	0.60	1994	10.05	6.03	0.60	2012	9.92	5.95	0.60	2029	9.82	5.89	0.60	2039	9.72	5.83	0.60	2107	9.58	5.75	0.60	2199	9.41	5.65	0.60	2348	9.19	5.51	0.60	2456	8.92	5.35	0.60	2549	8.19	4.91	0.60	2707	6.76	4.05	0.60	2810	5.58	3.35	0.60	2918
	21	20	10.68	5.13	0.48	2000	10.58	5.08	0.48	2018	10.46	5.02	0.48	2036	10.33	4.96	0.48	2052	10.23	4.91	0.48	2063	10.12	4.86	0.48	2130	9.98	4.79	0.48	2223	9.80	4.70	0.48	2372	9.57	4.59	0.48	2480	9.29	4.46	0.48	2572	8.53	4.09	0.48	2731	7.04	3.38	0.48	2834	5.81	2.79	0.48	2941
	22	18	10.58	6.77	0.64	1996	10.47	6.70	0.64	2014	10.36	6.63	0.64	2033	10.23	6.55	0.64	2049	10.13	6.48	0.64	2060	10.02	6.41	0.64	2128	9.88	6.32	0.64	2222	9.70	6.21	0.64	2372	9.48	6.06	0.64	2481	9.20	5.89	0.64	2574	8.44	5.40	0.64	2735	6.97	4.46	0.64	2839	5.75	3.68	0.64	2947
	22	20	10.90	5.67	0.52	2020	10.79	5.61	0.52	2038	10.68	5.55	0.52	2057	10.54	5.48	0.52	2073	10.44	5.43	0.52	2083	10.32	5.37	0.52	2152	10.18	5.29	0.52	2245	10.00	5.20	0.52	2395	9.77	5.08	0.52	2505	9.48	4.93	0.52	2598	8.70	4.53	0.52	2758	7.18	3.73	0.52	2863	5.92	3.08	0.52	2971
	22	22	11.09	4.44	0.40	2036	10.98	4.39	0.40	2054	10.86	4.34	0.40	2073	10.72	4.29	0.40	2089	10.61	4.25	0.40	2100	10.50	4.20	0.40	2168	10.35	4.14	0.40	2262	10.17	4.07	0.40	2412	9.93	3.97	0.40	2521	9.64	3.86	0.40	2614	8.85	3.54	0.40	2774	7.30	2.92	0.40	2879	6.02	2.41	0.40	2987
	23	18	10.79	7.34	0.68	2016	10.69	7.27	0.68	2035	10.57	7.19	0.68	2053	10.44	7.10	0.68	2070	10.33	7.03	0.68	2080	10.22	6.95	0.68	2149	10.08	6.85	0.68	2244	9.90	6.73	0.68	2396	9.67	6.57	0.68	2506	9.39	6.38	0.68	2600	8.62	5.86	0.68	2762	7.11	4.83	0.68	2867	5.87	3.99	0.68	2977
	23	20	11.13	6.23	0.56	2040	11.01	6.17	0.56	2059	10.90	6.10	0.56	2077	10.76	6.02	0.56	2094	10.65	5.96	0.56	2104	10.53	5.90	0.56	2173	10.39	5.82	0.56	2268	10.20	5.71	0.56	2420	9.96	5.58	0.56	2530	9.67	5.42	0.56	2624	8.88	4.97	0.56	2786	7.33	4.10	0.56	2891	6.04	3.39	0.56	3001
	23	22	11.31	4.98	0.44	2057	11.20	4.93	0.44	2075	11.08	4.88	0.44	2094	10.94	4.81	0.44	2110	10.83	4.77	0.44	2121	10.71	4.71	0.44	2190	10.56	4.65	0.44	2284	10.38	4.57	0.44	2436	10.13	4.46	0.44	2547	9.84	4.33	0.44	2641	9.03	3.97	0.44	2802	7.45	3.28	0.44	2908	6.15	2.70	0.44	3017
	24	18	11.01	7.93	0.72	2037	10.91	7.85	0.72	2055	10.79	7.77	0.72	2074	10.65	7.67	0.72	2091	10.54	7.59	0.72	2101	10.43	7.51	0.72	2171	10.28	7.40	0.72	2267	10.10	7.27	0.72	2420	9.87	7.10	0.72	2532	9.58	6.90	0.72	2627	8.79	6.33	0.72	2790	7.25	5.22	0.72	2896	5.98	4.31	0.72	3007
	24	20	11.35	6.81	0.60	2061	11.24	6.74	0.60	2080	11.12	6.67	0.60	2098	10.97	6.58	0.60	2115	10.87	6.52	0.60	2126	10.75	6.45	0.60	2195	10.60	6.36	0.60	2291	10.41	6.25	0.60	2444	10.17	6.10	0.60	2556	9.87	5.92	0.60	2651	9.06	5.44	0.60	2814	7.48	4.49	0.60	2921	6.17	3.70	0.60	3031
	24	22	11.55	5.54	0.48	2077	11.43	5.49	0.48	2096	11.31	5.43	0.48	2115	11.16	5.36	0.48	2132	11.05	5.30	0.48	2142	10.93	5.25	0.48	2212	10.78	5.17	0.48	2308	10.59	5.08	0.48	2461	10.34	4.96	0.48	2572	10.04	4.82	0.48	2667	9.22	4.42	0.48	2831	7.60	3.65	0.48	2937	6.27	3.01	0.48	3048
	24	24	11.71	4.21	0.36	2097	11.59	4.17	0.36	2115	11.46	4.13	0.36	2134	11.32	4.07	0.36	2151	11.21	4.03	0.36	2162	11.08	3.99	0.36	2231	10.93	3.93	0.36	2327	10.74	3.87	0.36	2480	10.49	3.77	0.36	2592	10.18	3.66	0.36	2687	9.35	3.36	0.36	2850	7.71	2.78	0.36	2957	6.36	2.29	0.36	3067
	25	18	11.36	8.63	0.76	2057	11.24	8.54	0.76	2076	11.12	8.45	0.76	2095	10.98	8.34	0.76	2112	10.87	8.26	0.76	2123	10.75	8.17	0.76	2193	10.60	8.06	0.76	2290	10.42	7.92	0.76	2444	10.17	7.73	0.76	2557	9.87	7.50	0.76	2653	9.07	6.89	0.76	2818	7.48	5.68	0.76	2926	6.17	4.69	0.76	3037
	25	20	11.70	7.49	0.64	2082	11.59	7.42	0.64	2101	11.46	7.34	0.64	2119	11.31	7.24	0.64	2136	11.20	7.17	0.64	2147	11.08	7.09	0.64	2218	10.93	6.99	0.64	2314	10.73	6.87	0.64	2469	10.48	6.71	0.64	2582	10.18	6.51	0.64	2678	9.34	5.98	0.64	2843	7.71	4.93	0.64	2950	6.36	4.07	0.64	3062
	25	22	11.90	6.19	0.52	2098	11.78	6.13	0.52	2117	11.66	6.06	0.52	2136	11.51	5.98	0.52	2153	11.39	5.92	0.52	2164	11.27	5.86	0.52	2234	11.11	5.78	0.52	2331	10.92	5.68	0.52	2485	10.66	5.54	0.52	2598	10.35	5.38	0.52	2694	9.50	4.94	0.52	2859	7.84	4.08	0.52	2967	6.47	3.36	0.52	3078
	25	24	12.07	4.83	0.40	2118	11.95	4.78	0.40	2137	11.82	4.73	0.40	2156	11.67	4.67	0.40	2173	11.55	4.62	0.40	2183	11.43	4.57	0.40	2254	11.27	4.51	0.40	2350	11.07	4.43	0.40	2505	10.81	4.32	0.40	2618	10.50	4.20	0.40	2714	9.63	3.85	0.40	2879	7.95	3.18	0.40	2986	6.56	2.62	0.40	3098
	26	18	11.71	9.37	0.80	2078	11.59	9.27	0.80	2097	11.46	9.17	0.80	2116	11.32	9.05	0.80	2133	11.21	8.96	0.80	2144	11.08	8.87	0.80	2215	10.93	8.74	0.80	2313	10.74	8.59	0.80	2469	10.49	8.39	0.80	2583	10.18	8.14	0.80	2680	9.35	7.48	0.80	2847	7.71	6.17	0.80	2955	6.36	5.09	0.80	3068
	26	20	12.07	8.20	0.68	2103	11.95	8.12	0.68	2122	11.82																																											

4. CAPACITIES AND SELECTION DATA

				Cooling Operation PERFORMANCE DATA																																																		
				OUTDOOR DB (°C)																																																		
COMBINATION (%)	IDDB (°C)	ID WB (°C)	-15				-7				0				10				15				21				25				27				30				35				40				45				50			
			Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT								
120%	21	18	10.16	6.10	0.60	1957	10.06	6.04	0.60	1975	9.95	5.97	0.60	1993	9.83	5.90	0.60	2009	9.73	5.84	0.60	2019	9.62	5.77	0.60	2086	9.49	5.69	0.60	2178	9.32	5.59	0.60	2325	9.10	5.46	0.60	2433	8.84	5.30	0.60	2524	8.11	4.87	0.60	2681	6.69	4.02	0.60	2783	5.52	3.31	0.60	2890
	21	20	10.58	5.08	0.48	1981	10.48	5.03	0.48	1999	10.36	4.98	0.48	2017	10.23	4.91	0.48	2033	10.13	4.86	0.48	2043	10.02	4.81	0.48	2110	9.88	4.74	0.48	2202	9.71	4.66	0.48	2349	9.48	4.55	0.48	2456	9.20	4.42	0.48	2548	8.45	4.06	0.48	2705	6.97	3.35	0.48	2807	5.75	2.76	0.48	2913
	22	18	10.48	6.71	0.64	1977	10.38	6.64	0.64	1995	10.26	6.57	0.64	2013	10.13	6.48	0.64	2030	10.03	6.42	0.64	2040	9.92	6.35	0.64	2108	9.78	6.26	0.64	2200	9.61	6.15	0.64	2349	9.39	6.01	0.64	2457	9.11	5.83	0.64	2550	8.37	5.35	0.64	2708	6.90	4.42	0.64	2812	5.69	3.64	0.64	2919
	22	20	10.80	5.62	0.52	2001	10.69	5.56	0.52	2019	10.58	5.50	0.52	2037	10.44	5.43	0.52	2053	10.34	5.38	0.52	2064	10.22	5.32	0.52	2131	10.08	5.24	0.52	2224	9.91	5.15	0.52	2373	9.67	5.03	0.52	2481	9.39	4.88	0.52	2573	8.62	4.48	0.52	2732	7.11	3.70	0.52	2835	5.87	3.05	0.52	2943
	22	22	10.98	4.39	0.40	2017	10.87	4.35	0.40	2035	10.76	4.30	0.40	2053	10.62	4.25	0.40	2069	10.51	4.21	0.40	2080	10.40	4.16	0.40	2147	10.26	4.10	0.40	2240	10.07	4.03	0.40	2389	9.84	3.94	0.40	2497	9.55	3.82	0.40	2590	8.77	3.51	0.40	2748	7.23	2.89	0.40	2851	5.97	2.39	0.40	2959
	23	18	10.69	7.27	0.68	1997	10.59	7.20	0.68	2015	10.47	7.12	0.68	2034	10.34	7.03	0.68	2050	10.23	6.96	0.68	2060	10.12	6.88	0.68	2129	9.98	6.79	0.68	2223	9.81	6.67	0.68	2373	9.58	6.51	0.68	2482	9.30	6.32	0.68	2575	8.54	5.80	0.68	2736	7.04	4.79	0.68	2840	5.81	3.95	0.68	2948
	23	20	11.02	6.17	0.56	2021	10.91	6.11	0.56	2039	10.79	6.04	0.56	2058	10.65	5.97	0.56	2074	10.55	5.91	0.56	2084	10.43	5.84	0.56	2153	10.29	5.76	0.56	2247	10.11	5.66	0.56	2397	9.87	5.53	0.56	2506	9.58	5.37	0.56	2599	8.80	4.93	0.56	2760	7.26	4.06	0.56	2864	5.99	3.35	0.56	2972
	23	22	11.21	4.93	0.44	2037	11.10	4.88	0.44	2056	10.98	4.83	0.44	2074	10.83	4.77	0.44	2090	10.73	4.72	0.44	2101	10.61	4.67	0.44	2169	10.46	4.60	0.44	2263	10.28	4.52	0.44	2413	10.04	4.42	0.44	2523	9.75	4.29	0.44	2616	8.95	3.94	0.44	2776	7.38	3.25	0.44	2880	6.09	2.68	0.44	2989
	24	18	10.91	7.86	0.72	2017	10.80	7.78	0.72	2036	10.69	7.69	0.72	2054	10.55	7.59	0.72	2071	10.44	7.52	0.72	2081	10.33	7.44	0.72	2150	10.19	7.34	0.72	2245	10.01	7.21	0.72	2397	9.77	7.04	0.72	2507	9.49	6.83	0.72	2601	8.71	6.27	0.72	2763	7.19	5.17	0.72	2869	5.93	4.27	0.72	2978
	24	20	11.24	6.75	0.60	2041	11.13	6.68	0.60	2060	11.01	6.61	0.60	2078	10.87	6.52	0.60	2095	10.76	6.46	0.60	2105	10.65	6.39	0.60	2175	10.50	6.30	0.60	2269	10.31	6.19	0.60	2421	10.07	6.04	0.60	2532	9.78	5.87	0.60	2626	8.98	5.39	0.60	2788	7.41	4.44	0.60	2893	6.11	3.67	0.60	3002
	24	22	11.44	5.49	0.48	2058	11.32	5.43	0.48	2076	11.20	5.38	0.48	2095	11.06	5.31	0.48	2112	10.95	5.25	0.48	2122	10.83	5.20	0.48	2191	10.68	5.13	0.48	2286	10.49	5.03	0.48	2437	10.24	4.92	0.48	2548	9.94	4.77	0.48	2642	9.13	4.38	0.48	2804	7.53	3.62	0.48	2909	6.21	2.98	0.48	3019
	24	24	11.60	4.17	0.36	2077	11.48	4.13	0.36	2096	11.36	4.09	0.36	2114	11.21	4.04	0.36	2131	11.10	4.00	0.36	2141	10.98	3.95	0.36	2210	10.83	3.90	0.36	2305	10.64	3.83	0.36	2457	10.39	3.74	0.36	2568	10.08	3.63	0.36	2662	9.26	3.33	0.36	2823	7.64	2.75	0.36	2929	6.30	2.27	0.36	3038
	25	18	11.25	8.55	0.76	2037	11.14	8.46	0.76	2056	11.02	8.37	0.76	2075	10.87	8.26	0.76	2092	10.77	8.18	0.76	2102	10.65	8.09	0.76	2172	10.50	7.98	0.76	2268	10.32	7.84	0.76	2421	10.08	7.66	0.76	2533	9.78	7.43	0.76	2628	8.98	6.82	0.76	2791	7.41	5.63	0.76	2898	6.11	4.64	0.76	3008
	25	20	11.59	7.42	0.64	2062	11.48	7.35	0.64	2081	11.35	7.27	0.64	2099	11.21	7.17	0.64	2116	11.10	7.10	0.64	2127	10.98	7.02	0.64	2197	10.82	6.93	0.64	2292	10.63	6.80	0.64	2445	10.38	6.65	0.64	2557	10.08	6.45	0.64	2652	9.25	5.92	0.64	2816	7.63	4.89	0.64	2922	6.30	4.03	0.64	3033
	25	22	11.79	6.13	0.52	2079	11.67	6.07	0.52	2097	11.55	6.00	0.52	2116	11.40	5.93	0.52	2133	11.29	5.87	0.52	2143	11.16	5.80	0.52	2213	11.01	5.72	0.52	2309	10.81	5.62	0.52	2462	10.56	5.49	0.52	2574	10.25	5.33	0.52	2669	9.41	4.89	0.52	2832	7.76	4.04	0.52	2939	6.41	3.33	0.52	3049
	25	24	11.95	4.78	0.40	2098	11.84	4.73	0.40	2117	11.71	4.68	0.40	2136	11.56	4.62	0.40	2152	11.44	4.58	0.40	2163	11.32	4.53	0.40	2233	11.16	4.46	0.40	2328	10.96	4.39	0.40	2482	10.71	4.28	0.40	2593	10.40	4.16	0.40	2688	9.54	3.82	0.40	2852	7.87	3.15	0.40	2958	6.50	2.60	0.40	3069
	26	18	11.60	9.28	0.80	2058	11.48	9.19	0.80	2077	11.36	9.09	0.80	2096	11.21	8.97	0.80	2113	11.10	8.88	0.80	2123	10.98	8.78	0.80	2194	10.83	8.66	0.80	2291	10.64	8.51	0.80	2445	10.39	8.31	0.80	2558	10.08	8.07	0.80	2654	9.26	7.41	0.80	2819	7.64	6.11	0.80	2927	6.30	5.04	0.80	3038
	26	20	11.95	8.13	0.6.6																																																	

4. CAPACITIES AND SELECTION DATA

	Cooling Operation PERFORMANCE DATA																																																					
	OUTDOOR DB (°C)																																																					
COMBINATION (%)	IDDB (°C)	ID WB (°C)	-15				-7				0				10				15				21				25				27				30				35				40				45				50			
			Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT								
110%	21	18	9.97	5.98	0.60	1938	9.87	5.92	0.60	1956	9.76	5.86	0.60	1974	9.64	5.78	0.60	1990	9.54	5.73	0.60	2000	9.44	5.66	0.60	2066	9.31	5.59	0.60	2157	9.15	5.49	0.60	2303	8.93	5.36	0.60	2409	8.67	5.20	0.60	2500	7.96	4.78	0.60	2655	6.57	3.94	0.60	2756	5.42	3.25	0.60	2862
	21	20	10.38	4.98	0.48	1962	10.28	4.93	0.48	1979	10.17	4.88	0.48	1997	10.04	4.82	0.48	2013	9.94	4.77	0.48	2023	9.83	4.72	0.48	2090	9.69	4.65	0.48	2181	9.52	4.57	0.48	2326	9.30	4.46	0.48	2433	9.03	4.33	0.48	2523	8.29	3.98	0.48	2679	6.84	3.28	0.48	2780	5.64	2.71	0.48	2885
	22	18	10.28	6.58	0.64	1958	10.18	6.51	0.64	1976	10.07	6.44	0.64	1994	9.94	6.36	0.64	2010	9.84	6.30	0.64	2020	9.73	6.23	0.64	2087	9.60	6.14	0.64	2179	9.43	6.03	0.64	2326	9.21	5.89	0.64	2434	8.94	5.72	0.64	2525	8.21	5.25	0.64	2682	6.77	4.33	0.64	2784	5.59	3.57	0.64	2890
	22	20	10.59	5.51	0.52	1982	10.49	5.45	0.52	1999	10.37	5.39	0.52	2017	10.24	5.33	0.52	2034	10.14	5.27	0.52	2044	10.03	5.22	0.52	2111	9.89	5.14	0.52	2203	9.72	5.05	0.52	2350	9.49	4.93	0.52	2457	9.21	4.79	0.52	2549	8.46	4.40	0.52	2706	6.98	3.63	0.52	2808	5.76	2.99	0.52	2914
	22	22	10.77	4.31	0.40	1998	10.67	4.27	0.40	2016	10.55	4.22	0.40	2034	10.42	4.17	0.40	2050	10.31	4.13	0.40	2060	10.20	4.08	0.40	2127	10.06	4.02	0.40	2219	9.88	3.95	0.40	2366	9.65	3.86	0.40	2474	9.37	3.75	0.40	2565	8.60	3.44	0.40	2722	7.10	2.84	0.40	2824	5.85	2.34	0.40	2930
	23	18	10.49	7.13	0.68	1978	10.39	7.06	0.68	1996	10.27	6.99	0.68	2014	10.14	6.90	0.68	2030	10.04	6.83	0.68	2040	9.93	6.75	0.68	2108	9.79	6.66	0.68	2201	9.62	6.54	0.68	2350	9.39	6.39	0.68	2458	9.12	6.20	0.68	2550	8.37	5.69	0.68	2709	6.91	4.70	0.68	2812	5.70	3.88	0.68	2920
	23	20	10.81	6.05	0.56	2002	10.70	5.99	0.56	2020	10.59	5.93	0.56	2038	10.45	5.85	0.56	2054	10.35	5.79	0.56	2064	10.23	5.73	0.56	2132	10.09	5.65	0.56	2225	9.91	5.55	0.56	2374	9.68	5.42	0.56	2482	9.40	5.26	0.56	2574	8.63	4.83	0.56	2733	7.12	3.99	0.56	2836	5.87	3.29	0.56	2944
	23	22	10.99	4.84	0.44	2018	10.89	4.79	0.44	2036	10.77	4.74	0.44	2054	10.63	4.68	0.44	2070	10.52	4.63	0.44	2081	10.41	4.58	0.44	2149	10.27	4.52	0.44	2241	10.08	4.44	0.44	2390	9.85	4.33	0.44	2499	9.56	4.21	0.44	2591	8.78	3.86	0.44	2749	7.24	3.19	0.44	2853	5.97	2.63	0.44	2960
	24	18	10.70	7.71	0.72	1998	10.60	7.63	0.72	2016	10.48	7.55	0.72	2034	10.35	7.45	0.72	2051	10.24	7.38	0.72	2061	10.13	7.30	0.72	2129	9.99	7.20	0.72	2223	9.82	7.07	0.72	2373	9.59	6.90	0.72	2483	9.31	6.70	0.72	2576	8.54	6.15	0.72	2736	7.05	5.08	0.72	2841	5.82	4.19	0.72	2949
	24	20	11.03	6.62	0.60	2022	10.92	6.55	0.60	2040	10.80	6.48	0.60	2058	10.66	6.40	0.60	2075	10.56	6.34	0.60	2085	10.44	6.27	0.60	2154	10.30	6.18	0.60	2247	10.12	6.07	0.60	2398	9.88	5.93	0.60	2507	9.59	5.76	0.60	2600	8.81	5.28	0.60	2761	7.26	4.36	0.60	2865	5.99	3.60	0.60	2973
	24	22	11.22	5.38	0.48	2038	11.11	5.33	0.48	2057	10.99	5.27	0.48	2075	10.85	5.21	0.48	2091	10.74	5.15	0.48	2102	10.62	5.10	0.48	2170	10.47	5.03	0.48	2264	10.29	4.94	0.48	2414	10.05	4.82	0.48	2524	9.76	4.68	0.48	2617	8.96	4.30	0.48	2777	7.39	3.55	0.48	2882	6.10	2.93	0.48	2990
	24	24	11.38	4.10	0.36	2058	11.26	4.05	0.36	2076	11.14	4.01	0.36	2094	11.00	3.96	0.36	2111	10.89	3.92	0.36	2121	10.77	3.88	0.36	2190	10.62	3.82	0.36	2283	10.43	3.76	0.36	2434	10.19	3.67	0.36	2543	9.89	3.56	0.36	2636	9.08	3.27	0.36	2797	7.49	2.70	0.36	2901	6.18	2.23	0.36	3009
	25	18	11.03	8.39	0.76	2018	10.92	8.30	0.76	2036	10.81	8.21	0.76	2055	10.67	8.11	0.76	2071	10.56	8.03	0.76	2082	10.45	7.94	0.76	2151	10.30	7.83	0.76	2246	10.12	7.69	0.76	2397	9.88	7.51	0.76	2508	9.60	7.29	0.76	2602	8.81	6.69	0.76	2764	7.27	5.52	0.76	2870	6.00	4.56	0.76	2979
	25	20	11.37	7.28	0.64	2042	11.26	7.21	0.64	2061	11.14	7.13	0.64	2079	10.99	7.04	0.64	2096	10.89	6.97	0.64	2106	10.77	6.89	0.64	2175	10.62	6.80	0.64	2270	10.43	6.68	0.64	2422	10.19	6.52	0.64	2533	9.89	6.33	0.64	2627	9.08	5.81	0.64	2789	7.49	4.79	0.64	2894	6.18	3.95	0.64	3003
	25	22	11.57	6.01	0.52	2059	11.45	5.95	0.52	2077	11.33	5.89	0.52	2096	11.18	5.81	0.52	2113	11.07	5.76	0.52	2123	10.95	5.69	0.52	2192	10.80	5.62	0.52	2287	10.61	5.52	0.52	2439	10.36	5.39	0.52	2549	10.06	5.23	0.52	2643	9.23	4.80	0.52	2805	7.62	3.96	0.52	2911	6.28	3.27	0.52	3020
	25	24	11.73	4.69	0.40	2078	11.61	4.64	0.40	2097	11.48	4.59	0.40	2115	11.34	4.53	0.40	2132	11.23	4.49	0.40	2143	11.10	4.44	0.40	2212	10.95	4.38	0.40	2306	10.76	4.30	0.40	2458	10.50	4.20	0.40	2569	10.20	4.08	0.40	2663	9.36	3.74	0.40	2825	7.72	3.09	0.40	2930	6.37	2.55	0.40	3040
	26	18	11.38	9.10	0.80	2038	11.26	9.01	0.80	2057	11.14	8.91	0.80	2075	11.00	8.80	0.80	2092	10.89	8.71	0.80	2103	10.77	8.62	0.80	2173	10.62	8.50	0.80	2268	10.43	8.35	0.80	2422	10.19	8.15	0.80	2533	9.89	7.91	0.80	2628	9.08	7.26	0.80	2792	7.49	5.99	0.80	2899	6.18	4.94	0.80	3009
	26	20	11.72	7.97	0.68	2063	11.61	7.89	0.68	2081	11.48	7.81	0.68	2100	11.33</																																							

4. CAPACITIES AND SELECTION DATA

	Cooling Operation PERFORMANCE DATA																																																					
	OUTDOOR DB (°C)																																																					
COMBINATION (%)	IDDB (°C)	ID WB (°C)	-15				-7				0				10				15				21				25				27				30				35				40				45				50			
			Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT								
100%	21	18	9.68	5.81	0.60	1891	9.58	5.75	0.60	1908	9.48	5.69	0.60	1925	9.36	5.62	0.60	1941	9.27	5.56	0.60	1951	9.17	5.50	0.60	2016	9.04	5.42	0.60	2104	8.88	5.33	0.60	2246	8.67	5.20	0.60	2350	8.42	5.05	0.60	2438	7.73	4.64	0.60	2590	6.38	3.83	0.60	2689	5.26	3.16	0.60	2792
	21	20	10.08	4.84	0.48	1914	9.98	4.79	0.48	1932	9.87	4.74	0.48	1949	9.74	4.68	0.48	1965	9.65	4.63	0.48	1974	9.54	4.58	0.48	2039	9.41	4.52	0.48	2128	9.24	4.44	0.48	2270	9.03	4.33	0.48	2374	8.77	4.21	0.48	2462	8.05	3.86	0.48	2614	6.64	3.19	0.48	2713	5.48	2.63	0.48	2815
	22	18	9.98	6.39	0.64	1910	9.88	6.32	0.64	1927	9.77	6.26	0.64	1945	9.65	6.17	0.64	1961	9.55	6.11	0.64	1970	9.45	6.05	0.64	2036	9.32	5.96	0.64	2126	9.15	5.86	0.64	2269	8.94	5.72	0.64	2374	8.68	5.55	0.64	2463	7.97	5.10	0.64	2616	6.57	4.21	0.64	2716	5.42	3.47	0.64	2820
	22	20	10.29	5.35	0.52	1934	10.18	5.30	0.52	1951	10.07	5.24	0.52	1969	9.94	5.17	0.52	1984	9.85	5.12	0.52	1994	9.74	5.06	0.52	2060	9.60	4.99	0.52	2149	9.43	4.91	0.52	2293	9.21	4.79	0.52	2398	8.94	4.65	0.52	2487	8.21	4.27	0.52	2640	6.77	3.52	0.52	2740	5.59	2.91	0.52	2843
	22	22	10.46	4.18	0.40	1950	10.36	4.14	0.40	1967	10.24	4.10	0.40	1985	10.11	4.05	0.40	2001	10.01	4.00	0.40	2010	9.90	3.96	0.40	2076	9.77	3.91	0.40	2166	9.59	3.84	0.40	2309	9.37	3.75	0.40	2414	9.10	3.64	0.40	2503	8.35	3.34	0.40	2656	6.89	2.76	0.40	2756	5.68	2.27	0.40	2860
	23	18	10.18	6.92	0.68	1929	10.08	6.86	0.68	1947	9.97	6.78	0.68	1964	9.85	6.69	0.68	1980	9.75	6.63	0.68	1990	9.64	6.56	0.68	2057	9.51	6.47	0.68	2147	9.34	6.35	0.68	2292	9.12	6.20	0.68	2398	8.86	6.02	0.68	2488	8.13	5.53	0.68	2643	6.71	4.56	0.68	2744	5.53	3.76	0.68	2848
	23	20	10.50	5.88	0.56	1953	10.39	5.82	0.56	1971	10.28	5.76	0.56	1988	10.15	5.68	0.56	2004	10.05	5.63	0.56	2014	9.94	5.56	0.56	2081	9.80	5.49	0.56	2171	9.63	5.39	0.56	2316	9.40	5.26	0.56	2422	9.13	5.11	0.56	2512	8.38	4.69	0.56	2667	6.91	3.87	0.56	2768	5.70	3.19	0.56	2872
	23	22	10.67	4.70	0.44	1969	10.57	4.65	0.44	1987	10.45	4.60	0.44	2005	10.32	4.54	0.44	2021	10.22	4.50	0.44	2031	10.11	4.45	0.44	2097	9.97	4.39	0.44	2187	9.79	4.31	0.44	2332	9.56	4.21	0.44	2438	9.28	4.08	0.44	2528	8.52	3.75	0.44	2683	7.03	3.09	0.44	2784	5.80	2.55	0.44	2889
	24	18	10.39	7.48	0.72	1949	10.29	7.41	0.72	1966	10.18	7.33	0.72	1984	10.05	7.23	0.72	2000	9.95	7.16	0.72	2010	9.84	7.08	0.72	2077	9.70	6.99	0.72	2169	9.53	6.86	0.72	2315	9.31	6.70	0.72	2422	9.04	6.51	0.72	2513	8.30	5.97	0.72	2669	6.84	4.93	0.72	2771	5.65	4.07	0.72	2877
	24	20	10.71	6.43	0.60	1973	10.60	6.36	0.60	1991	10.49	6.29	0.60	2009	10.35	6.21	0.60	2025	10.25	6.15	0.60	2035	10.14	6.08	0.60	2102	10.00	6.00	0.60	2193	9.82	5.89	0.60	2340	9.59	5.76	0.60	2447	9.31	5.59	0.60	2537	8.55	5.13	0.60	2694	7.05	4.23	0.60	2796	5.82	3.49	0.60	2901
	24	22	10.89	5.23	0.48	1989	10.78	5.18	0.48	2007	10.67	5.12	0.48	2025	10.53	5.05	0.48	2041	10.43	5.00	0.48	2051	10.31	4.95	0.48	2118	10.17	4.88	0.48	2210	9.99	4.80	0.48	2356	9.76	4.68	0.48	2463	9.47	4.55	0.48	2554	8.69	4.17	0.48	2710	7.17	3.44	0.48	2812	5.92	2.84	0.48	2918
	24	24	11.04	3.98	0.36	2009	10.93	3.94	0.36	2027	10.82	3.89	0.36	2044	10.68	3.84	0.36	2061	10.57	3.81	0.36	2071	10.46	3.76	0.36	2137	10.31	3.71	0.36	2229	10.13	3.65	0.36	2375	9.89	3.56	0.36	2482	9.60	3.46	0.36	2573	8.82	3.17	0.36	2730	7.27	2.62	0.36	2831	6.00	2.16	0.36	2937
	25	18	10.71	8.14	0.76	1968	10.61	8.06	0.76	1986	10.49	7.97	0.76	2004	10.36	7.87	0.76	2021	10.25	7.79	0.76	2031	10.14	7.71	0.76	2098	10.00	7.60	0.76	2191	9.83	7.47	0.76	2339	9.60	7.29	0.76	2447	9.32	7.08	0.76	2538	8.55	6.50	0.76	2696	7.06	5.36	0.76	2799	5.82	4.42	0.76	2906
	25	20	11.04	7.07	0.64	1993	10.93	7.00	0.64	2011	10.81	6.92	0.64	2029	10.67	6.83	0.64	2045	10.57	6.76	0.64	2055	10.45	6.69	0.64	2123	10.31	6.60	0.64	2215	10.13	6.48	0.64	2363	9.89	6.33	0.64	2471	9.60	6.14	0.64	2563	8.81	5.64	0.64	2721	7.27	4.65	0.64	2824	6.00	3.84	0.64	2931
	25	22	11.23	5.84	0.52	2009	11.12	5.78	0.52	2027	11.00	5.72	0.52	2046	10.86	5.64	0.52	2062	10.75	5.59	0.52	2072	10.63	5.53	0.52	2139	10.48	5.45	0.52	2232	10.30	5.36	0.52	2380	10.06	5.23	0.52	2488	9.76	5.08	0.52	2580	8.96	4.66	0.52	2738	7.39	3.85	0.52	2840	6.10	3.17	0.52	2947
	25	24	11.39	4.55	0.40	2029	11.27	4.51	0.40	2047	11.15	4.46	0.40	2065	11.01	4.40	0.40	2081	10.90	4.36	0.40	2092	10.78	4.31	0.40	2159	10.63	4.25	0.40	2251	10.44	4.18	0.40	2399	10.20	4.08	0.40	2507	9.90	3.96	0.40	2599	9.09	3.64	0.40	2757	7.50	3.00	0.40	2860	6.19	2.47	0.40	2967
	26	18	11.04	8.84	0.80	1988	10.93	8.75	0.80	2006	10.82	8.65	0.80	2025	10.68	8.54	0.80	2041	10.57	8.46	0.80	2051	10.46	8.36	0.80	2119	10.31	8.25	0.80	2213	10.13	8.10	0.80	2362	9.89	7.91	0.80	2471	9.60	7.68	0.80	2564	8.82	7.05	0.80	2724	7.27	5.82	0.80	2828	6.00	4.80	0.80	2935
	26	20	11.38	7.74	0.68	2013	11.27	7.66	0.68	2031	11.15	7.58	0.68	2049	11.00	7.48	0.68	2066																																				

4. CAPACITIES AND SELECTION DATA

				Cooling Operation PERFORMANCE DATA																																																		
				OUTDOOR DB (°C)																																																		
COMBINATION (%)	IDDB (°C)	ID WB (°C)	-15				-7				0				10				15				21				25				27				30				35				40				45				50			
			Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT								
90%	21	18	9.49	5.69	0.60	1872	9.39	5.64	0.60	1889	9.29	5.57	0.60	1906	9.17	5.50	0.60	1921	9.08	5.45	0.60	1931	8.98	5.39	0.60	1995	8.86	5.31	0.60	2083	8.70	5.22	0.60	2224	8.50	5.10	0.60	2327	8.25	4.95	0.60	2414	7.57	4.54	0.60	2564	6.25	3.75	0.60	2662	5.15	3.09	0.60	2764
	21	20	9.88	4.74	0.48	1895	9.78	4.69	0.48	1912	9.67	4.64	0.48	1930	9.55	4.58	0.48	1945	9.46	4.54	0.48	1955	9.35	4.49	0.48	2019	9.22	4.43	0.48	2107	9.06	4.35	0.48	2247	8.85	4.25	0.48	2350	8.59	4.12	0.48	2437	7.89	3.79	0.48	2588	6.51	3.12	0.48	2686	5.37	2.58	0.48	2787
	22	18	9.78	6.26	0.64	1891	9.68	6.20	0.64	1908	9.58	6.13	0.64	1925	9.46	6.05	0.64	1941	9.36	5.99	0.64	1951	9.26	5.93	0.64	2015	9.13	5.84	0.64	2104	8.97	5.74	0.64	2246	8.76	5.61	0.64	2350	8.50	5.44	0.64	2438	7.81	5.00	0.64	2590	6.44	4.12	0.64	2689	5.31	3.40	0.64	2791
	22	20	10.08	5.24	0.52	1914	9.98	5.19	0.52	1932	9.87	5.13	0.52	1949	9.74	5.07	0.52	1965	9.65	5.02	0.52	1974	9.54	4.96	0.52	2039	9.41	4.89	0.52	2128	9.24	4.81	0.52	2270	9.03	4.69	0.52	2374	8.77	4.56	0.52	2462	8.05	4.18	0.52	2614	6.64	3.45	0.52	2713	5.48	2.85	0.52	2815
	22	22	10.25	4.10	0.40	1931	10.15	4.06	0.40	1948	10.04	4.02	0.40	1965	9.91	3.96	0.40	1981	9.81	3.92	0.40	1991	9.71	3.88	0.40	2055	9.57	3.83	0.40	2144	9.40	3.76	0.40	2286	9.18	3.67	0.40	2390	8.91	3.57	0.40	2478	8.18	3.27	0.40	2630	6.75	2.70	0.40	2729	5.57	2.23	0.40	2831
	23	18	9.98	6.79	0.68	1910	9.88	6.72	0.68	1927	9.77	6.65	0.68	1945	9.65	6.56	0.68	1960	9.55	6.50	0.68	1970	9.45	6.43	0.68	2036	9.32	6.34	0.68	2126	9.15	6.22	0.68	2269	8.94	6.08	0.68	2374	8.68	5.90	0.68	2463	7.97	5.42	0.68	2616	6.57	4.47	0.68	2716	5.42	3.69	0.68	2820
	23	20	10.29	5.76	0.56	1934	10.18	5.70	0.56	1951	10.07	5.64	0.56	1969	9.94	5.57	0.56	1985	9.85	5.51	0.56	1994	9.74	5.45	0.56	2060	9.60	5.38	0.56	2150	9.43	5.28	0.56	2293	9.21	5.16	0.56	2398	8.94	5.01	0.56	2487	8.21	4.60	0.56	2640	6.77	3.79	0.56	2740	5.59	3.13	0.56	2844
	23	22	10.46	4.60	0.44	1950	10.36	4.56	0.44	1967	10.24	4.51	0.44	1985	10.11	4.45	0.44	2001	10.01	4.41	0.44	2011	9.90	4.36	0.44	2076	9.77	4.30	0.44	2166	9.59	4.22	0.44	2309	9.37	4.12	0.44	2414	9.10	4.00	0.44	2503	8.35	3.67	0.44	2657	6.89	3.03	0.44	2756	5.68	2.50	0.44	2860
	24	18	10.18	7.33	0.72	1929	10.08	7.26	0.72	1947	9.97	7.18	0.72	1964	9.85	7.09	0.72	1980	9.75	7.02	0.72	1990	9.64	6.94	0.72	2056	9.51	6.85	0.72	2147	9.34	6.72	0.72	2292	9.12	6.57	0.72	2398	8.86	6.38	0.72	2488	8.13	5.85	0.72	2643	6.71	4.83	0.72	2743	5.53	3.98	0.72	2848
	24	20	10.50	6.30	0.60	1953	10.39	6.23	0.60	1971	10.28	6.17	0.60	1989	10.15	6.09	0.60	2005	10.05	6.03	0.60	2015	9.94	5.96	0.60	2081	9.80	5.88	0.60	2171	9.63	5.78	0.60	2316	9.40	5.64	0.60	2422	9.13	5.48	0.60	2512	8.38	5.03	0.60	2667	6.91	4.15	0.60	2768	5.70	3.42	0.60	2872
	24	22	10.67	5.12	0.48	1970	10.57	5.07	0.48	1987	10.45	5.02	0.48	2005	10.32	4.95	0.48	2021	10.22	4.90	0.48	2031	10.11	4.85	0.48	2097	9.97	4.78	0.48	2188	9.79	4.70	0.48	2333	9.56	4.59	0.48	2439	9.28	4.46	0.48	2529	8.52	4.09	0.48	2683	7.03	3.37	0.48	2784	5.80	2.78	0.48	2889
	24	24	10.82	3.90	0.36	1989	10.72	3.86	0.36	2007	10.60	3.82	0.36	2025	10.46	3.77	0.36	2040	10.36	3.73	0.36	2050	10.25	3.69	0.36	2117	10.11	3.64	0.36	2207	9.93	3.57	0.36	2352	9.69	3.49	0.36	2458	9.41	3.39	0.36	2548	8.64	3.11	0.36	2703	7.13	2.57	0.36	2804	5.88	2.12	0.36	2908
	25	18	10.50	7.98	0.76	1948	10.39	7.90	0.76	1966	10.28	7.81	0.76	1984	10.15	7.71	0.76	2000	10.05	7.64	0.76	2010	9.94	7.55	0.76	2077	9.80	7.45	0.76	2169	9.63	7.32	0.76	2315	9.40	7.15	0.76	2422	9.13	6.94	0.76	2513	8.38	6.37	0.76	2669	6.91	5.25	0.76	2771	5.70	4.34	0.76	2877
	25	20	10.82	6.92	0.64	1973	10.71	6.86	0.64	1991	10.60	6.78	0.64	2009	10.46	6.69	0.64	2025	10.36	6.63	0.64	2035	10.24	6.56	0.64	2102	10.10	6.47	0.64	2193	9.92	6.35	0.64	2340	9.69	6.20	0.64	2447	9.41	6.02	0.64	2537	8.64	5.53	0.64	2694	7.13	4.56	0.64	2796	5.88	3.76	0.64	2901
	25	22	11.00	5.72	0.52	1990	10.89	5.67	0.52	2007	10.78	5.60	0.52	2025	10.64	5.53	0.52	2041	10.53	5.48	0.52	2052	10.42	5.42	0.52	2118	10.27	5.34	0.52	2210	10.09	5.25	0.52	2356	9.86	5.13	0.52	2463	9.57	4.98	0.52	2554	8.78	4.57	0.52	2711	7.25	3.77	0.52	2812	5.98	3.11	0.52	2918
	25	24	11.16	4.46	0.40	2009	11.05	4.42	0.40	2027	10.93	4.37	0.40	2045	10.79	4.31	0.40	2061	10.68	4.27	0.40	2071	10.56	4.23	0.40	2138	10.42	4.17	0.40	2229	10.23	4.09	0.40	2376	9.99	4.00	0.40	2483	9.70	3.88	0.40	2574	8.91	3.56	0.40	2730	7.35	2.94	0.40	2832	6.06	2.43	0.40	2938
	26	18	10.82	8.66	0.80	1968	10.72	8.57	0.80	1986	10.60	8.48	0.80	2004	10.46	8.37	0.80	2021	10.36	8.29	0.80	2031	10.25	8.20	0.80	2098	10.11	8.08	0.80	2191	9.93	7.94	0.80	2339	9.69	7.76	0.80	2447	9.41	7.53	0.80	2538	8.64	6.91	0.80	2696	7.13	5.70	0.80	2799	5.88	4.70	0.80	2906
	26	20	11.15	7.59	0.68	1993	11.04	7.51	0.68	2011	10.92	7.43	0.68	2029	10.78	7.33	0.68	2045	10.68	7.26	0.68	2055	10.56	7.1																														

4. CAPACITIES AND SELECTION DATA

	Cooling Operation PERFORMANCE DATA																																																					
	OUTDOOR DB (°C)																																																					
COMBINATION (%)	IDDB (°C)	ID WB (°C)	-15				-7				0				10				15				21				25				27				30				35				40				45				50			
			Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT	Q	SHC	SHF	IPT												
80%	21	18	9.20	5.52	0.60	1853	9.11	5.46	0.60	1870	9.01	5.40	0.60	1887	8.89	5.33	0.60	1902	8.80	5.28	0.60	1912	8.71	5.22	0.60	1975	8.59	5.15	0.60	2062	8.43	5.06	0.60	2201	8.24	4.94	0.60	2303	8.00	4.80	0.60	2389	7.34	4.40	0.60	2538	6.06	3.63	0.60	2635	5.00	3.00	0.60	2736
	21	20	9.58	4.60	0.48	1876	9.48	4.55	0.48	1893	9.38	4.50	0.48	1910	9.26	4.44	0.48	1926	9.17	4.40	0.48	1935	9.07	4.35	0.48	1999	8.94	4.29	0.48	2086	8.78	4.22	0.48	2225	8.58	4.12	0.48	2327	8.33	4.00	0.48	2413	7.64	3.67	0.48	2562	6.31	3.03	0.48	2659	5.20	2.50	0.48	2759
	22	18	9.48	6.07	0.64	1871	9.39	6.01	0.64	1889	9.28	5.94	0.64	1906	9.17	5.87	0.64	1921	9.07	5.81	0.64	1931	8.98	5.74	0.64	1995	8.85	5.67	0.64	2083	8.70	5.57	0.64	2224	8.49	5.43	0.64	2326	8.24	5.28	0.64	2414	7.57	4.84	0.64	2564	6.24	4.00	0.64	2662	5.15	3.30	0.64	2763
	22	20	9.77	5.08	0.52	1895	9.67	5.03	0.52	1912	9.57	4.98	0.52	1930	9.45	4.91	0.52	1945	9.35	4.86	0.52	1955	9.25	4.81	0.52	2019	9.12	4.74	0.52	2107	8.96	4.66	0.52	2247	8.75	4.55	0.52	2350	8.50	4.42	0.52	2437	7.80	4.06	0.52	2588	6.44	3.35	0.52	2685	5.31	2.76	0.52	2787
	22	22	9.94	3.97	0.40	1911	9.84	3.94	0.40	1928	9.73	3.89	0.40	1946	9.61	3.84	0.40	1961	9.51	3.80	0.40	1971	9.41	3.76	0.40	2035	9.28	3.71	0.40	2123	9.11	3.65	0.40	2264	8.90	3.56	0.40	2366	8.64	3.46	0.40	2454	7.93	3.17	0.40	2604	6.54	2.62	0.40	2702	5.40	2.16	0.40	2803
	23	18	9.67	6.58	0.68	1890	9.58	6.51	0.68	1908	9.47	6.44	0.68	1925	9.35	6.36	0.68	1941	9.26	6.30	0.68	1950	9.16	6.23	0.68	2015	9.03	6.14	0.68	2104	8.87	6.03	0.68	2246	8.67	5.89	0.68	2350	8.41	5.72	0.68	2438	7.72	5.25	0.68	2590	6.37	4.33	0.68	2689	5.26	3.57	0.68	2791
	23	20	9.97	5.58	0.56	1914	9.87	5.53	0.56	1932	9.76	5.47	0.56	1949	9.64	5.40	0.56	1965	9.54	5.34	0.56	1974	9.44	5.29	0.56	2039	9.31	5.21	0.56	2128	9.14	5.12	0.56	2270	8.93	5.00	0.56	2374	8.67	4.86	0.56	2462	7.96	4.46	0.56	2614	6.57	3.68	0.56	2713	5.42	3.03	0.56	2815
	23	22	10.14	4.46	0.44	1931	10.04	4.42	0.44	1948	9.93	4.37	0.44	1965	9.80	4.31	0.44	1981	9.71	4.27	0.44	1991	9.60	4.22	0.44	2056	9.47	4.17	0.44	2144	9.30	4.09	0.44	2286	9.08	4.00	0.44	2390	8.82	3.88	0.44	2478	8.09	3.56	0.44	2630	6.68	2.94	0.44	2729	5.51	2.42	0.44	2831
	24	18	9.87	7.11	0.72	1909	9.77	7.04	0.72	1927	9.67	6.96	0.72	1944	9.54	6.87	0.72	1960	9.45	6.80	0.72	1970	9.35	6.73	0.72	2036	9.22	6.64	0.72	2125	9.05	6.52	0.72	2269	8.84	6.37	0.72	2374	8.58	6.18	0.72	2463	7.88	5.67	0.72	2616	6.50	4.68	0.72	2716	5.36	3.86	0.72	2819
	24	20	10.17	6.10	0.60	1934	10.07	6.04	0.60	1951	9.96	5.98	0.60	1969	9.84	5.90	0.60	1984	9.74	5.84	0.60	1994	9.63	5.78	0.60	2060	9.50	5.70	0.60	2149	9.33	5.60	0.60	2293	9.11	5.47	0.60	2398	8.85	5.31	0.60	2487	8.12	4.87	0.60	2640	6.70	4.02	0.60	2740	5.53	3.32	0.60	2843
	24	22	10.35	4.97	0.48	1950	10.24	4.92	0.48	1968	10.13	4.86	0.48	1985	10.00	4.80	0.48	2001	9.90	4.75	0.48	2011	9.80	4.70	0.48	2076	9.66	4.64	0.48	2166	9.49	4.56	0.48	2310	9.27	4.45	0.48	2414	9.00	4.32	0.48	2503	8.26	3.96	0.48	2657	6.81	3.27	0.48	2756	5.62	2.70	0.48	2860
	24	24	10.49	3.78	0.36	1970	10.39	3.74	0.36	1987	10.27	3.70	0.36	2005	10.14	3.65	0.36	2020	10.04	3.62	0.36	2030	9.93	3.58	0.36	2096	9.80	3.53	0.36	2185	9.62	3.46	0.36	2329	9.40	3.38	0.36	2434	9.12	3.28	0.36	2523	8.38	3.02	0.36	2676	6.91	2.49	0.36	2776	5.70	2.05	0.36	2879
	25	18	10.18	7.73	0.76	1929	10.08	7.66	0.76	1946	9.97	7.57	0.76	1964	9.84	7.48	0.76	1980	9.74	7.40	0.76	1990	9.64	7.32	0.76	2056	9.50	7.22	0.76	2147	9.33	7.09	0.76	2292	9.12	6.93	0.76	2398	8.85	6.73	0.76	2487	8.12	6.17	0.76	2642	6.70	5.09	0.76	2743	5.53	4.20	0.76	2848
	25	20	10.49	6.71	0.64	1953	10.38	6.65	0.64	1971	10.27	6.57	0.64	1989	10.14	6.49	0.64	2004	10.04	6.43	0.64	2014	9.93	6.36	0.64	2081	9.79	6.27	0.64	2171	9.62	6.16	0.64	2316	9.39	6.01	0.64	2422	9.12	5.84	0.64	2512	8.37	5.36	0.64	2667	6.91	4.42	0.64	2768	5.70	3.65	0.64	2872
	25	22	10.67	5.55	0.52	1970	10.56	5.49	0.52	1987	10.45	5.43	0.52	2005	10.31	5.36	0.52	2021	10.21	5.31	0.52	2031	10.10	5.25	0.52	2097	9.96	5.18	0.52	2188	9.78	5.09	0.52	2333	9.55	4.97	0.52	2439	9.28	4.82	0.52	2529	8.52	4.43	0.52	2683	7.03	3.65	0.52	2784	5.80	3.01	0.52	2889
	25	24	10.82	4.33	0.40	1989	10.71	4.28	0.40	2007	10.59	4.24	0.40	2025	10.46	4.18	0.40	2041	10.35	4.14	0.40	2051	10.24	4.10	0.40	2117	10.10	4.04	0.40	2207	9.92	3.97	0.40	2352	9.69	3.88	0.40	2458	9.41	3.76	0.40	2548	8.63	3.45	0.40	2703	7.12	2.85	0.40	2804	5.88	2.35	0.40	2908
	26	18	10.49	8.39	0.80	1948	10.39	8.31	0.80	1966	10.27	8.22	0.80	1984	10.14	8.11	0.80	2000	10.04	8.03	0.80	2010	9.93	7.95	0.80	2077	9.80	7.84	0.80	2168	9.62	7.70	0.80	2315	9.40	7.52	0.80	2422	9.12	7.30	0.80	2513	8.38	6.70	0.80	2669	6.91	5.53	0.80	2771	5.70	4.56	0.80	2876
	26	20	10.81	7.35	0.68	1973	10.71	7.28	0.68	1991	10.59	7.20	0.68	2009	10.45	7.11	0.68	2025																																				

4. CAPACITIES AND SELECTION DATA

36K

HEATING PERFORMANCE DATA

COMBINATION (%)	INDOOR DB(°C)	OUTDOOR WB(°C)															
		-15		-10		-5		0		5		10		15		20	
		Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT
130%	15	7.95	2639	9.35	2721	10.39	2748	11.42	2804	12.42	2952	13.41	3099	14.08	3192	14.50	3256
	16	7.86	2660	9.24	2743	10.27	2770	11.29	2827	12.27	2976	13.25	3124	13.91	3218	14.33	3282
	17	7.76	2682	9.13	2765	10.15	2793	11.15	2850	12.12	3000	13.09	3150	13.75	3244	14.16	3309
	18	7.67	2703	9.03	2787	10.03	2815	11.02	2873	11.98	3024	12.94	3175	13.58	3270	13.99	3336
	19	7.58	2725	8.92	2809	9.91	2838	10.89	2896	11.84	3048	12.78	3201	13.42	3297	13.83	3363
	20	7.51	2747	8.83	2832	9.81	2861	10.78	2919	11.72	3073	12.66	3226	13.29	3323	13.69	3390
	21	7.42	2777	8.72	2863	9.69	2892	10.65	2951	11.58	3107	12.51	3262	13.13	3360	13.52	3427
	22	7.33	2808	8.62	2895	9.58	2924	10.52	2984	11.44	3141	12.36	3298	12.97	3397	13.36	3465
	23	7.24	2839	8.52	2927	9.46	2956	10.40	3017	11.30	3175	12.21	3334	12.82	3434	13.20	3503
	24	7.15	2870	8.41	2959	9.35	2989	10.27	3050	11.17	3210	12.06	3371	12.66	3472	13.04	3541
	25	7.07	2902	8.31	2991	9.24	3022	10.15	3083	11.03	3246	11.92	3408	12.51	3510	12.89	3580
	26	6.98	2934	8.21	3024	9.13	3055	10.03	3117	10.90	3281	11.77	3445	12.36	3549	12.73	3620
	27	6.90	2966	8.11	3058	9.02	3088	9.91	3151	10.77	3317	11.63	3483	12.21	3588	12.58	3659
	28	6.81	2998	8.02	3091	8.91	3122	9.79	3186	10.64	3354	11.49	3521	12.07	3627	12.43	3700
	29	6.73	3031	7.92	3125	8.80	3157	9.67	3221	10.51	3391	11.35	3560	11.92	3667	12.28	3740
	30	6.65	3065	7.83	3160	8.70	3191	9.56	3257	10.39	3428	11.22	3599	11.78	3707	12.13	3782
120%	15	7.72	2513	9.08	2591	10.09	2617	11.09	2671	12.05	2811	13.02	2952	13.67	3040	14.08	3101
	16	7.63	2534	8.97	2612	9.97	2638	10.96	2692	11.91	2834	12.86	2976	13.51	3065	13.91	3126
	17	7.54	2554	8.87	2633	9.85	2660	10.83	2714	11.77	2857	12.71	3000	13.35	3090	13.75	3151
	18	7.45	2575	8.76	2654	9.74	2681	10.70	2736	11.63	2880	12.56	3024	13.19	3114	13.58	3177
	19	7.36	2595	8.66	2676	9.62	2703	10.57	2758	11.49	2903	12.41	3048	13.03	3140	13.42	3202
	20	7.29	2616	8.57	2697	9.53	2725	10.47	2780	11.38	2926	12.29	3073	12.90	3165	13.29	3228
	21	7.20	2645	8.47	2727	9.41	2754	10.34	2811	11.24	2959	12.14	3107	12.75	3200	13.13	3264
	22	7.11	2674	8.37	2757	9.30	2785	10.22	2842	11.11	2991	12.00	3141	12.60	3235	12.97	3300
	23	7.03	2704	8.27	2787	9.19	2815	10.10	2873	10.97	3024	11.85	3175	12.44	3271	12.82	3336
	24	6.94	2733	8.17	2818	9.08	2846	9.97	2904	10.84	3057	11.71	3210	12.29	3307	12.66	3373
	25	6.86	2763	8.07	2849	8.97	2878	9.85	2936	10.71	3091	11.57	3246	12.15	3343	12.51	3410
	26	6.78	2794	7.97	2880	8.86	2909	9.74	2969	10.58	3125	11.43	3281	12.00	3380	12.36	3447
	27	6.70	2825	7.88	2912	8.75	2941	9.62	3001	10.46	3159	11.29	3317	11.86	3417	12.21	3485
	28	6.62	2856	7.78	2944	8.65	2974	9.50	3034	10.33	3194	11.16	3354	11.71	3454	12.07	3523
	29	6.54	2887	7.69	2976	8.55	3006	9.39	3068	10.21	3229	11.02	3391	11.57	3492	11.92	3562
	30	6.46	2919	7.60	3009	8.44	3039	9.28	3102	10.08	3265	10.89	3428	11.44	3531	11.78	3601
110%	15	7.49	2464	8.82	2540	9.80	2566	10.77	2618	11.70	2756	12.64	2894	13.27	2981	13.67	3040
	16	7.41	2484	8.71	2561	9.68	2587	10.64	2639	11.56	2778	12.49	2917	13.11	3005	13.51	3065
	17	7.32	2504	8.61	2581	9.57	2607	10.51	2661	11.43	2801	12.34	2941	12.96	3029	13.35	3090
	18	7.23	2524	8.51	2602	9.45	2629	10.39	2682	11.29	2823	12.19	2964	12.80	3053	13.19	3114
	19	7.15	2545	8.41	2623	9.34	2650	10.26	2704	11.16	2846	12.05	2988	12.65	3078	13.03	3140
	20	7.07	2565	8.32	2644	9.25	2671	10.16	2726	11.05	2869	11.93	3013	12.53	3103	12.90	3165
	21	6.99	2593	8.22	2673	9.14	2700	10.04	2756	10.91	2901	11.79	3046	12.38	3137	12.75	3200
	22	6.91	2622	8.12	2703	9.03	2730	9.92	2786	10.78	2933	11.65	3079	12.23	3172	12.60	3235
	23	6.82	2651	8.03	2733	8.92	2760	9.80	2817	10.65	2965	11.51	3113	12.08	3206	12.44	3271
	24	6.74	2680	7.93	2763	8.81	2791	9.68	2848	10.53	2997	11.37	3147	11.94	3242	12.29	3307
	25	6.66	2709	7.84	2793	8.71	2821	9.57	2879	10.40	3030	11.23	3182	11.79	3277	12.15	3343
	26	6.58	2739	7.74	2824	8.60	2852	9.45	2911	10.27	3064	11.10	3217	11.65	3313	12.00	3380
	27	6.50	2769	7.65	2855	8.50	2884	9.34	2943	10.15	3097	10.96	3252	11.51	3350	11.86	3417
	28	6.42	2800	7.56	2886	8.40	2915	9.23	2975	10.03	3131	10.83	3288	11.37	3387	11.71	3454
	29	6.35	2830	7.47	2918	8.30	2947	9.12	3008	9.91	3166	10.70	3324	11.24	3424	11.57	3492
	30	6.27	2862	7.38	2950	8.20	2980	9.01	3041	9.79	3201	10.57	3361	11.10	3462	11.44	3531

4. CAPACITIES AND SELECTION DATA

HEATING PERFORMANCE DATA

COMBINATION (%)	INDOOR DB(°C)	OUTDOOR WB(°C)															
		-15		-10		-5		0		5		10		15		20	
		Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT
100%	15	7.28	2392	8.56	2466	9.51	2491	10.45	2542	11.36	2676	12.27	2810	12.88	2894	13.27	2952
	16	7.19	2412	8.46	2486	9.40	2511	10.33	2563	11.23	2697	12.13	2832	12.73	2917	13.11	2976
	17	7.11	2431	8.36	2506	9.29	2532	10.21	2583	11.09	2719	11.98	2855	12.58	2941	12.96	3000
	18	7.02	2451	8.26	2526	9.18	2552	10.09	2604	10.96	2741	11.84	2878	12.43	2964	12.80	3024
	19	6.94	2470	8.16	2547	9.07	2573	9.97	2625	10.83	2763	11.70	2901	12.28	2988	12.65	3048
	20	6.87	2490	8.08	2567	8.98	2593	9.87	2646	10.73	2785	11.58	2925	12.16	3013	12.53	3073
	21	6.79	2518	7.98	2596	8.87	2622	9.75	2675	10.60	2816	11.44	2957	12.02	3046	12.38	3107
	22	6.71	2545	7.89	2624	8.76	2651	9.63	2705	10.47	2847	11.31	2989	11.87	3079	12.23	3141
	23	6.62	2573	7.79	2653	8.66	2680	9.52	2734	10.34	2878	11.17	3022	11.73	3113	12.08	3175
	24	6.55	2602	7.70	2682	8.56	2709	9.40	2765	10.22	2910	11.04	3056	11.59	3147	11.94	3210
	25	6.47	2630	7.61	2712	8.45	2739	9.29	2795	10.10	2942	10.90	3089	11.45	3182	11.79	3246
	26	6.39	2659	7.52	2742	8.35	2769	9.18	2826	9.98	2974	10.77	3123	11.31	3217	11.65	3281
	27	6.31	2689	7.43	2772	8.25	2800	9.07	2857	9.86	3007	10.64	3158	11.18	3252	11.51	3317
	28	6.24	2718	7.34	2802	8.15	2830	8.96	2888	9.74	3040	10.52	3192	11.04	3288	11.37	3354
	29	6.16	2748	7.25	2833	8.05	2862	8.85	2920	9.62	3074	10.39	3227	10.91	3324	11.24	3391
	30	6.09	2778	7.16	2864	7.96	2893	8.74	2952	9.51	3108	10.27	3263	10.78	3361	11.10	3428
COMBINATION (%)	INDOOR DB(°C)	OUTDOOR WB(°C)															
		-15		-10		-5		0		5		10		15		20	
		Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT
90%	15	7.02	2349	8.26	2422	9.18	2446	10.09	2496	10.96	2628	11.84	2759	12.43	2842	12.81	2899
	16	6.94	2368	8.16	2441	9.07	2466	9.97	2516	10.83	2649	11.70	2781	12.29	2865	12.65	2922
	17	6.86	2387	8.07	2461	8.96	2486	9.85	2537	10.71	2670	11.56	2804	12.14	2888	12.50	2946
	18	6.78	2407	7.97	2481	8.86	2506	9.73	2557	10.58	2692	11.42	2826	12.00	2911	12.36	2969
	19	6.69	2426	7.88	2501	8.75	2526	9.62	2578	10.45	2713	11.29	2849	11.85	2935	12.21	2993
	20	6.63	2446	7.80	2521	8.66	2547	9.52	2599	10.35	2735	11.18	2872	11.74	2958	12.09	3017
	21	6.55	2472	7.70	2549	8.56	2575	9.41	2627	10.23	2765	11.04	2904	11.60	2991	11.94	3051
	22	6.47	2500	7.61	2577	8.46	2603	9.29	2656	10.10	2796	10.91	2936	11.46	3024	11.80	3084
	23	6.39	2527	7.52	2605	8.36	2632	9.18	2685	9.98	2827	10.78	2968	11.32	3057	11.66	3118
	24	6.32	2555	7.43	2634	8.26	2661	9.07	2715	9.86	2858	10.65	3001	11.18	3091	11.52	3152
	25	6.24	2583	7.34	2663	8.16	2690	8.96	2745	9.74	2889	10.52	3034	11.05	3125	11.38	3187
	26	6.17	2611	7.25	2692	8.06	2719	8.86	2775	9.63	2921	10.40	3067	10.92	3159	11.24	3222
	27	6.09	2640	7.17	2722	7.96	2749	8.75	2805	9.51	2953	10.27	3101	10.79	3194	11.11	3258
	28	6.02	2669	7.08	2752	7.87	2780	8.65	2836	9.40	2986	10.15	3135	10.66	3229	10.98	3293
	29	5.95	2699	7.00	2782	7.77	2810	8.54	2867	9.28	3018	10.03	3169	10.53	3264	10.84	3330
	30	5.87	2728	6.91	2813	7.68	2841	8.44	2899	9.17	3052	9.91	3204	10.40	3300	10.71	3366
COMBINATION (%)	INDOOR DB(°C)	OUTDOOR WB(°C)															
		-15	-10	-5	0	5	10	15	20	-15	-10	-5	0	5	10	15	20
		Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT	Q	INPUT
80%	15	6.81	2326	8.01	2398	8.90	2422	9.78	2471	10.64	2601	11.49	2731	12.06	2813	12.42	2870
	16	6.73	2345	7.92	2417	8.80	2441	9.67	2491	10.51	2622	11.35	2753	11.92	2836	12.27	2893
	17	6.65	2363	7.82	2437	8.69	2461	9.55	2511	10.38	2644	11.22	2776	11.78	2859	12.13	2916
	18	6.57	2382	7.73	2456	8.59	2481	9.44	2532	10.26	2665	11.08	2798	11.64	2882	11.99	2940
	19	6.49	2402	7.64	2476	8.49	2501	9.33	2552	10.14	2686	10.95	2821	11.50	2905	11.84	2963
	20	6.43	2421	7.56	2496	8.40	2521	9.24	2573	10.04	2708	10.84	2843	11.38	2929	11.73	2987
	21	6.35	2448	7.47	2523	8.30	2549	9.13	2601	9.92	2738	10.71	2875	11.25	2961	11.59	3020
	22	6.28	2475	7.38	2551	8.20	2577	9.02	2629	9.80	2768	10.58	2906	11.11	2993	11.45	3053
	23	6.20	2502	7.30	2579	8.11	2605	8.91	2658	9.68	2798	10.46	2938	10.98	3026	11.31	3087
	24	6.13	2529	7.21	2608	8.01	2634	8.80	2688	9.57	2829	10.33	2971	10.85	3060	11.17	3121
	25	6.05	2557	7.12	2636	7.91	2663	8.69	2717	9.45	2860	10.21	3003	10.72	3093	11.04	3155
	26	5.98	2585	7.04	2665	7.82	2692	8.59	2747	9.34	2892	10.08	3036	10.59	3127	10.91	3190
	27	5.91	2614	6.95	2695	7.72	2722	8.49	2777	9.23	2924	9.96	3070	10.46	3162	10.78	3225
	28	5.84	2642	6.87	2724	7.63	2752	8.39	2808	9.11	2956	9.84	3103	10.34	3197	10.65	3260
	29	5.77	2672	6.79	2754	7.54	2782	8.29	2839	9.01	2988	9.73	3138	10.21	3232	10.52	3296
	30	5.70	2701	6.70	2784	7.45	2813	8.19	2870	8.90	3021	9.61	3172	10.09	3267	10.39	3333

5AMW125U4RTA

-

UE MULTI 5 POSTES 12,5 KW

5AMW125U4RTA

-

UE MULTI 5 POSTES 12,5 KW

Up to 5 IDUs

5AMW125U4RTA - UE MULTI 5 POSTES 12,5 KW

AMW5-42U4RTA

COOLING CAPACITY (W)

Indoor temperature		Outdoor temperature (°C DB)						
(°C DB)	(°C WB)	15	20	25	30	35	40	45
22	16	10250	10625	10750	11125	11250	10000	8375
27	19	13250	13125	13000	12750	12500	11250	9125
30	22	13125	13750	13625	13750	14000	12500	10000

(°C DB) : Dry Bulb Temperature (°C)

(°C WB) : Wet Bulb Temperature (°C)

HEATING CAPACITY (W)

Indoor temperature	Outdoor temperature DB (°C)							
DB (°C)	-15	-10	-5	0	5	10	15	20
16	8505	9450	10530	11880	12015	12150	12285	12420
20	8748	9720	10935	12150	13230	13905	14850	14580
24	9113	10125	12150	13500	14850	15525	16605	13230

(°C DB) : Dry Bulb Temperature (°C)

(°C WB) : Wet Bulb Temperature (°C)