

Combined ceiling diffuser

11044121

Manual trip device

The manual trip device is used in a smoke and heat exhaust system in multi-occupancy housing.



PRODUCT BENEFITS

- compliance: NF-S 61936,
- easily identified red box,
- simple and fast to install.

Principles of operation

The manual activation device is used to report the outbreak of a fire. Once activated manually, it reports the information to the smoke exhaust control panel.

Product description

The manual trip device is used in a smoke and heat exhaust system in multi-occupancy housing. One must be installed in the stairwell on each storey.

Fields of application

Multi-occupancy residential housing, New, Refurbishment

Installation

- for installation in stairwell on each storey,
- screw attachment.

Reference arguments

- Manual trip device for use in a smoke and heat exhaust system in multi-occupancy housing, for installation on each storey in the stairwell.

Main characteristics

- compliance: NF-S 61936,
- red ABS,
- dimensions: 90 x 90 x 35 mm.

Accessories

Description	Variants
ParkONE CAR PARK DAH 2 FANS	11057539